

LSMC ICU Expansion - Final Development Plan Review

LSMC ICU Expansion - Final Development Plan Review						
Item	Requested By	Question / Issue	Dept/Individual R	Status	Notes	Design Team Response
Engineering Review						
1	Loic Nguingiri	Cover Sheet	ACIB	Closed	Add to the cover sheet: the developer's contact information and the utility contact information.	See revised sheets
2	Loic Nguingiri	Sheet C2.0	GBA	Closed	On sheet C2.0, add the information for the 8" (E) inflow and revise the calculation for the 6" (W) inflow at proposed storm structure 3. Storm structure 4 also needs to clearly show elevations of inflow and outflow, plus cardinal directions of each. Make sure to revise sheet C4.0 accordingly	See revised sheets
3	Loic Nguingiri	Storm Data	GBA	Closed	Add the 100-year storm data to the table located on sheet C3.0. Make sure to also show and label the 100-year HGL on sheet C4.0	See revised sheets