

Minor Plat Applicant's Letter

Date: Friday, April 15, 2022

To:

Property Owner: CLAYTON PROPERTIES Email:
GROUP INC

Applicant: ENGINEERING SOLUTIONS Email: MSCHLICHT@ES-KC.COM

From: Dawn Bell, Project Manager

Re:

Application Number: PL2022110

Application Type: Minor Plat

Application Name: OSAGE LOTS 20A & 20B MINOR PLAT

Location: 2003 SW OSAGE DR, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

All Planning applicaiton and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in mulit-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Review Status:

Required Corrections:

Planning Review	Shannon McGuire	Planner	Corrections
------------------------	-----------------	---------	-------------

DEVELOPMENT SERVICES

(816) 969-1237

Shannon.McGuire@cityofls.net

1. Please include the total acreage of the proposed subdivision.
2. Please remove "GIS Dept." from the county signature block.
3. Please removed the building footprint and set back labels from the plat drawing.
4. Please provide coordinates, based on the Missouri Coordinate System 1983, on the corners of the plat boundary, the control station, station coordinates, and grid factor used in accordance with the regulations of the Missouri Department of Natural Resources. Two corners are missing on the eastern side of the property.

Engineering Review	Loic Nguingiri, E.I.	Staff Engineer Loic.Nguingiri@cityofls.net	No Comments
---------------------------	----------------------	---	-------------

GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	Corrections
-------------------	---------------------------------	--	-------------

1. Please provide an ITB on either end of the curve.