

May 3, 2022

Re: Highland Meadows 6th Plat

Anderson Engineering has received your comments dated May 2, 2022 and have the following responses:

City of Lee's Summit – Asbuilt Review – Street/Storm
Sue Pyles, P.E. – (816) 969-1245

1. Please choose the most appropriate option within the bracket in the As-Graded certification. **Certification statement has been revised to say that the information was obtained by my firm.**
2. Please include the existing contours beyond the as-built contours. They should tie together to provide a complete picture of the grading. **The site was topographically surveyed up to the Highland Meadow - 6th Plat, platted boundary. Any additional surface data that we have available was added to the plan with this resubmittal.**
3. The following spot elevations do not match the as-graded contours. Please revise as needed.
 - a. Lot 168/Lot 169 rear lot corner.
 - b. Ex Lot 123/Ex Lot 124 intersection with Lot 171.
 - c. Lot 194 both rear lot corners.**Spot elevations at the locations listed above have been reviewed and corrected as necessary.**

If you have any further questions, feel free to contact me at 913-284-9362 or by email at gcates@ae-inc.com.

Sincerely,



Garrett Cates, PE
Anderson Engineering Inc.
941 W 141st Terr, Suite A
Kansas City, MO 64145