

Date: Sunday, May 08, 2022

To: POWELL CWM INC
3200 S STATE ROUTE 291 BLDG 1
INDEPENDENCE, MO 64057

From:

Application Number: PL2022165
Application Type: Engineering Plan Review
Application Name: Lakewood Business Center on I-470 Plat S - Erosion and Sediment Control and Mass Grading

The Development Services Department has completed its review of the above-referenced plans dated Mar. 31, 2022 and offer the following comments listed below.

- See comments below to determine the required revisions and resubmit to the Development Services Department public portal located at devservices.cityofls.net. Digital documents shall follow the electronic plan submittal guides as stated below.
- Revised plans will be reviewed within ten (10) business days of the date received.

Engineering Review

1. The erosion and sediment control plan was not submitted in a standalone format, but rather, appear to be a submittal of the Street and Stormwater plans with the erosion and sediment control and mass grading. Is a separate permit being sought for the erosion and sediment control with mass grading? If so, please break it down to erosion and sediment control, along with any mass grading to be performed with the erosion and sediment control. If a separate permit is not being sought for erosion and sediment control and mass grading, then it will become a part of the Street and Stormwater plans already submitted.
2. A SWPPP is required prior to formal approval of any plans on this project.
3. Are there any wetlands on this project?

Traffic Review - Not Required

In order to calculate the Engineering Plan Review and Inspection Fee, a sealed Engineer's Opinion of Probable Construction Costs shall accompany your final submittal copies. The itemized estimate (material and installation) shall be sufficiently broken down and shall include the following items, as applicable.

- Public infrastructure, both onsite and offsite.
- Private street construction, including parking lots and driveways.

- Sidewalks located within the right-of-way.
- ADA accessible ramps.
- Sanitary sewer manholes and piping between manholes, including private mains.
- Connection of the building sanitary sewer stub to the public main.
- Waterlines larger than 2 inches in diameter, valves, hydrants, and backflow preventer with vault, if outside the building.
- Stormwater piping greater than 6 inches in diameter, structures, and detention / retention facilities - public or private.
- Water quality features installed to meet the 40-hour extended duration detention requirements.
- Grading for detention / retention ponds.
- Grading to establish proper site drainage.
- Utility infrastructure adjustments to finished grade (i.e. manhole lids, water valves, etc.).
- Erosion and sediment control devices required for construction.
- Re-vegetation and other post-construction erosion and sediment control activities.

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact me if you have any questions or comments.

Sincerely,

/s/ electronically signed May 8, 2022

Gene Williams, P.E.
Senior Staff Engineer

cc: Development Engineering Project File