

Jim Long

From: Gene Williams <Gene.Williams@cityofls.net>
Sent: Tuesday, May 24, 2022 8:43 AM
To: Jim Long
Cc: Amanda Bagwell; Mike Weisenborn
Subject: PL2021433 The Manor at Bailey Farms 1st Plat - Sanitary Sewer Final QA/QC Check

Hello Jim,

Water Utilities performed a final QA/QC check of the plans and noted the following issues that must be addressed prior to issuance of an MDNR concurrence letter:

1. Line Segments from manhole A2 manhole A1 and manhole A1 to the existing manhole should be restrained joint zinc-coated DIP in accordance with the Design and Construction Manual.
2. Please call out the existing manhole as 47-138.
3. (Minor Comment but please change since you are resubmitting): Please change Public Works Director to Michael Park.

We will not be able to issue the MDNR concurrence letter until these have been corrected. Please see previous email concerning this issue. Let me know if there are any questions.



Gene Williams, P.E., CFM | Senior Staff Engineer
220 SE Green Street | Lee's Summit, MO 64063
816.969.1223 | cityofLS.net | Gene.Williams@cityofls.net



CONFIDENTIALITY NOTICE: "This electronic message transmission (including any accompanying attachments) from www.cityofls.net is intended solely for the person or entity for its intended recipient(s) and may contain information that is confidential, privileged, or otherwise protected from disclosure. The information contained is intended solely for the use of the individual(s), organization(s) or entity(ies) named above. If you have received this transmission but are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or use of the contents of this message is strictly prohibited. If you have received this e-mail in error, please contact sender immediately by Reply e-mail and delete/destroy the original message and all copies."

Although this e-mail and any attachments are believed to be free of any virus or other defect that might negatively affect any computer system into which it is received and opened, it is the responsibility of the recipient to ensure that it is virus free and no responsibility is accepted by the sender for any loss or damage arising in any way in the event that such a virus or defect exists.