



May 24, 2022

Gene Williams, PE
City of Lee's Summit, Missouri
220 SE Green Street
Lee's Summit, MO 64063

**RE: PL2021433 MANOR AT BAILEY FARMS 1ST PLAT
SANITARY SEWER PLANS FINAL QA/QC**

This letter is regarding the above referenced emailed comments on May 24, 2022 at 8:43 a.m. to which we have the following responses:

1. Line Segments from manhole A2 manhole A1 and manhole A1 to the existing manhole should be restrained joint zinc-coated DIP in accordance with the Design and Construction Manual.

Response: Note has been revised to include "Restrained Joints".

2. Please call out the existing manhole as 47-138.

Response: Added to plan and profiles on Sheet 6 and to Sheets 2 and 3

3. (Minor Comment but please change since you are resubmitting): Please change Public Works Director to Michael Park.

Response: Revised

We appreciate your review. Should you have any further comments or questions please contact me.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.

A handwritten signature in blue ink, appearing to read 'Jim Long', is written over a light blue horizontal line.

Jim Long, PE
Sr. Project Engineer
Direct Dial 913-322-7146
JL@schlagelassociates.com