

June 1, 2022

Gene Williams
City of Lee's Summit
220 SE Green St
Lee's Summit, MO 64063

**RE: PL2021484 CORNERSTONE AT BAILEY FARMS 1ST PLAT
WATER LINE QA/QC COMMENTS FROM WATER UTILITIES
DATED MAY 31, 2022 VIA EMAIL**

This letter is in response to the above-referenced comments:

Water Utilities had the following comments related to the above application that need correction prior to issuing the MDNR concurrence letter:


1. The note at Sta. 0+00 Line 6 of Cornerstone at Bailey farms states to remove the end of line assembly. The gate valve on the end of line assembly needs to stay at this location. This is likely the case at other locations where end of line assemblies are installed.

Response: Added note to the plan and profile views that the valve is to remain. Applied the same note to Sta. 0+00, Line 7.

Should you have additional comments, please let me know. Thank you.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.



Jim Long, PE
Sr. Project Engineer
Direct 913-322-7146
JL@schlagelassociates.com

/mr
Enclosure