

July 5, 2022

Ms. Sue Pyles, P.E.
Development Services
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

**Re: Summit View Farms 4th Plat
PL2019392 (Street & Storm), PL2019393 (Sanitary), PL2019394 (Water)
Record Drawings - Responses to City Comments**

Dear Ms. Pyles:

Lamp Rynearson has prepared responses to the City comments received on June 2, 2022 for this project. Lamp Rynearson has provided responses to the comments in **bold**.

PL2019392 Street & Storm

1. The following structures do not meet City requirements for drop across structure. Please review elevations and address:
 - Line 4-10: 10G, 10F, 10E
 - Line 4-13: 13F
 - Line 4-14: 13C
 - Line 4-15: 15B

All of these storm sewer invert elevations have been confirmed and are measured as-constructed elevations. The storm sewer will function as designed.

PL2019393 Sanitary

1. The following MHs do not meet City requirements for drop across structure. Please review elevations and address:
 - Line 4-A: A8, A7, A2, A1
 - Line 4-C: C3, C1
 - Line 4-D: D2, D1

All of these sanitary sewer invert elevations have been confirmed and are measured as-constructed elevations. The sanitary sewer will function as designed.

2. MH A-2 has 2 additional elevations shown in () in the Lines A-C Profile views. Please clarify.

The two additional elevations shown in parenthesis are the lower drop elevations from the north and the east directions.

PL2019394 Water

1. All Line 4-01 bends other than the first one have all been crossed out. Please revise.

Per discussions with the Contractor, bends that are crossed out on Line 4-01 were not installed. The pipe joints were deflected in accordance with manufacturer's recommendations.

Sincerely,

LAMP RYNEARSON



Dan McGhee, P.E.
Senior Project Manager

cc: Project File