

Tuesday, August 02, 2022

Attn: Sue Pyles, P.E.

City of Lee's Summit, Missouri 220 SE Green Street Lee's Summit, MO 64063

SUBJECT: TIFFANY WOODS LOTS 4C AND 7C - HYDRANT RELOCATION (PL2022265)

This letter provides responses to comments as provided August 2nd, 2022. Please note the following formatting conventions:

- Comments as provided or described as well as possible shall be italicized. This includes interpretations of markups such as circled plan areas that do not have supporting descriptions.
- Responses to comments shall be bold.

If v	ou have anv	questions or need	additional in	formation.	please d	o not hesitate	to contact us.
------	-------------	-------------------	---------------	------------	----------	----------------	----------------

Thanks,

Daniel Goodwin

- Install the straddle block symbol in the Plan View Legend.
 Straddle block symbol has been added to Plan View Legend.
- Include a call-out for the straddle block in Plan View.
 Call-out has been added for the straddle block in Plan View.
- 3. Include the necessary City Standard Details (WAT-3 and WAT-7) in the plan set. Details WAT-3 and WAT-7 have been added to plan set as a detail sheet.
- **4.** The City will allow the existing main to be either abandoned in place or removed. Please specify which alternative will be used.

Existing main to be abandoned and capped. Note revised in plan set to indicate abandonment.