



Project: Woodland Oaks 1st Plat – Public Low Pressure Sanitary Sewer System

Application Number: PL2021074

Application Type: Engineering Plan Review

Comments Dated: July 22, 2022

Engineering Review

Note 7 on the Cover Sheet names an epoxy supplier and series that does not meet the requirements of
the most recent version of the standard specifications, Section 3500 – Sanitary Sewers, Paragraph
3501.P.10 nor is it included on the Water Utilities Department Approved Products List. Epoxy
supplier revised to meet current standards and Approved Products List.

2. Cost estimate was missing the following item; 1) epoxy-lining of manholes, 2) connection to existing line, 3) boring costs (assuming this is separate since the linear foot cost for pipe seemed low). **Stated items have been included on revised estimate, see enclosed.**

Please forward all comments or concerns to Matthew Schlicht.