



August 17, 2022

City of Lee's Summit
Attn: Sue Pyles, PE
220 SE Green Street
Lee's Summit, MO 64063

**RE: PERGOLA PARK 5TH PLAT – PUBLIC WATER
PL2021452**

This letter is in response to staff comments for the above-referenced project dated August 2nd, 2022.

Engineering Review – Corrections

1. Please revise the Line 1 / Line 3 connection location as shown in the attached exhibit in order to eliminate the skewed storm crossing and the need to locate the tee on a slope.

Response: The location of the tee has been adjusted to avoid the storm crossing.

2. Please show the storm crossing located just north of the Street A curb inlet in profile view.

Response: Storm crossing has been added.

3. With the revision to make the Lumberman's Row water main plan a long dead end, where will the Pergola Park 6th Plat water main extension be connected? It would appear that a line should be extended across Blue Ribbon Lane just north of the roundabout.

Response: Would a line going down the alley for 6th plat be acceptable as there is no sanitary in this alley compared to the past plats? Or we could run a line to the west of 6th plat (along Pergola Park Dr.) that serves the western lots of 6th plat and then the lots adjacent to Blue Ribbon Ln would be served by Line 1 on the east side of Blue Ribbon Ln?

Should you have any questions , please contact me. Thank you.

Sincerely,

SCHLAGEL & ASSOCIATES, P.A.

Brad Luebbert, IE
Staff Engineer
Direct 913-322-7151
BL@schlagelassociates.com

/mr
Attachments