DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date: Wednesday, September 07, 2022

To:

	10.	Applicant: BHC R	RHODES	Email: JEFF.BARTZ@IBHC.COM or PATRICK.JOYCE@IBHC.COM		
		Property Owner	: DH4 HOLDINGS LLC	Email: DAVID.HILL@DH4HOLDINGS.COM		
		Architect: SLAGG	GIE ARCHITECTS INC	Email: PDOUGHERTY@SLAGGIE.COM		
	From:	Mike Weisenbor	m, Project Manager			
Re: Application Number: Application Type: Application Name:		ation Number:	PL2022251			
			Commercial Final Development Plan K1 Speed			
		ation Name:				
	Locatio	on:	2911 NE INDEPENDENCE AVE, I	EES SUMMIT, MO 64064		

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
Engineering Review	Nikia Chapman-Freiberger (816) 969-1813	Nikia.Chapman-Freiberger@cityofls. net	Approved with Conditions

1. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.

2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.

3. Prior to any activities within the right-of-way that are not directly associated with a specific infrastructure or building permit, a separate right-of-way permit may be required. Contact a Right-of-Way Inspector at (816) 969-1800 to obtain the required permit.

4. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$74,667.42

5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	
conditions in new and ex	kisting buildings, structur	protection from the hazards of fir es and premises, and to the safety e in accordance with the 2018 Inte	to fire fighters and emergency
Traffic Review	Brad Cooley, P.E., RSPI	Brad.Cooley@cityofls.net	No Comments
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

1. Information:

- Review did not include architectural plans

- 4 sided screening required for hvac equipment. If roof mounted screening must be by parapets. If ground mounted screening can be either masonry or evergreen landscaping.

7/29/22 - acknowledged in letter

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development