

PRELIMINARY STORMWATER REPORT

FOR

HCA LSMC ASC

1950 SE Shenandoah Drive
Lee's Summit, MO 64063

Prepared By:

BHC

7101 College Blvd, Suite 400
Overland Park, KS 66210
913-663-1900

Prepared For:

Hammes Partners

1400 N. Water Street, Suite 500
Milwaukee, WI 53202

BHC RHODES # 034660

October 21, 2022



TABLE OF CONTENTS

1.0	GENERAL INFORMATION	4
2.0	METHODOLOGY	5
3.0	EXISTING CONDITIONS ANALYSIS.....	5
3.1	Watershed	5
3.2	Calculations.....	6
4.0	PROPOSED CONDITIONS ANALYSIS	6
4.1	Watershed	6
4.2	Calculations.....	6
5.0	CONCLUSIONS AND RECOMMENDATIONS.....	7

APPENDICES

Appendix A – Reference Documents

- A1. Aerial Photograph of Project Area
- A2. National Wetland Inventory Map
- A3. NRCS Soils Report
- A4. FEMA Firmette – Panel 29095C0439G

Appendix B – Drainage Maps

- B1. Existing Drainage Map
- B2. Proposed Drainage Map

Appendix C – Calculations

- C1. PondPack Output

1.0 GENERAL INFORMATION

This preliminary stormwater report is in support of a new approximately 20,000 square foot ambulatory surgery center on the HCA Lee's Summit Medical Center campus. The entire campus is approximately 28.5-acres located between SE Shenandoah Drive and SE Blue Parkway to the west of SE Cumberland Drive in Lee's Summit, Missouri. This proposed project will be on an approximately 4-acre piece of the southwest corner of the overall campus property. The site is currently vacant and used for agricultural purposes and is separated on the east by a wooded stream from the main hospital campus. The site lies within the northwest quarter of Section 10, Township 47, Range 31, in Jackson County. The site lies entirely within the South Prairie Lee watershed.

The site is generally rectangular. The site is bounded on the south by SE Blue Parkway and US 50 Highway, to the west by SE Cumberland Drive and vacant land, to the north by undeveloped land, and to the east by the existing Lee's Summit Medical Center campus. Refer to the aerial photograph in Appendix A for existing cover conditions and surrounding land use.

The proposed project consists of a one-story, approximately 20,000 square foot surgery center. The project will include the construction of parking lot and drive aisles, sidewalks, storm drainage improvements, and utility relocations.

The site generally consists of one watershed that slopes gently from the west to east. It eventually works to a wooded stream that runs along the east edge of the property to be developed. The property does not have any special flood hazard areas on it. Thus, there will be no floodplain issues with the project and no permitting will be needed with FEMA. All existing drainage patterns will be generally maintained.

Along the east side of the site is an existing wooded stream area. This stream has an upstream tributary greater than 40 acres but less than 160 acres. This requires a stream buffer of 60 feet on either side of the ordinary high-water mark for the stream. This stream buffer will not be encroached upon with the project.

The soil types that have been identified on the site for the areas to be disturbed are Arisbug-Urban land complex (1-5% slopes) and Udarents-Urban land-Sampsel complex (2-5% slopes). The soil type falls within Hydraulic Soil Group (HSG) C for the site. For additional information pertaining to the soils, refer to the NRCS soils report included in Appendix A.

The purpose of this plan is to identify existing and potential drainage issues, delineate required stormwater facilities and document that stormwater runoff from the development will not have an adverse impact on existing properties adjacent to or downstream of the project.

2.0 METHODOLOGY

To calculate stormwater runoff rates, the software Bentley PondPack V8i was used to model the drainage basins and ponds. The unit hydrograph method is used to determine runoff levels, based on the SCS, Type II 24-hour rainfall. The hydrograph routing through the ponds uses the modified-Puls level pool routing method. Storm events for the 50%, 10%, and 1% chance events were evaluated based on the comprehensive control requirements. As well, the 90% mean annual event was modeled to be released over a 40-hour period. The rainfall depths used are from "Precipitation Frequency Estimates for the Kansas City Metropolitan Area" (McEnroe, 2002) as shown below in Table 1.

Table 1 – Rainfall Depth (in.)

Storm Event	90%	50%	10%	1%
Depth	1.37	3.55	5.25	7.94

Analysis of the storm drainage systems followed all adopted City of Lee's Summit codes, ordinances, and design criteria. The stormwater facility design was analyzed using the current Section 5600 of KCAPWA and APWA/MARC BMP Manual design criteria.

3.0 EXISTING CONDITIONS ANALYSIS

3.1 WATERSHED

The site consists of one watershed that currently sheet drains to the east to the existing wooded area and stream. The entire site is within the South Prairie Lee Watershed. Refer to the Existing Drainage Area Map in Appendix B. Table 2 below summarizes the existing runoff conditions on the property.

Table 2 – Existing Runoff Conditions

Drainage Sub-Basin	Area (acres)	Runoff Coeff. (CN)	Time of Conc. (min.)	50% Runoff Rate (cfs)	10% Runoff Rate (cfs)	1% Runoff Rate (cfs)
Existing	3.94	85	10	11.03	18.88	31.35

3.2 CALCULATIONS

The site will need to follow the comprehensive control requirements outlined in section 5608.4 of the APWA design criteria. This allows 0.5 cfs per acre for the 50% event, 2.0 cfs per acre for the 10% event, and 3.0 cfs per acre for the 1% event. Refer to Table 3 below for the allowable release rates the site for each respective storm event

Table 3 – Allowable Release Rates (cfs)

Drainage Sub-Basin	50%	10%	1%
Existing	1.97	7.88	11.82

4.0 PROPOSED CONDITIONS ANALYSIS

4.1 WATERSHED

The site will generally maintain the same drainage patterns as currently exist. The site will be split into three watersheds in the proposed condition. The south part of the site and the building will be conveyed to a detention pond on the southwest corner. The north part of the site will be conveyed to a detention pond on the northeast corner. A small portion of the north end of the site will surface drain off the site undetained. Everything will continue to generally drain and discharge to the wooded area and stream along the east boundary of the site. Refer to the Proposed Drainage Map in Appendix B for more detailed information.

4.2 CALCULATIONS

To analyze the proposed conditions, the software Bentley PondPack V8i was used to model the drainage basins and ponds. The unit hydrograph method was used to determine runoff levels for the proposed conditions, based on the SCS, Type II 24-hour rainfall. The hydrograph routing through the ponds used the modified-Puls level pool routing method. The ponds and their outlets were designed so that the peak flows for the 50%, 10%, and 1% storm events at the proposed condition would not exceed the allowable release rates. The primary outlet control for the ponds will consist of an outlet control structure containing multiple orifices. This will then have a discharge pipe. The ponds are also designed to release the water quality event over a 40-hour period. See Table 4 below for a summary of the peak flows and water surface elevations for the detention and refer to the runoff calculations in Appendix C for detailed calculations. Table 5 shows a comparison between the allowable and proposed peak runoff rates. The proposed condition produces lower peak runoff rates than the allowable runoff rates.

Table 4 – Proposed Watershed Conditions

Drainage Sub-Basin	Runoff Coeff. (CN)	Time of Conc. (min)	Area (AC)	Proposed 50% Peak Flow (cfs)	50% Max. W.S.E.	Proposed 10% Peak Flow (cfs)	10% Max. W.S.E.	Proposed 1% Peak Flow (cfs)	1% Max. W.S.E.
North	91	5	1.12	4.32	-	6.90	-	10.92	-
N Detention	-	-	-	0.39	982.90	1.17	983.70	1.88	984.76
South	90	5	2.36	8.86	-	14.31	-	22.82	-
S Detention	-	-	-	0.50	986.17	2.17	986.98	8.03	987.96
Undetained	82	5	0.46	1.26	-	2.29	-	3.97	-

Table 5 –Allowable vs. Proposed Release Rates (cfs)

Condition	50%	10%	1%
Allowable	1.97	7.88	11.82
Proposed	1.83	4.33	11.76

5.0 CONCLUSIONS AND RECOMMENDATIONS

This preliminary stormwater report is in support of a new approximately 20,000 square foot ambulatory surgery center on the HCA Lee's Summit Medical Center campus. The entire campus is approximately 28.5-acres located between SE Shenandoah Drive and SE Blue Parkway to the west of SE Cumberland Drive in Lee's Summit, Missouri. This proposed project will be on an approximately 4-acre piece of the southwest corner of the overall campus property. The site is currently vacant and used for agricultural purposes and is separated on the east by a wooded stream from the main hospital campus.

The proposed project consists of a one-story, approximately 20,000 square foot surgery center. The project will include the construction of parking lot and drive aisles, sidewalks, storm drainage improvements, and utility relocations.

The site consists of one watershed currently that slopes gently from the west to east. It eventually works to a wooded stream that runs along the east edge of the property to be developed. All existing drainage patterns will be generally maintained. The existing wooded stream area along the east edge of the site will require a stream buffer of 60 feet on either side of the ordinary high-water mark for the stream. This


stream buffer will not be encroached upon with the project. The general drainage patterns will be maintained by the proposed site. The site will have two detention ponds, one that handles the north parking area and one that handles the south parking area and building. A small portion of the north end of the site will sheet drain undetained off the site.

Based on the codes of the City of Lee's Summit, detention is being provided to limit the proposed peak runoff rates to the allowable rates for the 50%, 10%, and 1% storm events.

An extended dry detention basin is proposed to release the water quality event over a 40-hour period utilizing a small orifice and trash rack in the outlet structure.

The project will not produce any impacts to the downstream system as the rates of runoff will be limited to below the allowed rate, which are also below existing conditions. The project will not impact any FEMA floodplains and will respect the existing stream buffer.

APPENDIX A – REFERENCE DOCUMENTS






U.S. Fish and Wildlife Service

National Wetlands Inventory

Wetlands



October 19, 2022

Wetlands

	Estuarine and Marine Deepwater		Freshwater Emergent Wetland		Lake
	Estuarine and Marine Wetland		Freshwater Forested/Shrub Wetland		Other
			Freshwater Pond		Riverine

This map is for general reference only. The US Fish and Wildlife Service is not responsible for the accuracy or currentness of the base data shown on this map. All wetlands related data should be used in accordance with the layer metadata found on the Wetlands Mapper web site.




United States
Department of
Agriculture

NRCS

Natural
Resources
Conservation
Service

A product of the National
Cooperative Soil Survey,
a joint effort of the United
States Department of
Agriculture and other
Federal agencies, State
agencies including the
Agricultural Experiment
Stations, and local
participants

Custom Soil Resource Report for **Jackson County, Missouri**



October 19, 2022

Preface

Soil surveys contain information that affects land use planning in survey areas. They highlight soil limitations that affect various land uses and provide information about the properties of the soils in the survey areas. Soil surveys are designed for many different users, including farmers, ranchers, foresters, agronomists, urban planners, community officials, engineers, developers, builders, and home buyers. Also, conservationists, teachers, students, and specialists in recreation, waste disposal, and pollution control can use the surveys to help them understand, protect, or enhance the environment.

Various land use regulations of Federal, State, and local governments may impose special restrictions on land use or land treatment. Soil surveys identify soil properties that are used in making various land use or land treatment decisions. The information is intended to help the land users identify and reduce the effects of soil limitations on various land uses. The landowner or user is responsible for identifying and complying with existing laws and regulations.

Although soil survey information can be used for general farm, local, and wider area planning, onsite investigation is needed to supplement this information in some cases. Examples include soil quality assessments (<http://www.nrcs.usda.gov/wps/portal/nrcs/main/soils/health/>) and certain conservation and engineering applications. For more detailed information, contact your local USDA Service Center (<https://offices.sc.egov.usda.gov/locator/app?agency=nrcs>) or your NRCS State Soil Scientist (http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/?cid=nrcs142p2_053951).

Great differences in soil properties can occur within short distances. Some soils are seasonally wet or subject to flooding. Some are too unstable to be used as a foundation for buildings or roads. Clayey or wet soils are poorly suited to use as septic tank absorption fields. A high water table makes a soil poorly suited to basements or underground installations.

The National Cooperative Soil Survey is a joint effort of the United States Department of Agriculture and other Federal agencies, State agencies including the Agricultural Experiment Stations, and local agencies. The Natural Resources Conservation Service (NRCS) has leadership for the Federal part of the National Cooperative Soil Survey.

Information about soils is updated periodically. Updated information is available through the NRCS Web Soil Survey, the site for official soil survey information.

The U.S. Department of Agriculture (USDA) prohibits discrimination in all its programs and activities on the basis of race, color, national origin, age, disability, and where applicable, sex, marital status, familial status, parental status, religion, sexual orientation, genetic information, political beliefs, reprisal, or because all or a part of an individual's income is derived from any public assistance program. (Not all prohibited bases apply to all programs.) Persons with disabilities who require

alternative means for communication of program information (Braille, large print, audiotape, etc.) should contact USDA's TARGET Center at (202) 720-2600 (voice and TDD). To file a complaint of discrimination, write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410 or call (800) 795-3272 (voice) or (202) 720-6382 (TDD). USDA is an equal opportunity provider and employer.

Contents

Preface	2
Soil Map	5
Soil Map.....	6
Legend.....	7
Map Unit Legend.....	8
Map Unit Descriptions.....	8
Jackson County, Missouri.....	10
10082—Arisburg-Urban land complex, 1 to 5 percent slopes.....	10
10180—Udarents-Urban land-Sampsel complex, 2 to 5 percent slopes.....	11
Soil Information for All Uses	14
Soil Properties and Qualities.....	14
Soil Qualities and Features.....	14
Hydrologic Soil Group.....	14

Soil Map

The soil map section includes the soil map for the defined area of interest, a list of soil map units on the map and extent of each map unit, and cartographic symbols displayed on the map. Also presented are various metadata about data used to produce the map, and a description of each soil map unit.

Custom Soil Resource Report Soil Map



Custom Soil Resource Report

MAP LEGEND

Area of Interest (AOI)

 Area of Interest (AOI)

Soils

 Soil Map Unit Polygons

 Soil Map Unit Lines

 Soil Map Unit Points

Special Point Features

 Blowout

 Borrow Pit

 Clay Spot

 Closed Depression

 Gravel Pit

 Gravelly Spot

 Landfill

 Lava Flow

 Marsh or swamp

 Mine or Quarry

 Miscellaneous Water

 Perennial Water

 Rock Outcrop

 Saline Spot

 Sandy Spot

 Severely Eroded Spot

 Sinkhole

 Slide or Slip

 Sodic Spot

 Spoil Area

 Stony Spot

 Very Stony Spot

 Wet Spot

 Other

 Special Line Features

Water Features

 Streams and Canals

Transportation

 Rails

 Interstate Highways

 US Routes

 Major Roads

 Local Roads

Background

 Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service
Web Soil Survey URL:
Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Jackson County, Missouri
Survey Area Data: Version 24, Aug 31, 2022

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Sep 6, 2019—Nov 16, 2019

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Map Unit Legend

Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
10082	Arisburg-Urban land complex, 1 to 5 percent slopes	1.9	44.3%
10180	Udarents-Urban land-Sampsel complex, 2 to 5 percent slopes	2.4	55.7%
Totals for Area of Interest		4.3	100.0%

Map Unit Descriptions

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor components may not have been observed, and consequently they are not mentioned in the descriptions, especially where the pattern was so complex that it was impractical to make enough observations to identify all the soils and miscellaneous areas on the landscape.

The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The objective of mapping is not to delineate pure taxonomic classes but rather to separate the landscape into landforms or landform segments that have similar use and management requirements. The delineation of such segments on the map provides sufficient information for the

Custom Soil Resource Report

development of resource plans. If intensive use of small areas is planned, however, onsite investigation is needed to define and locate the soils and miscellaneous areas.

An identifying symbol precedes the map unit name in the map unit descriptions. Each description includes general facts about the unit and gives important soil properties and qualities.

Soils that have profiles that are almost alike make up a *soil series*. Except for differences in texture of the surface layer, all the soils of a series have major horizons that are similar in composition, thickness, and arrangement.

Soils of one series can differ in texture of the surface layer, slope, stoniness, salinity, degree of erosion, and other characteristics that affect their use. On the basis of such differences, a soil series is divided into *soil phases*. Most of the areas shown on the detailed soil maps are phases of soil series. The name of a soil phase commonly indicates a feature that affects use or management. For example, Alpha silt loam, 0 to 2 percent slopes, is a phase of the Alpha series.

Some map units are made up of two or more major soils or miscellaneous areas. These map units are complexes, associations, or undifferentiated groups.

A *complex* consists of two or more soils or miscellaneous areas in such an intricate pattern or in such small areas that they cannot be shown separately on the maps. The pattern and proportion of the soils or miscellaneous areas are somewhat similar in all areas. Alpha-Beta complex, 0 to 6 percent slopes, is an example.

An *association* is made up of two or more geographically associated soils or miscellaneous areas that are shown as one unit on the maps. Because of present or anticipated uses of the map units in the survey area, it was not considered practical or necessary to map the soils or miscellaneous areas separately. The pattern and relative proportion of the soils or miscellaneous areas are somewhat similar. Alpha-Beta association, 0 to 2 percent slopes, is an example.

An *undifferentiated group* is made up of two or more soils or miscellaneous areas that could be mapped individually but are mapped as one unit because similar interpretations can be made for use and management. The pattern and proportion of the soils or miscellaneous areas in a mapped area are not uniform. An area can be made up of only one of the major soils or miscellaneous areas, or it can be made up of all of them. Alpha and Beta soils, 0 to 2 percent slopes, is an example.

Some surveys include *miscellaneous areas*. Such areas have little or no soil material and support little or no vegetation. Rock outcrop is an example.

Jackson County, Missouri

10082—Arisburg-Urban land complex, 1 to 5 percent slopes

Map Unit Setting

National map unit symbol: 2w7ld
Elevation: 750 to 1,130 feet
Mean annual precipitation: 39 to 45 inches
Mean annual air temperature: 50 to 55 degrees F
Frost-free period: 177 to 220 days
Farmland classification: All areas are prime farmland

Map Unit Composition

Arisburg and similar soils: 61 percent
Urban land: 30 percent
Minor components: 9 percent
Estimates are based on observations, descriptions, and transects of the mapunit.

Description of Arisburg

Setting

Landform: Interfluves
Landform position (two-dimensional): Summit
Landform position (three-dimensional): Interfluve
Down-slope shape: Convex
Across-slope shape: Convex
Parent material: Loess

Typical profile

Ap - 0 to 6 inches: silt loam
A - 6 to 13 inches: silt loam
Bt - 13 to 19 inches: silty clay loam
Btg - 19 to 56 inches: silty clay loam
BCg - 56 to 79 inches: silty clay loam

Properties and qualities

Slope: 1 to 5 percent
Depth to restrictive feature: More than 80 inches
Drainage class: Somewhat poorly drained
Capacity of the most limiting layer to transmit water (Ksat): Moderately high (0.20 to 0.60 in/hr)
Depth to water table: About 18 to 30 inches
Frequency of flooding: None
Frequency of ponding: None
Maximum salinity: Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)
Available water supply, 0 to 60 inches: High (about 11.5 inches)

Interpretive groups

Land capability classification (irrigated): None specified
Land capability classification (nonirrigated): 2e
Hydrologic Soil Group: C
Ecological site: R107XB007MO - Loess Upland Prairie
Hydric soil rating: No

Description of Urban Land

Interpretive groups

Land capability classification (irrigated): None specified

Land capability classification (nonirrigated): 8

Hydric soil rating: No

Minor Components

Sampsel

Percent of map unit: 3 percent

Landform: Hills

Landform position (two-dimensional): Backslope

Landform position (three-dimensional): Side slope

Down-slope shape: Convex

Across-slope shape: Concave

Ecological site: R109XY010MO - Interbedded Sedimentary Upland Savanna

Hydric soil rating: Yes

Greenton

Percent of map unit: 3 percent

Landform: Hillslopes

Landform position (two-dimensional): Shoulder

Landform position (three-dimensional): Side slope

Down-slope shape: Convex

Across-slope shape: Convex

Ecological site: R109XY002MO - Loess Upland Prairie

Hydric soil rating: No

Sharpsburg

Percent of map unit: 3 percent

Landform: Ridges

Landform position (two-dimensional): Summit

Landform position (three-dimensional): Interfluve

Down-slope shape: Linear

Across-slope shape: Linear

Ecological site: R109XY002MO - Loess Upland Prairie

Hydric soil rating: No

10180—Udarents-Urban land-Sampsel complex, 2 to 5 percent slopes

Map Unit Setting

National map unit symbol: 1n85h

Elevation: 600 to 900 feet

Mean annual precipitation: 33 to 43 inches

Mean annual air temperature: 50 to 57 degrees F

Frost-free period: 175 to 220 days

Farmland classification: All areas are prime farmland

Map Unit Composition

Udarents and similar soils: 46 percent

Urban land: 39 percent

Sampsel and similar soils: 15 percent

Estimates are based on observations, descriptions, and transects of the mapunit.

Description of Udarents

Setting

Landform position (two-dimensional): Summit

Landform position (three-dimensional): Crest

Down-slope shape: Convex

Across-slope shape: Convex

Parent material: Mine spoil or earthy fill

Typical profile

C1 - 0 to 5 inches: silt loam

C2 - 5 to 80 inches: silty clay loam

Properties and qualities

Slope: 2 to 5 percent

Depth to restrictive feature: More than 80 inches

Drainage class: Somewhat poorly drained

Runoff class: Very high

Capacity of the most limiting layer to transmit water (Ksat): Moderately low to moderately high (0.14 to 0.57 in/hr)

Depth to water table: More than 80 inches

Frequency of flooding: None

Frequency of ponding: None

Maximum salinity: Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)

Available water supply, 0 to 60 inches: Moderate (about 9.0 inches)

Interpretive groups

Land capability classification (irrigated): None specified

Land capability classification (nonirrigated): 6e

Hydrologic Soil Group: C

Ecological site: R107XB002MO - Deep Loess Upland Prairie

Other vegetative classification: Mixed/Transitional (Mixed Native Vegetation)

Hydric soil rating: No

Description of Urban Land

Setting

Landform: Interfluves

Landform position (two-dimensional): Summit

Landform position (three-dimensional): Interfluve

Across-slope shape: Convex

Interpretive groups

Land capability classification (irrigated): None specified

Land capability classification (nonirrigated): 8

Hydric soil rating: No

Description of Sampsel

Setting

Landform: Hillslopes

Custom Soil Resource Report

Landform position (two-dimensional): Footslope
Landform position (three-dimensional): Base slope
Down-slope shape: Concave
Across-slope shape: Convex
Parent material: Residuum weathered from shale

Typical profile

Ap - 0 to 13 inches: silty clay loam
Bt - 13 to 80 inches: silty clay

Properties and qualities

Slope: 2 to 5 percent
Depth to restrictive feature: More than 80 inches
Drainage class: Somewhat poorly drained
Runoff class: Very high
Capacity of the most limiting layer to transmit water (Ksat): Moderately low to moderately high (0.06 to 0.20 in/hr)
Depth to water table: About 0 to 18 inches
Frequency of flooding: None
Frequency of ponding: None
Maximum salinity: Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)
Available water supply, 0 to 60 inches: Moderate (about 8.6 inches)

Interpretive groups

Land capability classification (irrigated): None specified
Land capability classification (nonirrigated): 2e
Hydrologic Soil Group: C/D
Ecological site: R109XY010MO - Interbedded Sedimentary Upland Savanna
Other vegetative classification: Grass/Prairie (Herbaceous Vegetation)
Hydric soil rating: No

Soil Information for All Uses

Soil Properties and Qualities

The Soil Properties and Qualities section includes various soil properties and qualities displayed as thematic maps with a summary table for the soil map units in the selected area of interest. A single value or rating for each map unit is generated by aggregating the interpretive ratings of individual map unit components. This aggregation process is defined for each property or quality.

Soil Qualities and Features

Soil qualities are behavior and performance attributes that are not directly measured, but are inferred from observations of dynamic conditions and from soil properties. Example soil qualities include natural drainage, and frost action. Soil features are attributes that are not directly part of the soil. Example soil features include slope and depth to restrictive layer. These features can greatly impact the use and management of the soil.

Hydrologic Soil Group

Hydrologic soil groups are based on estimates of runoff potential. Soils are assigned to one of four groups according to the rate of water infiltration when the soils are not protected by vegetation, are thoroughly wet, and receive precipitation from long-duration storms.

The soils in the United States are assigned to four groups (A, B, C, and D) and three dual classes (A/D, B/D, and C/D). The groups are defined as follows:

Group A. Soils having a high infiltration rate (low runoff potential) when thoroughly wet. These consist mainly of deep, well drained to excessively drained sands or gravelly sands. These soils have a high rate of water transmission.

Group B. Soils having a moderate infiltration rate when thoroughly wet. These consist chiefly of moderately deep or deep, moderately well drained or well drained soils that have moderately fine texture to moderately coarse texture. These soils have a moderate rate of water transmission.

Custom Soil Resource Report

Group C. Soils having a slow infiltration rate when thoroughly wet. These consist chiefly of soils having a layer that impedes the downward movement of water or soils of moderately fine texture or fine texture. These soils have a slow rate of water transmission.

Group D. Soils having a very slow infiltration rate (high runoff potential) when thoroughly wet. These consist chiefly of clays that have a high shrink-swell potential, soils that have a high water table, soils that have a claypan or clay layer at or near the surface, and soils that are shallow over nearly impervious material. These soils have a very slow rate of water transmission.

If a soil is assigned to a dual hydrologic group (A/D, B/D, or C/D), the first letter is for drained areas and the second is for undrained areas. Only the soils that in their natural condition are in group D are assigned to dual classes.

Custom Soil Resource Report Map—Hydrologic Soil Group



Custom Soil Resource Report

MAP LEGEND

Area of Interest (AOI)

 Area of Interest (AOI)

Soils

Soil Rating Polygons

 A
 A/D
 B
 B/D
 C
 C/D
 D
 Not rated or not available

Soil Rating Lines

 A
 A/D
 B
 B/D
 C
 C/D
 D
 Not rated or not available

Soil Rating Points

 A
 A/D
 B
 B/D

 C
 C/D
 D
 Not rated or not available

Water Features

 Streams and Canals

Transportation

 Rails
 Interstate Highways
 US Routes
 Major Roads
 Local Roads

Background

 Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service
Web Soil Survey URL:
Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Jackson County, Missouri
Survey Area Data: Version 24, Aug 31, 2022

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Sep 6, 2019—Nov 16, 2019

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Table—Hydrologic Soil Group

Map unit symbol	Map unit name	Rating	Acres in AOI	Percent of AOI
10082	Arisburg-Urban land complex, 1 to 5 percent slopes	C	1.9	44.3%
10180	Udarents-Urban land-Sampsel complex, 2 to 5 percent slopes	C	2.4	55.7%
Totals for Area of Interest			4.3	100.0%

Rating Options—Hydrologic Soil Group

Aggregation Method: Dominant Condition


Component Percent Cutoff: None Specified

Tie-break Rule: Higher

National Flood Hazard Layer FIRMMette



94°20'27"W 38°54'33"N



0 250 500 1,000 1,500 2,000 Feet

1:6,000

94°19'50"W 38°54'5"N

Basemap: USGS National Map: Orthoimagery: Data refreshed October, 2020

Legend

SEE FIS REPORT FOR DETAILED LEGEND AND INDEX MAP FOR FIRM PANEL LAYOUT

SPECIAL FLOOD HAZARD AREAS		Without Base Flood Elevation (BFE) Zone A, V, A99
		With BFE or Depth Zone AE, AO, AH, VE, AR
		Regulatory Floodway
OTHER AREAS OF FLOOD HAZARD		0.2% Annual Chance Flood Hazard, Areas of 1% annual chance flood with average depth less than one foot or with drainage areas of less than one square mile Zone X
		Future Conditions 1% Annual Chance Flood Hazard Zone X
		Area with Reduced Flood Risk due to Levee. See Notes. Zone X
		Area with Flood Risk due to Levee Zone D
OTHER AREAS		NO SCREEN Area of Minimal Flood Hazard Zone X
		Effective LOMRs
		Area of Undetermined Flood Hazard Zone D
GENERAL STRUCTURES		Channel, Culvert, or Storm Sewer
		Levee, Dike, or Floodwall
OTHER FEATURES		20.2 Cross Sections with 1% Annual Chance Water Surface Elevation
		17.5 Cross Sections with 1% Annual Chance Water Surface Elevation
		Coastal Transect
		Base Flood Elevation Line (BFE)
		Limit of Study
		Jurisdiction Boundary
OTHER FEATURES		Coastal Transect Baseline
		Profile Baseline
		Hydrographic Feature
MAP PANELS		Digital Data Available
		No Digital Data Available
		Unmapped



The pin displayed on the map is an approximate point selected by the user and does not represent an authoritative property location.

This map complies with FEMA's standards for the use of digital flood maps if it is not void as described below. The basemap shown complies with FEMA's basemap accuracy standards

The flood hazard information is derived directly from the authoritative NFHL web services provided by FEMA. This map was exported on **10/19/2022 at 9:39 AM** and does not reflect changes or amendments subsequent to this date and time. The NFHL and effective information may change or become superseded by new data over time.


This map image is void if the one or more of the following map elements do not appear: basemap imagery, flood zone labels, legend, scale bar, map creation date, community identifiers, FIRM panel number, and FIRM effective date. Map images for unmapped and unmodernized areas cannot be used for regulatory purposes.

APPENDIX B – DRAINAGE MAPS




DRAINAGE LEGEND

	<i>DRAINAGE AREA BOUNDARY</i>
	<i>DRAINAGE DIRECTION</i>
	<i>AREA/DIRECTION OF DRAINAGE BOUNDARY</i>
	<i>EXISTING GRADE MAJOR CONTOUR</i>
	<i>EXISTING GRADE MINOR CONTOUR</i>
	<i>PROPERTY LINE</i>
	<i>RIGHT-OF-WAY LINE</i>

[illegible]



- DRAINAGE LEGEND**
- DRAINAGE AREA BOUNDARY
 - DRAINAGE DIRECTION
 - AREA/DIRECTION OF DRAINAGE BOUNDARY
 - PROPOSED FINISH GRADE MAJOR CONTOUR
 - PROPOSED FINISH GRADE MINOR CONTOUR
 - EXISTING GRADE MAJOR CONTOUR
 - EXISTING GRADE MINOR CONTOUR
 - PROPERTY LINE
 - RIGHT-OF-WAY LINE



Prepared For:		HCA LSMC ASC		PROPOSED DRAINAGE MAP	
Design: TMS Drawn: TMS		Checked: ERB		Issue Date: 10/21/22	
Project Number: 034660		Rev.		Date	
Description		By		App.	

BHC
CIVIL ENGINEERING, SURVEYING & UTILITIES
7101 College Blvd., Suite 400
Overland Park, Kansas 66210
p. 913.651.9900
BHC is a subsidiary of Bergquist International Company, P.A.

APPENDIX C – CALCULATIONS

Table of Contents

	Master Network Summary	1
Time-Depth - 1		
	Time-Depth Curve, 100 years	3
	Time-Depth Curve, 10 years	5
	Time-Depth Curve, 2 years	7
	Time-Depth Curve, 1 years	9
CM-1	Time of Concentration Calculations, 1 years	11
CM-1		
	Runoff CN-Area, 1 years	13
	Runoff CN-Area, 1 years	13
CM-1		
	Unit Hydrograph Summary, 1 years	15
	Unit Hydrograph Summary, 1 years	15
	Unit Hydrograph Summary, 2 years	17
	Unit Hydrograph Summary, 2 years	17
	Unit Hydrograph Summary, 10 years	19
	Unit Hydrograph Summary, 10 years	19
	Unit Hydrograph Summary, 100 years	21
	Unit Hydrograph Summary, 100 years	21
CM-2		
	Unit Hydrograph Summary, 1 years	23
	Unit Hydrograph Summary, 2 years	24
	Unit Hydrograph Summary, 10 years	25
	Unit Hydrograph Summary, 100 years	26
CM-3		
	Unit Hydrograph Summary, 1 years	27
	Unit Hydrograph Summary, 2 years	28
	Unit Hydrograph Summary, 10 years	29
	Unit Hydrograph Summary, 100 years	30
PO-1		
	Elevation-Area Volume Curve, 1 years	31
PO-2		
	Elevation-Area Volume Curve, 1 years	32
Composite Outlet Structure - 1		
	Outlet Input Data, 1 years	33
	Individual Outlet Curves, 1 years	36
	Composite Rating Curve, 1 years	40

Table of Contents

Composite Outlet Structure - 2

Outlet Input Data, 1 years	41
Individual Outlet Curves, 1 years	44
Composite Rating Curve, 1 years	50

PO-1

Elevation-Volume-Flow Table (Pond), 1 years	51
---	----

PO-1 (IN)

Level Pool Pond Routing Summary, 1 years	52
Level Pool Pond Routing Summary, 2 years	53
Level Pool Pond Routing Summary, 10 years	54
Level Pool Pond Routing Summary, 100 years	55

PO-1 (OUT)

Pond Routed Hydrograph (total out), 1 years	56
Pond Routed Hydrograph (total out), 2 years	58
Pond Routed Hydrograph (total out), 10 years	60
Pond Routed Hydrograph (total out), 100 years	62

PO-2

Elevation-Volume-Flow Table (Pond), 1 years	64
---	----

PO-2 (IN)

Level Pool Pond Routing Summary, 1 years	65
Level Pool Pond Routing Summary, 2 years	66
Level Pool Pond Routing Summary, 10 years	67
Level Pool Pond Routing Summary, 100 years	68

PO-2 (OUT)

Pond Routed Hydrograph (total out), 1 years	69
Pond Routed Hydrograph (total out), 2 years	71
Pond Routed Hydrograph (total out), 10 years	73
Pond Routed Hydrograph (total out), 100 years	75

Subsection: Master Network Summary

Catchments Summary

Label	Scenario	Return Event (years)	Hydrograph Volume (ac-ft)	Time to Peak (hours)	Peak Flow (ft ³ /s)
CM-1	Existing WQ	1	0.122	12.000	1.88
CM-1	Proposed WQ	1	0.059	11.950	1.07
CM-1	Existing 2-yr	2	0.675	12.000	11.03
CM-1	Proposed 2-yr	2	0.241	11.900	4.32
CM-1	Existing 10-yr	10	1.180	12.000	18.88
CM-1	Proposed 10-yr	10	0.394	11.900	6.90
CM-1	Existing 100-yr	100	2.017	12.000	31.35
CM-1	Proposed 100-yr	100	0.640	11.900	10.92
CM-2	Proposed WQ	1	0.116	11.950	2.10
CM-2	Proposed 2-yr	2	0.493	11.900	8.86
CM-2	Proposed 10-yr	10	0.812	11.900	14.31
CM-2	Proposed 100-yr	100	1.329	11.900	22.82
CM-3	Proposed WQ	1	0.011	12.000	0.17
CM-3	Proposed 2-yr	2	0.070	11.900	1.26
CM-3	Proposed 10-yr	10	0.126	11.900	2.29
CM-3	Proposed 100-yr	100	0.222	11.900	3.97

Node Summary

Label	Scenario	Return Event (years)	Hydrograph Volume (ac-ft)	Time to Peak (hours)	Peak Flow (ft ³ /s)
O-1	Existing WQ	1	0.122	12.000	1.88
O-1	Proposed WQ	1	0.073	12.000	0.21
O-1	Existing 2-yr	2	0.675	12.000	11.03
O-1	Proposed 2-yr	2	0.594	11.950	1.83
O-1	Existing 10-yr	10	1.180	12.000	18.88
O-1	Proposed 10-yr	10	1.091	12.050	4.33
O-1	Existing 100-yr	100	2.017	12.000	31.35
O-1	Proposed 100-yr	100	1.905	12.050	11.76

Pond Summary

Label	Scenario	Return Event (years)	Hydrograph Volume (ac-ft)	Time to Peak (hours)	Peak Flow (ft ³ /s)	Maximum Water Surface Elevation (ft)	Maximum Pond Storage (ac-ft)
PO-1 (IN)	Proposed WQ	1	0.059	11.950	1.07	(N/A)	(N/A)
PO-1 (OUT)	Proposed WQ	1	0.019	18.650	0.02	981.67	0.041
PO-1 (IN)	Proposed 2-yr	2	0.241	11.900	4.32	(N/A)	(N/A)
PO-1 (OUT)	Proposed 2-yr	2	0.173	12.500	0.39	982.90	0.137
PO-1 (IN)	Proposed 10-yr	10	0.394	11.900	6.90	(N/A)	(N/A)
PO-1 (OUT)	Proposed 10-yr	10	0.322	12.150	1.17	983.70	0.212
PO-1 (IN)	Proposed 100-yr	100	0.640	11.900	10.92	(N/A)	(N/A)
PO-1 (OUT)	Proposed 100-yr	100	0.562	12.150	1.88	984.76	0.333
PO-2 (IN)	Proposed WQ	1	0.116	11.950	2.10	(N/A)	(N/A)

Subsection: Master Network Summary

Pond Summary

Label	Scenario	Return Event (years)	Hydrograph Volume (ac-ft)	Time to Peak (hours)	Peak Flow (ft ³ /s)	Maximum Water Surface Elevation (ft)	Maximum Pond Storage (ac-ft)
PO-2 (OUT)	Proposed WQ	1	0.043	18.000	0.04	984.70	0.077
PO-2 (IN)	Proposed 2-yr	2	0.493	11.900	8.86	(N/A)	(N/A)
PO-2 (OUT)	Proposed 2-yr	2	0.351	13.000	0.50	986.17	0.293
PO-2 (IN)	Proposed 10-yr	10	0.812	11.900	14.31	(N/A)	(N/A)
PO-2 (OUT)	Proposed 10-yr	10	0.643	12.200	2.17	986.98	0.446
PO-2 (IN)	Proposed 100-yr	100	1.329	11.900	22.82	(N/A)	(N/A)
PO-2 (OUT)	Proposed 100-yr	100	1.121	12.100	8.03	987.96	0.666

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 100 years
Storm Event: 100-yr

Time-Depth Curve: 100-yr

Label	100-yr
Start Time	0.000 hours
Increment	0.100 hours
End Time	24.000 hours
Return Event	100 years

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.100 hours

Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
0.000	0.0	0.0	0.0	0.0	0.0
0.500	0.0	0.0	0.1	0.1	0.1
1.000	0.1	0.1	0.1	0.1	0.1
1.500	0.1	0.1	0.1	0.2	0.2
2.000	0.2	0.2	0.2	0.2	0.2
2.500	0.2	0.2	0.2	0.3	0.3
3.000	0.3	0.3	0.3	0.3	0.3
3.500	0.3	0.3	0.3	0.4	0.4
4.000	0.4	0.4	0.4	0.4	0.4
4.500	0.4	0.5	0.5	0.5	0.5
5.000	0.5	0.5	0.5	0.5	0.6
5.500	0.6	0.6	0.6	0.6	0.6
6.000	0.6	0.6	0.7	0.7	0.7
6.500	0.7	0.7	0.7	0.8	0.8
7.000	0.8	0.8	0.8	0.8	0.9
7.500	0.9	0.9	0.9	0.9	0.9
8.000	1.0	1.0	1.0	1.0	1.0
8.500	1.1	1.1	1.1	1.1	1.1
9.000	1.2	1.2	1.2	1.2	1.3
9.500	1.3	1.3	1.3	1.4	1.4
10.000	1.4	1.5	1.5	1.5	1.6
10.500	1.6	1.7	1.7	1.8	1.8
11.000	1.9	1.9	2.0	2.1	2.2
11.500	2.2	2.4	2.8	3.4	4.5
12.000	5.3	5.4	5.5	5.7	5.8
12.500	5.8	5.9	6.0	6.0	6.1
13.000	6.1	6.2	6.2	6.3	6.3
13.500	6.3	6.4	6.4	6.4	6.5
14.000	6.5	6.5	6.6	6.6	6.6
14.500	6.7	6.7	6.7	6.7	6.8
15.000	6.8	6.8	6.8	6.8	6.9
15.500	6.9	6.9	6.9	6.9	7.0
16.000	7.0	7.0	7.0	7.0	7.1
16.500	7.1	7.1	7.1	7.1	7.1
17.000	7.2	7.2	7.2	7.2	7.2
17.500	7.2	7.3	7.3	7.3	7.3
18.000	7.3	7.3	7.3	7.4	7.4
18.500	7.4	7.4	7.4	7.4	7.4
19.000	7.4	7.5	7.5	7.5	7.5
19.500	7.5	7.5	7.5	7.5	7.5

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 100 years
Storm Event: 100-yr

CUMULATIVE RAINFALL (in)
Output Time Increment = 0.100 hours
Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
20.000	7.6	7.6	7.6	7.6	7.6
20.500	7.6	7.6	7.6	7.6	7.7
21.000	7.7	7.7	7.7	7.7	7.7
21.500	7.7	7.7	7.7	7.7	7.7
22.000	7.8	7.8	7.8	7.8	7.8
22.500	7.8	7.8	7.8	7.8	7.8
23.000	7.9	7.9	7.9	7.9	7.9
23.500	7.9	7.9	7.9	7.9	7.9
24.000	7.9	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 10 years
Storm Event: 10-yr

Time-Depth Curve: 10-yr

Label	10-yr
Start Time	0.000 hours
Increment	0.100 hours
End Time	24.000 hours
Return Event	10 years

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.100 hours

Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
0.000	0.0	0.0	0.0	0.0	0.0
0.500	0.0	0.0	0.0	0.0	0.0
1.000	0.1	0.1	0.1	0.1	0.1
1.500	0.1	0.1	0.1	0.1	0.1
2.000	0.1	0.1	0.1	0.1	0.1
2.500	0.1	0.2	0.2	0.2	0.2
3.000	0.2	0.2	0.2	0.2	0.2
3.500	0.2	0.2	0.2	0.2	0.2
4.000	0.3	0.3	0.3	0.3	0.3
4.500	0.3	0.3	0.3	0.3	0.3
5.000	0.3	0.3	0.3	0.4	0.4
5.500	0.4	0.4	0.4	0.4	0.4
6.000	0.4	0.4	0.4	0.4	0.5
6.500	0.5	0.5	0.5	0.5	0.5
7.000	0.5	0.5	0.5	0.6	0.6
7.500	0.6	0.6	0.6	0.6	0.6
8.000	0.6	0.6	0.7	0.7	0.7
8.500	0.7	0.7	0.7	0.7	0.8
9.000	0.8	0.8	0.8	0.8	0.8
9.500	0.9	0.9	0.9	0.9	0.9
10.000	1.0	1.0	1.0	1.0	1.0
10.500	1.1	1.1	1.1	1.2	1.2
11.000	1.2	1.3	1.3	1.4	1.4
11.500	1.5	1.6	1.9	2.3	3.0
12.000	3.5	3.6	3.7	3.7	3.8
12.500	3.9	3.9	3.9	4.0	4.0
13.000	4.1	4.1	4.1	4.1	4.2
13.500	4.2	4.2	4.2	4.3	4.3
14.000	4.3	4.3	4.3	4.4	4.4
14.500	4.4	4.4	4.4	4.4	4.5
15.000	4.5	4.5	4.5	4.5	4.5
15.500	4.6	4.6	4.6	4.6	4.6
16.000	4.6	4.6	4.6	4.7	4.7
16.500	4.7	4.7	4.7	4.7	4.7
17.000	4.7	4.7	4.8	4.8	4.8
17.500	4.8	4.8	4.8	4.8	4.8
18.000	4.8	4.8	4.9	4.9	4.9
18.500	4.9	4.9	4.9	4.9	4.9
19.000	4.9	4.9	4.9	4.9	5.0
19.500	5.0	5.0	5.0	5.0	5.0

Subsection: Time-Depth Curve
 Label: Time-Depth - 1

Return Event: 10 years
 Storm Event: 10-yr

CUMULATIVE RAINFALL (in)
Output Time Increment = 0.100 hours
Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
20.000	5.0	5.0	5.0	5.0	5.0
20.500	5.0	5.0	5.0	5.1	5.1
21.000	5.1	5.1	5.1	5.1	5.1
21.500	5.1	5.1	5.1	5.1	5.1
22.000	5.1	5.1	5.1	5.1	5.2
22.500	5.2	5.2	5.2	5.2	5.2
23.000	5.2	5.2	5.2	5.2	5.2
23.500	5.2	5.2	5.2	5.2	5.2
24.000	5.3	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 2 years
Storm Event: 2-yr

Time-Depth Curve: 2-yr

Label	2-yr
Start Time	0.000 hours
Increment	0.100 hours
End Time	24.000 hours
Return Event	2 years

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.100 hours

Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
0.000	0.0	0.0	0.0	0.0	0.0
0.500	0.0	0.0	0.0	0.0	0.0
1.000	0.0	0.0	0.0	0.0	0.1
1.500	0.1	0.1	0.1	0.1	0.1
2.000	0.1	0.1	0.1	0.1	0.1
2.500	0.1	0.1	0.1	0.1	0.1
3.000	0.1	0.1	0.1	0.1	0.1
3.500	0.1	0.2	0.2	0.2	0.2
4.000	0.2	0.2	0.2	0.2	0.2
4.500	0.2	0.2	0.2	0.2	0.2
5.000	0.2	0.2	0.2	0.2	0.2
5.500	0.3	0.3	0.3	0.3	0.3
6.000	0.3	0.3	0.3	0.3	0.3
6.500	0.3	0.3	0.3	0.3	0.3
7.000	0.4	0.4	0.4	0.4	0.4
7.500	0.4	0.4	0.4	0.4	0.4
8.000	0.4	0.4	0.4	0.5	0.5
8.500	0.5	0.5	0.5	0.5	0.5
9.000	0.5	0.5	0.5	0.6	0.6
9.500	0.6	0.6	0.6	0.6	0.6
10.000	0.6	0.7	0.7	0.7	0.7
10.500	0.7	0.7	0.8	0.8	0.8
11.000	0.8	0.9	0.9	0.9	1.0
11.500	1.0	1.1	1.3	1.5	2.0
12.000	2.4	2.4	2.5	2.5	2.6
12.500	2.6	2.6	2.7	2.7	2.7
13.000	2.7	2.8	2.8	2.8	2.8
13.500	2.8	2.9	2.9	2.9	2.9
14.000	2.9	2.9	2.9	2.9	3.0
14.500	3.0	3.0	3.0	3.0	3.0
15.000	3.0	3.0	3.1	3.1	3.1
15.500	3.1	3.1	3.1	3.1	3.1
16.000	3.1	3.1	3.1	3.1	3.2
16.500	3.2	3.2	3.2	3.2	3.2
17.000	3.2	3.2	3.2	3.2	3.2
17.500	3.2	3.2	3.2	3.3	3.3
18.000	3.3	3.3	3.3	3.3	3.3
18.500	3.3	3.3	3.3	3.3	3.3
19.000	3.3	3.3	3.3	3.3	3.4
19.500	3.4	3.4	3.4	3.4	3.4

Subsection: Time-Depth Curve

Label: Time-Depth - 1

Return Event: 2 years

Storm Event: 2-yr

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.100 hours

Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
20.000	3.4	3.4	3.4	3.4	3.4
20.500	3.4	3.4	3.4	3.4	3.4
21.000	3.4	3.4	3.4	3.4	3.4
21.500	3.4	3.5	3.5	3.5	3.5
22.000	3.5	3.5	3.5	3.5	3.5
22.500	3.5	3.5	3.5	3.5	3.5
23.000	3.5	3.5	3.5	3.5	3.5
23.500	3.5	3.5	3.5	3.5	3.5
24.000	3.6	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 1 years
Storm Event: WQ

Time-Depth Curve: WQ

Label	WQ
Start Time	0.000 hours
Increment	0.100 hours
End Time	24.000 hours
Return Event	1 years

CUMULATIVE RAINFALL (in)

Output Time Increment = 0.100 hours

Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
0.000	0.0	0.0	0.0	0.0	0.0
0.500	0.0	0.0	0.0	0.0	0.0
1.000	0.0	0.0	0.0	0.0	0.0
1.500	0.0	0.0	0.0	0.0	0.0
2.000	0.0	0.0	0.0	0.0	0.0
2.500	0.0	0.0	0.0	0.0	0.0
3.000	0.0	0.0	0.1	0.1	0.1
3.500	0.1	0.1	0.1	0.1	0.1
4.000	0.1	0.1	0.1	0.1	0.1
4.500	0.1	0.1	0.1	0.1	0.1
5.000	0.1	0.1	0.1	0.1	0.1
5.500	0.1	0.1	0.1	0.1	0.1
6.000	0.1	0.1	0.1	0.1	0.1
6.500	0.1	0.1	0.1	0.1	0.1
7.000	0.1	0.1	0.1	0.1	0.1
7.500	0.1	0.2	0.2	0.2	0.2
8.000	0.2	0.2	0.2	0.2	0.2
8.500	0.2	0.2	0.2	0.2	0.2
9.000	0.2	0.2	0.2	0.2	0.2
9.500	0.2	0.2	0.2	0.2	0.2
10.000	0.2	0.3	0.3	0.3	0.3
10.500	0.3	0.3	0.3	0.3	0.3
11.000	0.3	0.3	0.3	0.4	0.4
11.500	0.4	0.4	0.5	0.6	0.8
12.000	0.9	0.9	1.0	1.0	1.0
12.500	1.0	1.0	1.0	1.0	1.0
13.000	1.1	1.1	1.1	1.1	1.1
13.500	1.1	1.1	1.1	1.1	1.1
14.000	1.1	1.1	1.1	1.1	1.1
14.500	1.1	1.2	1.2	1.2	1.2
15.000	1.2	1.2	1.2	1.2	1.2
15.500	1.2	1.2	1.2	1.2	1.2
16.000	1.2	1.2	1.2	1.2	1.2
16.500	1.2	1.2	1.2	1.2	1.2
17.000	1.2	1.2	1.2	1.2	1.2
17.500	1.2	1.3	1.3	1.3	1.3
18.000	1.3	1.3	1.3	1.3	1.3
18.500	1.3	1.3	1.3	1.3	1.3
19.000	1.3	1.3	1.3	1.3	1.3
19.500	1.3	1.3	1.3	1.3	1.3

Subsection: Time-Depth Curve
Label: Time-Depth - 1

Return Event: 1 years
Storm Event: WQ

CUMULATIVE RAINFALL (in)
Output Time Increment = 0.100 hours
Time on left represents time for first value in each row.

Time (hours)	Depth (in)	Depth (in)	Depth (in)	Depth (in)	Depth (in)
20.000	1.3	1.3	1.3	1.3	1.3
20.500	1.3	1.3	1.3	1.3	1.3
21.000	1.3	1.3	1.3	1.3	1.3
21.500	1.3	1.3	1.3	1.3	1.3
22.000	1.3	1.3	1.3	1.3	1.3
22.500	1.3	1.3	1.3	1.4	1.4
23.000	1.4	1.4	1.4	1.4	1.4
23.500	1.4	1.4	1.4	1.4	1.4
24.000	1.4	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Time of Concentration Calculations
Label: CM-1

Return Event: 1 years
Storm Event: WQ

Time of Concentration Results

Segment #1: TR-55 Sheet Flow	
Hydraulic Length	100.00 ft
Manning's n	0.170
Slope	0.030 ft/ft
2 Year 24 Hour Depth	3.6 in
Average Velocity	0.19 ft/s
Segment Time of Concentration	0.146 hours
Segment #2: TR-55 Shallow Concentrated Flow	
Hydraulic Length	230.00 ft
Is Paved?	False
Slope	0.030 ft/ft
Average Velocity	2.79 ft/s
Segment Time of Concentration	0.023 hours
Time of Concentration (Composite)	
Time of Concentration (Composite)	0.169 hours

Subsection: Time of Concentration Calculations
Label: CM-1

Return Event: 1 years
Storm Event: WQ

==== SCS Channel Flow

Tc = $R = Qa / Wp$
 $V = (1.49 * (R^{2/3}) * (Sf^{*-0.5})) / n$

Where: $(Lf / V) / 3600$
R= Hydraulic radius
Aq= Flow area, square feet
Wp= Wetted perimeter, feet
V= Velocity, ft/sec
Sf= Slope, ft/ft
n= Manning's n
Tc= Time of concentration, hours
Lf= Flow length, feet

==== SCS TR-55 Shallow Concentration Flow

Tc = Unpaved surface:
 $V = 16.1345 * (Sf^{*0.5})$

Paved Surface:
 $V = 20.3282 * (Sf^{*0.5})$

Where: $(Lf / V) / 3600$
V= Velocity, ft/sec
Sf= Slope, ft/ft
Tc= Time of concentration, hours
Lf= Flow length, feet

Subsection: Runoff CN-Area
Label: CM-1

Return Event: 1 years
Storm Event: WQ

Runoff Curve Number Data

Soil/Surface Description	CN	Area (acres)	C (%)	UC (%)	Adjusted CN
Row crops - Straight row (SR), good - Soil C	85.000	3.940	0.0	0.0	85.000
COMPOSITE AREA & WEIGHTED CN --->	(N/A)	3.940	(N/A)	(N/A)	85.000

Subsection: Runoff CN-Area
Label: CM-1

Return Event: 1 years
Storm Event: WQ

Runoff Curve Number Data

Soil/Surface Description	CN	Area (acres)	C (%)	UC (%)	Adjusted CN
Impervious Areas - Paved parking lots, roofs, driveways, Streets and roads - Soil D	98.000	0.670	0.0	0.0	98.000
Open space (Lawns,parks etc.) - Good condition; grass cover > 75% - Soil D	80.000	0.450	0.0	0.0	80.000
COMPOSITE AREA & WEIGHTED CN --->	(N/A)	1.120	(N/A)	(N/A)	90.768

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 1 years
Storm Event: WQ

Storm Event	WQ
Return Event	1 years
Duration	24.000 hours
Depth	1.4 in
Time of Concentration (Composite)	0.169 hours
Area (User Defined)	3.940 acres
Computational Time Increment	0.022 hours
Time to Peak (Computed)	12.025 hours
Flow (Peak, Computed)	1.91 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	12.000 hours
Flow (Peak Interpolated Output)	1.88 ft ³ /s
Drainage Area	
SCS CN (Composite)	85.000
Area (User Defined)	3.940 acres
Maximum Retention (Pervious)	1.8 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	0.4 in
Runoff Volume (Pervious)	0.122 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.122 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.169 hours
Computational Time Increment	0.022 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	26.48 ft ³ /s
Unit peak time, Tp	0.112 hours
Unit receding limb, Tr	0.450 hours
Total unit time, Tb	0.562 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 1 years
Storm Event: WQ

Storm Event	WQ
Return Event	1 years
Duration	24.000 hours
Depth	1.4 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	1.120 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	1.12 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.950 hours
Flow (Peak Interpolated Output)	1.07 ft ³ /s
Drainage Area	
SCS CN (Composite)	91.000
Area (User Defined)	1.120 acres
Maximum Retention (Pervious)	1.0 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	0.6 in
Runoff Volume (Pervious)	0.059 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.059 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	15.23 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 2 years
Storm Event: 2-yr

Storm Event	2-yr
Return Event	2 years
Duration	24.000 hours
Depth	3.6 in
Time of Concentration (Composite)	0.169 hours
Area (User Defined)	3.940 acres
Computational Time Increment	0.022 hours
Time to Peak (Computed)	11.980 hours
Flow (Peak, Computed)	11.04 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	12.000 hours
Flow (Peak Interpolated Output)	11.03 ft ³ /s
Drainage Area	
SCS CN (Composite)	85.000
Area (User Defined)	3.940 acres
Maximum Retention (Pervious)	1.8 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	2.1 in
Runoff Volume (Pervious)	0.676 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.675 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.169 hours
Computational Time Increment	0.022 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	26.48 ft ³ /s
Unit peak time, Tp	0.112 hours
Unit receding limb, Tr	0.450 hours
Total unit time, Tb	0.562 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 2 years
Storm Event: 2-yr

Storm Event	2-yr
Return Event	2 years
Duration	24.000 hours
Depth	3.6 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	1.120 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	4.44 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	4.32 ft ³ /s
Drainage Area	
SCS CN (Composite)	91.000
Area (User Defined)	1.120 acres
Maximum Retention (Pervious)	1.0 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	2.6 in
Runoff Volume (Pervious)	0.242 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.241 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	15.23 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 10 years
Storm Event: 10-yr

Storm Event	10-yr
Return Event	10 years
Duration	24.000 hours
Depth	5.3 in
Time of Concentration (Composite)	0.169 hours
Area (User Defined)	3.940 acres
Computational Time Increment	0.022 hours
Time to Peak (Computed)	11.980 hours
Flow (Peak, Computed)	19.01 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	12.000 hours
Flow (Peak Interpolated Output)	18.88 ft ³ /s
Drainage Area	
SCS CN (Composite)	85.000
Area (User Defined)	3.940 acres
Maximum Retention (Pervious)	1.8 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	3.6 in
Runoff Volume (Pervious)	1.182 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	1.180 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.169 hours
Computational Time Increment	0.022 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	26.48 ft ³ /s
Unit peak time, Tp	0.112 hours
Unit receding limb, Tr	0.450 hours
Total unit time, Tb	0.562 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 10 years
Storm Event: 10-yr

Storm Event	10-yr
Return Event	10 years
Duration	24.000 hours
Depth	5.3 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	1.120 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	7.06 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	6.90 ft ³ /s
Drainage Area	
SCS CN (Composite)	91.000
Area (User Defined)	1.120 acres
Maximum Retention (Pervious)	1.0 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	4.2 in
Runoff Volume (Pervious)	0.394 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.394 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	15.23 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 100 years
Storm Event: 100-yr

Storm Event	100-yr
Return Event	100 years
Duration	24.000 hours
Depth	7.9 in
Time of Concentration (Composite)	0.169 hours
Area (User Defined)	3.940 acres
Computational Time Increment	0.022 hours
Time to Peak (Computed)	11.980 hours
Flow (Peak, Computed)	31.71 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	12.000 hours
Flow (Peak Interpolated Output)	31.35 ft ³ /s
Drainage Area	
SCS CN (Composite)	85.000
Area (User Defined)	3.940 acres
Maximum Retention (Pervious)	1.8 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	6.2 in
Runoff Volume (Pervious)	2.021 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	2.017 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.169 hours
Computational Time Increment	0.022 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	26.48 ft ³ /s
Unit peak time, Tp	0.112 hours
Unit receding limb, Tr	0.450 hours
Total unit time, Tb	0.562 hours

Subsection: Unit Hydrograph Summary
Label: CM-1

Return Event: 100 years
Storm Event: 100-yr

Storm Event	100-yr
Return Event	100 years
Duration	24.000 hours
Depth	7.9 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	1.120 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	11.14 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	10.92 ft ³ /s
Drainage Area	
SCS CN (Composite)	91.000
Area (User Defined)	1.120 acres
Maximum Retention (Pervious)	1.0 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	6.9 in
Runoff Volume (Pervious)	0.641 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.640 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	15.23 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-2

Return Event: 1 years
Storm Event: WQ

Storm Event	WQ
Return Event	1 years
Duration	24.000 hours
Depth	1.4 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	2.360 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	2.18 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.950 hours
Flow (Peak Interpolated Output)	2.10 ft ³ /s
Drainage Area	
SCS CN (Composite)	90.144
Area (User Defined)	2.360 acres
Maximum Retention (Pervious)	1.1 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	0.6 in
Runoff Volume (Pervious)	0.116 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.116 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	32.09 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-2

Return Event: 2 years
Storm Event: 2-yr

Storm Event	2-yr
Return Event	2 years
Duration	24.000 hours
Depth	3.6 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	2.360 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	9.13 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	8.86 ft ³ /s
Drainage Area	
SCS CN (Composite)	90.144
Area (User Defined)	2.360 acres
Maximum Retention (Pervious)	1.1 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	2.5 in
Runoff Volume (Pervious)	0.493 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.493 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	32.09 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-2

Return Event: 10 years
Storm Event: 10-yr

Storm Event	10-yr
Return Event	10 years
Duration	24.000 hours
Depth	5.3 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	2.360 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	14.65 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	14.31 ft ³ /s
Drainage Area	
SCS CN (Composite)	90.144
Area (User Defined)	2.360 acres
Maximum Retention (Pervious)	1.1 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	4.1 in
Runoff Volume (Pervious)	0.813 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.812 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	32.09 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-2

Return Event: 100 years
Storm Event: 100-yr

Storm Event	100-yr
Return Event	100 years
Duration	24.000 hours
Depth	7.9 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	2.360 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	23.28 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	22.82 ft ³ /s
Drainage Area	
SCS CN (Composite)	90.144
Area (User Defined)	2.360 acres
Maximum Retention (Pervious)	1.1 in
Maximum Retention (Pervious, 20 percent)	0.2 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	6.8 in
Runoff Volume (Pervious)	1.330 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	1.329 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	32.09 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-3

Return Event: 1 years
Storm Event: WQ

Storm Event	WQ
Return Event	1 years
Duration	24.000 hours
Depth	1.4 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	0.460 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	12.011 hours
Flow (Peak, Computed)	0.17 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	12.000 hours
Flow (Peak Interpolated Output)	0.17 ft ³ /s
Drainage Area	
SCS CN (Composite)	81.957
Area (User Defined)	0.460 acres
Maximum Retention (Pervious)	2.2 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	0.3 in
Runoff Volume (Pervious)	0.011 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.011 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	6.25 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-3

Return Event: 2 years
Storm Event: 2-yr

Storm Event	2-yr
Return Event	2 years
Duration	24.000 hours
Depth	3.6 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	0.460 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	1.32 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	1.26 ft ³ /s
Drainage Area	
SCS CN (Composite)	81.957
Area (User Defined)	0.460 acres
Maximum Retention (Pervious)	2.2 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	1.8 in
Runoff Volume (Pervious)	0.070 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.070 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	6.25 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-3

Return Event: 10 years
Storm Event: 10-yr

Storm Event	10-yr
Return Event	10 years
Duration	24.000 hours
Depth	5.3 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	0.460 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	2.38 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	2.29 ft ³ /s
Drainage Area	
SCS CN (Composite)	81.957
Area (User Defined)	0.460 acres
Maximum Retention (Pervious)	2.2 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	3.3 in
Runoff Volume (Pervious)	0.126 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.126 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	6.25 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Unit Hydrograph Summary
Label: CM-3

Return Event: 100 years
Storm Event: 100-yr

Storm Event	100-yr
Return Event	100 years
Duration	24.000 hours
Depth	7.9 in
Time of Concentration (Composite)	0.083 hours
Area (User Defined)	0.460 acres
Computational Time Increment	0.011 hours
Time to Peak (Computed)	11.922 hours
Flow (Peak, Computed)	4.09 ft ³ /s
Output Increment	0.050 hours
Time to Flow (Peak Interpolated Output)	11.900 hours
Flow (Peak Interpolated Output)	3.97 ft ³ /s
Drainage Area	
SCS CN (Composite)	81.957
Area (User Defined)	0.460 acres
Maximum Retention (Pervious)	2.2 in
Maximum Retention (Pervious, 20 percent)	0.4 in
Cumulative Runoff	
Cumulative Runoff Depth (Pervious)	5.8 in
Runoff Volume (Pervious)	0.222 ac-ft
Hydrograph Volume (Area under Hydrograph curve)	
Volume	0.222 ac-ft
SCS Unit Hydrograph Parameters	
Time of Concentration (Composite)	0.083 hours
Computational Time Increment	0.011 hours
Unit Hydrograph Shape Factor	483.432
K Factor	0.749
Receding/Rising, Tr/Tp	1.670
Unit peak, qp	6.25 ft ³ /s
Unit peak time, Tp	0.056 hours
Unit receding limb, Tr	0.222 hours
Total unit time, Tb	0.278 hours

Subsection: Elevation-Area Volume Curve
 Label: PO-1

Return Event: 1 years
 Storm Event: WQ

Elevation (ft)	Planimeter (ft ²)	Area (acres)	A1+A2+sqr (A1*A2) (acres)	Volume (ac-ft)
981.00	0.0	0.055	0.000	0.000
982.00	0.0	0.074	0.193	0.064
983.00	0.0	0.088	0.243	0.081
984.00	0.0	0.109	0.295	0.098
985.00	0.0	0.132	0.361	0.120
Volume (Total) (ac-ft)				
0.000				
0.064				
0.145				
0.243				
0.364				

Subsection: Elevation-Area Volume Curve
 Label: PO-2

Return Event: 1 years
 Storm Event: WQ

Elevation (ft)	Planimeter (ft ²)	Area (acres)	A1+A2+sqr (A1*A2) (acres)	Volume (ac-ft)
984.00	0.0	0.098	0.000	0.000
985.00	0.0	0.133	0.345	0.115
986.00	0.0	0.167	0.449	0.150
987.00	0.0	0.205	0.557	0.186
988.00	0.0	0.244	0.673	0.224
Volume (Total) (ac-ft)				
0.000				
0.115				
0.265				
0.450				
0.675				

Subsection: Outlet Input Data
 Label: Composite Outlet Structure - 1

Return Event: 1 years
 Storm Event: WQ

Requested Pond Water Surface Elevations	
Minimum (Headwater)	981.00 ft
Increment (Headwater)	0.50 ft
Maximum (Headwater)	985.00 ft

Outlet Connectivity

Structure Type	Outlet ID	Direction	Outfall	E1 (ft)	E2 (ft)
Orifice-Circular	Orifice - 1	Forward	Culvert - 1	981.00	985.00
Orifice-Circular	Orifice - 2	Forward	Culvert - 1	982.00	985.00
Orifice-Circular	Orifice - 3	Forward	Culvert - 1	983.00	985.00
Culvert-Circular	Culvert - 1	Forward	TW	981.00	985.00
Tailwater Settings	Tailwater			(N/A)	(N/A)

Subsection: Outlet Input Data
Label: Composite Outlet Structure - 1

Return Event: 1 years
Storm Event: WQ

Structure ID: Culvert - 1	
Structure Type: Culvert-Circular	
Number of Barrels	1
Diameter	12.0 in
Length	30.00 ft
Length (Computed Barrel)	30.00 ft
Slope (Computed)	0.010 ft/ft
Outlet Control Data	
Manning's n	0.013
Ke	0.200
Kb	0.031
Kr	0.200
Convergence Tolerance	0.00 ft
Inlet Control Data	
Equation Form	Form 1
K	0.0045
M	2.0000
C	0.0317
Y	0.6900
T1 ratio (HW/D)	1.090
T2 ratio (HW/D)	1.192
Slope Correction Factor	-0.500

Use unsubmerged inlet control 0 equation below T1 elevation.

Use submerged inlet control 0 equation above T2 elevation

In transition zone between unsubmerged and submerged inlet control, interpolate between flows at T1 & T2...

T1 Elevation	982.09 ft	T1 Flow	2.75 ft ³ /s
T2 Elevation	982.19 ft	T2 Flow	3.14 ft ³ /s

Subsection: Outlet Input Data

Label: Composite Outlet Structure - 1

Return Event: 1 years

Storm Event: WQ

Structure ID: Orifice - 1	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	981.00 ft
Orifice Diameter	1.0 in
Orifice Coefficient	0.600
Structure ID: Orifice - 2	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	982.00 ft
Orifice Diameter	4.0 in
Orifice Coefficient	0.600
Structure ID: Orifice - 3	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	983.00 ft
Orifice Diameter	6.0 in
Orifice Coefficient	0.600
Structure ID: TW	
Structure Type: TW Setup, DS Channel	
Tailwater Type	Free Outfall
Convergence Tolerances	
Maximum Iterations	30
Tailwater Tolerance (Minimum)	0.01 ft
Tailwater Tolerance (Maximum)	0.50 ft
Headwater Tolerance (Minimum)	0.01 ft
Headwater Tolerance (Maximum)	0.50 ft
Flow Tolerance (Minimum)	0.001 ft ³ /s
Flow Tolerance (Maximum)	10.000 ft ³ /s

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 1

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Culvert - 1 (Culvert-Circular)

Mannings open channel maximum capacity: 3.83 ft³/s
Upstream ID = Orifice - 1, Orifice - 2, Orifice - 3
Downstream ID = Tailwater (Pond Outfall)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
981.00	0.00	0.00	0.00	Free Outfall	0.00	0.00	(N/A)
981.50	0.02	981.07	Free Outfall	Free Outfall	0.00	0.00	(N/A)
982.00	0.03	981.09	Free Outfall	Free Outfall	0.00	0.00	(N/A)
982.50	0.27	981.30	Free Outfall	Free Outfall	0.00	0.00	(N/A)
983.00	0.42	981.38	Free Outfall	Free Outfall	0.00	0.00	(N/A)
983.50	1.01	981.61	Free Outfall	Free Outfall	0.00	0.00	(N/A)
984.00	1.42	981.75	Free Outfall	Free Outfall	0.00	0.00	(N/A)
984.50	1.74	981.84	Free Outfall	Free Outfall	0.00	0.00	(N/A)
985.00	2.00	981.91	Free Outfall	Free Outfall	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	CRIT.DEPTH CONTROL Vh= .018ft Dcr= .053ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .022ft Dcr= .064ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .075ft Dcr= .214ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .095ft Dcr= .267ft CRIT.DEPTH Hev= .00ft
0.00	FLOW PRECEDENCE SET TO UPSTREAM CONTROLLING STRUCTURE
0.00	CRIT.DEPTH CONTROL Vh= .199ft Dcr= .505ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .229ft Dcr= .561ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .253ft Dcr= .603ft CRIT.DEPTH Hev= .00ft

Subsection: Individual Outlet Curves
 Label: Composite Outlet Structure - 1

Return Event: 1 years
 Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
 Structure ID = Orifice - 1 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
 Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
981.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
981.50	0.02	981.50	981.07	981.07	0.00	0.00	(N/A)
982.00	0.03	982.00	981.09	981.09	0.00	0.00	(N/A)
982.50	0.03	982.50	981.30	981.30	0.00	0.00	(N/A)
983.00	0.03	983.00	981.38	981.38	0.00	0.00	(N/A)
983.50	0.04	983.50	981.61	981.61	0.00	0.00	(N/A)
984.00	0.04	984.00	981.74	981.75	0.00	0.00	(N/A)
984.50	0.04	984.50	981.84	981.84	0.00	0.00	(N/A)
985.00	0.05	985.00	981.91	981.91	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	H =.43
0.00	H =.91
0.00	H =1.20
0.00	H =1.62
0.00	H =1.89
0.00	H =2.26
0.00	H =2.66
0.00	H =3.09

Subsection: Individual Outlet Curves
 Label: Composite Outlet Structure - 1

Return Event: 1 years
 Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
 Structure ID = Orifice - 2 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
 Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
981.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
981.50	0.00	0.00	0.00	981.07	0.00	0.00	(N/A)
982.00	0.00	0.00	0.00	981.09	0.00	0.00	(N/A)
982.50	0.24	982.50	Free Outfall	981.30	0.00	0.00	(N/A)
983.00	0.38	983.00	Free Outfall	981.38	0.00	0.00	(N/A)
983.50	0.48	983.50	Free Outfall	981.61	0.00	0.00	(N/A)
984.00	0.57	984.00	Free Outfall	981.75	0.00	0.00	(N/A)
984.50	0.64	984.50	Free Outfall	981.84	0.00	0.00	(N/A)
985.00	0.71	985.00	Free Outfall	981.91	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	H =.33
0.00	H =.83
0.00	H =1.33
0.00	H =1.83
0.00	H =2.33
0.00	H =2.83

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 1

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Orifice - 3 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
981.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
981.50	0.00	0.00	0.00	981.07	0.00	0.00	(N/A)
982.00	0.00	0.00	0.00	981.09	0.00	0.00	(N/A)
982.50	0.00	0.00	0.00	981.30	0.00	0.00	(N/A)
983.00	0.00	0.00	0.00	981.38	0.00	0.00	(N/A)
983.50	0.47	983.50	Free Outfall	981.61	0.00	0.00	(N/A)
984.00	0.82	984.00	Free Outfall	981.75	0.00	0.00	(N/A)
984.50	1.06	984.50	Free Outfall	981.84	0.00	0.00	(N/A)
985.00	1.25	985.00	Free Outfall	981.91	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	H =.25
0.00	H =.75
0.00	H =1.25
0.00	H =1.75

Subsection: Composite Rating Curve
Label: Composite Outlet Structure - 1

Return Event: 1 years
Storm Event: WQ

Composite Outflow Summary

Water Surface Elevation (ft)	Flow (ft ³ /s)	Tailwater Elevation (ft)	Convergence Error (ft)
981.00	0.00	(N/A)	0.00
981.50	0.02	(N/A)	0.00
982.00	0.03	(N/A)	0.00
982.50	0.27	(N/A)	0.00
983.00	0.42	(N/A)	0.00
983.50	0.99	(N/A)	0.00
984.00	1.43	(N/A)	0.00
984.50	1.74	(N/A)	0.00
985.00	2.00	(N/A)	0.00

Contributing Structures

(no Q: Orifice - 1,Orifice
- 2,Orifice - 3,Culvert - 1)
Orifice - 1,Culvert - 1
(no Q: Orifice - 2,Orifice -
3)
Orifice - 1,Culvert - 1
(no Q: Orifice - 2,Orifice -
3)
Orifice - 1,Orifice -
2,Culvert - 1 (no Q:
Orifice - 3)
Orifice - 1,Orifice -
2,Culvert - 1 (no Q:
Orifice - 3)
Orifice - 1,Orifice -
2,Orifice - 3,Culvert - 1
Orifice - 1,Orifice -
2,Orifice - 3,Culvert - 1
Orifice - 1,Orifice -
2,Orifice - 3,Culvert - 1
Orifice - 1,Orifice -
2,Orifice - 3,Culvert - 1

Subsection: Outlet Input Data
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

Requested Pond Water Surface Elevations

Minimum (Headwater)	984.00 ft
Increment (Headwater)	0.50 ft
Maximum (Headwater)	988.00 ft

Outlet Connectivity

Structure Type	Outlet ID	Direction	Outfall	E1 (ft)	E2 (ft)
Orifice-Circular	Orifice - 1	Forward	Culvert - 1	984.00	988.00
Orifice-Circular	Orifice - 2	Forward	Culvert - 1	985.00	988.00
Orifice-Circular	Orifice - 3	Forward	Culvert - 1	986.25	988.00
Culvert-Circular	Culvert - 1	Forward	TW	984.00	988.00
Rectangular Weir	Weir - 1	Forward	TW	987.75	988.00
Tailwater Settings	Tailwater			(N/A)	(N/A)

Subsection: Outlet Input Data
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

Structure ID: Culvert - 1	
Structure Type: Culvert-Circular	
Number of Barrels	1
Diameter	12.0 in
Length	40.00 ft
Length (Computed Barrel)	40.00 ft
Slope (Computed)	0.010 ft/ft
Outlet Control Data	
Manning's n	0.013
Ke	0.200
Kb	0.031
Kr	0.200
Convergence Tolerance	0.00 ft
Inlet Control Data	
Equation Form	Form 1
K	0.0045
M	2.0000
C	0.0317
Y	0.6900
T1 ratio (HW/D)	1.090
T2 ratio (HW/D)	1.192
Slope Correction Factor	-0.500

Use unsubmerged inlet control 0 equation below T1 elevation.

Use submerged inlet control 0 equation above T2 elevation

In transition zone between unsubmerged and submerged inlet control, interpolate between flows at T1 & T2...

T1 Elevation	985.09 ft	T1 Flow	2.75 ft ³ /s
T2 Elevation	985.19 ft	T2 Flow	3.14 ft ³ /s

Subsection: Outlet Input Data
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

Structure ID: Orifice - 1	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	984.00 ft
Orifice Diameter	1.5 in
Orifice Coefficient	0.600
Structure ID: Orifice - 2	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	985.00 ft
Orifice Diameter	4.0 in
Orifice Coefficient	0.600
Structure ID: Orifice - 3	
Structure Type: Orifice-Circular	
Number of Openings	1
Elevation	986.25 ft
Orifice Diameter	12.0 in
Orifice Coefficient	0.600
Structure ID: Weir - 1	
Structure Type: Rectangular Weir	
Number of Openings	1
Elevation	987.75 ft
Weir Length	10.00 ft
Weir Coefficient	3.00 (ft ^{0.5})/s
Structure ID: TW	
Structure Type: TW Setup, DS Channel	
Tailwater Type	Free Outfall
Convergence Tolerances	
Maximum Iterations	30
Tailwater Tolerance (Minimum)	0.01 ft
Tailwater Tolerance (Maximum)	0.50 ft
Headwater Tolerance (Minimum)	0.01 ft
Headwater Tolerance (Maximum)	0.50 ft
Flow Tolerance (Minimum)	0.001 ft ³ /s
Flow Tolerance (Maximum)	10.000 ft ³ /s

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Culvert - 1 (Culvert-Circular)

Mannings open channel maximum capacity: 3.83 ft³/s
Upstream ID = Orifice - 1, Orifice - 2, Orifice - 3
Downstream ID = Tailwater (Pond Outfall)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
984.00	0.00	0.00	0.00	Free Outfall	0.00	0.00	(N/A)
984.50	0.04	984.11	Free Outfall	Free Outfall	0.00	0.00	(N/A)
985.00	0.05	984.13	Free Outfall	Free Outfall	0.00	0.00	(N/A)
985.50	0.31	984.32	Free Outfall	Free Outfall	0.00	0.00	(N/A)
986.00	0.47	984.40	Free Outfall	Free Outfall	0.00	0.01	(N/A)
986.25	0.52	984.43	Free Outfall	Free Outfall	0.00	0.00	(N/A)
986.50	0.78	984.53	Free Outfall	Free Outfall	0.00	0.01	(N/A)
987.00	2.24	984.97	Free Outfall	Free Outfall	0.00	0.00	(N/A)
987.50	3.95	985.49	Free Outfall	Free Outfall	0.00	0.00	(N/A)
987.75	4.45	985.76	Free Outfall	Free Outfall	0.00	0.00	(N/A)
988.00	4.89	986.04	Free Outfall	Free Outfall	0.00	0.00	(N/A)

Tailwater Error (ft) Message

0.00	WS below an invert; no flow.
0.00	CRIT.DEPTH CONTROL Vh= .026ft Dcr= .078ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .032ft Dcr= .095ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .080ft Dcr= .228ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .102ft Dcr= .284ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .107ft Dcr= .298ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .136ft Dcr= .368ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .277ft Dcr= .641ft CRIT.DEPTH Hev= .00ft
0.00	INLET CONTROL... Submerged: HW =1.49
0.00	FULL FLOW...Lfull=29.43ft Vh=.499ft HL=1.059ft Hev= .00ft

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Culvert - 1 (Culvert-Circular)

Mannings open channel maximum capacity: 3.83 ft³/s
Upstream ID = Orifice - 1, Orifice - 2, Orifice - 3
Downstream ID = Tailwater (Pond Outfall)

Tailwater Error (ft)	Message
0.00	FULL FLOW...Lfull=35.44ft Vh=.603ft HL=1.393ft Hev= .00ft

Subsection: Individual Outlet Curves
 Label: Composite Outlet Structure - 2

Return Event: 1 years
 Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
 Structure ID = Orifice - 1 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
 Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
984.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
984.50	0.04	984.50	984.11	984.11	0.00	0.00	(N/A)
985.00	0.05	985.00	984.13	984.13	0.00	0.00	(N/A)
985.50	0.06	985.50	984.32	984.32	0.00	0.00	(N/A)
986.00	0.07	986.00	984.40	984.40	0.00	0.00	(N/A)
986.25	0.08	986.25	984.43	984.43	0.00	0.00	(N/A)
986.50	0.08	986.50	984.53	984.53	0.00	0.00	(N/A)
987.00	0.08	987.00	984.97	984.97	0.00	0.00	(N/A)
987.50	0.08	987.50	985.49	985.49	0.00	0.00	(N/A)
987.75	0.08	987.75	985.76	985.76	0.00	0.00	(N/A)
988.00	0.08	988.00	986.04	986.04	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	H =.39
0.00	H =.87
0.00	H =1.18
0.00	H =1.60
0.00	H =1.82
0.00	H =1.97
0.00	H =2.03
0.00	H =2.01
0.00	H =1.99
0.00	H =1.96

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Orifice - 2 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
984.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
984.50	0.00	0.00	0.00	984.11	0.00	0.00	(N/A)
985.00	0.00	0.00	0.00	984.13	0.00	0.00	(N/A)
985.50	0.24	985.50	Free Outfall	984.32	0.00	0.00	(N/A)
986.00	0.38	986.00	Free Outfall	984.40	0.00	0.00	(N/A)
986.25	0.44	986.25	Free Outfall	984.43	0.00	0.00	(N/A)
986.50	0.48	986.50	Free Outfall	984.53	0.00	0.00	(N/A)
987.00	0.57	987.00	Free Outfall	984.97	0.00	0.00	(N/A)
987.50	0.60	987.50	985.49	985.49	0.00	0.00	(N/A)
987.75	0.59	987.75	985.76	985.76	0.00	0.00	(N/A)
988.00	0.59	988.00	986.04	986.04	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	H =.33
0.00	H =.83
0.00	H =1.08
0.00	H =1.33
0.00	H =1.83
0.00	H =2.01
0.00	H =1.99
0.00	H =1.96

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Orifice - 3 (Orifice-Circular)

Upstream ID = (Pond Water Surface)
Downstream ID = Culvert - 1 (Culvert-Circular)

Water Surface Elevation (ft)	Device Flow (ft ³ /s)	(into) Headwater Hydraulic Grade Line (ft)	Converge Downstream Hydraulic Grade Line (ft)	Next Downstream Hydraulic Grade Line (ft)	Downstream Hydraulic Grade Line Error (ft)	Convergence Error (ft ³ /s)	Downstream Channel Tailwater (ft)
984.00	0.00	0.00	0.00	0.00	0.00	0.00	(N/A)
984.50	0.00	0.00	0.00	984.11	0.00	0.00	(N/A)
985.00	0.00	0.00	0.00	984.13	0.00	0.00	(N/A)
985.50	0.00	0.00	0.00	984.32	0.00	0.00	(N/A)
986.00	0.00	0.00	0.00	984.40	0.00	0.00	(N/A)
986.25	0.00	0.00	0.00	984.43	0.00	0.00	(N/A)
986.50	0.20	986.50	Free Outfall	984.53	0.00	0.00	(N/A)
987.00	1.59	987.00	Free Outfall	984.97	0.00	0.00	(N/A)
987.50	3.27	987.50	Free Outfall	985.49	0.00	0.00	(N/A)
987.75	3.78	987.75	Free Outfall	985.76	0.00	0.00	(N/A)
988.00	4.23	988.00	Free Outfall	986.04	0.00	0.00	(N/A)

Tailwater Error (ft)	Message
----------------------	---------

0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	WS below an invert; no flow.
0.00	CRIT.DEPTH CONTROL Vh= .064ft Dcr= .185ft CRIT.DEPTH Hev= .00ft
0.00	CRIT.DEPTH CONTROL Vh= .214ft Dcr= .535ft CRIT.DEPTH Hev= .00ft
0.00	H =.75
0.00	H =1.00
0.00	H =1.25

Subsection: Individual Outlet Curves
Label: Composite Outlet Structure - 2

Return Event: 1 years
Storm Event: WQ

RATING TABLE FOR ONE OUTLET TYPE
Structure ID = Weir - 1 (Rectangular Weir)

Upstream ID = (Pond Water Surface)
Downstream ID = Tailwater (Pond Outfall)

Water Surface Elevation (ft)	Flow (ft ³ /s)	Tailwater Elevation (ft)	Convergence Error (ft)
984.00	0.00	(N/A)	0.00
984.50	0.00	(N/A)	0.00
985.00	0.00	(N/A)	0.00
985.50	0.00	(N/A)	0.00
986.00	0.00	(N/A)	0.00
986.25	0.00	(N/A)	0.00
986.50	0.00	(N/A)	0.00
987.00	0.00	(N/A)	0.00
987.50	0.00	(N/A)	0.00
987.75	0.00	(N/A)	0.00
988.00	3.75	(N/A)	0.00

Computation Messages

WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
WS below an invert; no
flow.
H=.25; Htw=.00;
Qfree=3.75;

Return Event: 1 years
Storm Event: WQ

Water Surface Elevation (ft)	Flow (ft ³ /s)	Tailwater Elevation (ft)	Convergence Error (ft)
984.00	0.00	(N/A)	0.00
984.50	0.04	(N/A)	0.00
985.00	0.05	(N/A)	0.00
985.50	0.31	(N/A)	0.00
986.00	0.47	(N/A)	0.00
986.25	0.52	(N/A)	0.00
986.50	0.78	(N/A)	0.00
987.00	2.24	(N/A)	0.00
987.50	3.95	(N/A)	0.00
987.75	4.45	(N/A)	0.00
988.00	8.64	(N/A)	0.00

(no Q: Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1, Weir - 1)
Orifice - 1, Culvert - 1
(no Q: Orifice - 2, Orifice - 3, Weir - 1)
Orifice - 1, Culvert - 1
(no Q: Orifice - 2, Orifice - 3, Weir - 1)
Orifice - 1, Orifice - 2, Culvert - 1 (no Q: Orifice - 3, Weir - 1)
Orifice - 1, Orifice - 2, Culvert - 1 (no Q: Orifice - 3, Weir - 1)
Orifice - 1, Orifice - 2, Culvert - 1 (no Q: Orifice - 3, Weir - 1)
Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1 (no Q: Weir - 1)
Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1 (no Q: Weir - 1)
Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1 (no Q: Weir - 1)
Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1 (no Q: Weir - 1)
Orifice - 1, Orifice - 2, Orifice - 3, Culvert - 1, Weir - 1

Subsection: Elevation-Volume-Flow Table (Pond)
Label: PO-1

Return Event: 1 years
Storm Event: WQ

Infiltration	
Infiltration Method (Computed)	No Infiltration
Initial Conditions	
Elevation (Water Surface, Initial)	981.00 ft
Volume (Initial)	0.000 ac-ft
Flow (Initial Outlet)	0.00 ft ³ /s
Flow (Initial Infiltration)	0.00 ft ³ /s
Flow (Initial, Total)	0.00 ft ³ /s
Time Increment	0.050 hours

Elevation (ft)	Outflow (ft ³ /s)	Storage (ac-ft)	Area (acres)	Infiltration (ft ³ /s)	Flow (Total) (ft ³ /s)	2S/t + O (ft ³ /s)
981.00	0.00	0.000	0.055	0.00	0.00	0.00
981.50	0.02	0.030	0.064	0.00	0.02	14.42
982.00	0.03	0.064	0.074	0.00	0.03	31.13
982.50	0.27	0.103	0.081	0.00	0.27	50.11
983.00	0.42	0.145	0.088	0.00	0.42	70.68
983.50	0.99	0.192	0.098	0.00	0.99	93.77
984.00	1.43	0.243	0.109	0.00	1.43	119.27
984.50	1.74	0.301	0.120	0.00	1.74	147.31
985.00	2.00	0.364	0.132	0.00	2.00	178.08

Subsection: Level Pool Pond Routing Summary
Label: PO-1 (IN)

Return Event: 1 years
Storm Event: WQ

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		981.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		1.07 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		0.02 ft³/s	Time to Peak (Flow, Outlet)
			11.950 hours
			18.650 hours
Elevation (Water Surface, Peak)		981.67 ft	
Volume (Peak)		0.041 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		0.059 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		0.019 ac-ft	
Volume (Retained)		0.039 ac-ft	
Volume (Unrouted)		-0.001 ac-ft	
Error (Mass Balance)		1.0 %	

Subsection: Level Pool Pond Routing Summary
Label: PO-1 (IN)

Return Event: 2 years
Storm Event: 2-yr

Infiltration				
Infiltration Method (Computed)		No Infiltration		
Initial Conditions				
Elevation (Water Surface, Initial)		981.00 ft		
Volume (Initial)		0.000 ac-ft		
Flow (Initial Outlet)		0.00 ft³/s		
Flow (Initial Infiltration)		0.00 ft³/s		
Flow (Initial, Total)		0.00 ft³/s		
Time Increment		0.050 hours		
Inflow/Outflow Hydrograph Summary				
Flow (Peak In)		4.32 ft³/s	Time to Peak (Flow, In)	11.900 hours
Flow (Peak Outlet)		0.39 ft³/s	Time to Peak (Flow, Outlet)	12.500 hours
Elevation (Water Surface, Peak)		982.90 ft		
Volume (Peak)		0.137 ac-ft		
Mass Balance (ac-ft)				
Volume (Initial)		0.000 ac-ft		
Volume (Total Inflow)		0.241 ac-ft		
Volume (Total Infiltration)		0.000 ac-ft		
Volume (Total Outlet Outflow)		0.173 ac-ft		
Volume (Retained)		0.068 ac-ft		
Volume (Unrouted)		0.000 ac-ft		
Error (Mass Balance)		0.1 %		

Subsection: Level Pool Pond Routing Summary
Label: PO-1 (IN)

Return Event: 10 years
Storm Event: 10-yr

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		981.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		6.90 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		1.17 ft³/s	Time to Peak (Flow, Outlet)
			11.900 hours
			12.150 hours
Peak Conditions			
Elevation (Water Surface, Peak)		983.70 ft	
Volume (Peak)		0.212 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		0.394 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		0.322 ac-ft	
Volume (Retained)		0.072 ac-ft	
Volume (Unrouted)		-0.001 ac-ft	
Error (Mass Balance)		0.1 %	

Subsection: Level Pool Pond Routing Summary
Label: PO-1 (IN)

Return Event: 100 years
Storm Event: 100-yr

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		981.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		10.92 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		1.88 ft³/s	Time to Peak (Flow, Outlet)
			11.900 hours
			12.150 hours
Elevation (Water Surface, Peak)		984.76 ft	
Volume (Peak)		0.333 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		0.640 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		0.562 ac-ft	
Volume (Retained)		0.078 ac-ft	
Volume (Unrouted)		-0.001 ac-ft	
Error (Mass Balance)		0.1 %	

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 1 years
Storm Event: WQ

Peak Discharge	0.02 ft ³ /s
Time to Peak	18.650 hours
Hydrograph Volume	0.019 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
11.300	0.00	0.00	0.00	0.00	0.00
11.550	0.00	0.00	0.00	0.00	0.00
11.800	0.00	0.01	0.01	0.01	0.01
12.050	0.01	0.02	0.02	0.02	0.02
12.300	0.02	0.02	0.02	0.02	0.02
12.550	0.02	0.02	0.02	0.02	0.02
12.800	0.02	0.02	0.02	0.02	0.02
13.050	0.02	0.02	0.02	0.02	0.02
13.300	0.02	0.02	0.02	0.02	0.02
13.550	0.02	0.02	0.02	0.02	0.02
13.800	0.02	0.02	0.02	0.02	0.02
14.050	0.02	0.02	0.02	0.02	0.02
14.300	0.02	0.02	0.02	0.02	0.02
14.550	0.02	0.02	0.02	0.02	0.02
14.800	0.02	0.02	0.02	0.02	0.02
15.050	0.02	0.02	0.02	0.02	0.02
15.300	0.02	0.02	0.02	0.02	0.02
15.550	0.02	0.02	0.02	0.02	0.02
15.800	0.02	0.02	0.02	0.02	0.02
16.050	0.02	0.02	0.02	0.02	0.02
16.300	0.02	0.02	0.02	0.02	0.02
16.550	0.02	0.02	0.02	0.02	0.02
16.800	0.02	0.02	0.02	0.02	0.02
17.050	0.02	0.02	0.02	0.02	0.02
17.300	0.02	0.02	0.02	0.02	0.02
17.550	0.02	0.02	0.02	0.02	0.02
17.800	0.02	0.02	0.02	0.02	0.02
18.050	0.02	0.02	0.02	0.02	0.02
18.300	0.02	0.02	0.02	0.02	0.02
18.550	0.02	0.02	0.02	0.02	0.02
18.800	0.02	0.02	0.02	0.02	0.02
19.050	0.02	0.02	0.02	0.02	0.02
19.300	0.02	0.02	0.02	0.02	0.02
19.550	0.02	0.02	0.02	0.02	0.02
19.800	0.02	0.02	0.02	0.02	0.02
20.050	0.02	0.02	0.02	0.02	0.02
20.300	0.02	0.02	0.02	0.02	0.02
20.550	0.02	0.02	0.02	0.02	0.02
20.800	0.02	0.02	0.02	0.02	0.02
21.050	0.02	0.02	0.02	0.02	0.02
21.300	0.02	0.02	0.02	0.02	0.02
21.550	0.02	0.02	0.02	0.02	0.02
21.800	0.02	0.02	0.02	0.02	0.02

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 1 years
Storm Event: WQ

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
22.050	0.02	0.02	0.02	0.02	0.02
22.300	0.02	0.02	0.02	0.02	0.02
22.550	0.02	0.02	0.02	0.02	0.02
22.800	0.02	0.02	0.02	0.02	0.02
23.050	0.02	0.02	0.02	0.02	0.02
23.300	0.02	0.02	0.02	0.02	0.02
23.550	0.02	0.02	0.02	0.02	0.02
23.800	0.02	0.02	0.02	0.02	0.02

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 2 years
Storm Event: 2-yr

Peak Discharge	0.39 ft ³ /s
Time to Peak	12.500 hours
Hydrograph Volume	0.173 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
7.050	0.00	0.00	0.00	0.00	0.00
7.300	0.00	0.00	0.00	0.00	0.00
7.550	0.00	0.00	0.00	0.00	0.00
7.800	0.00	0.00	0.00	0.00	0.00
8.050	0.00	0.00	0.00	0.00	0.00
8.300	0.00	0.00	0.00	0.00	0.00
8.550	0.00	0.00	0.00	0.00	0.00
8.800	0.00	0.00	0.00	0.00	0.00
9.050	0.00	0.00	0.00	0.00	0.00
9.300	0.00	0.00	0.00	0.00	0.01
9.550	0.01	0.01	0.01	0.01	0.01
9.800	0.01	0.01	0.01	0.01	0.01
10.050	0.01	0.01	0.01	0.01	0.01
10.300	0.01	0.01	0.01	0.01	0.01
10.550	0.01	0.01	0.01	0.01	0.01
10.800	0.01	0.01	0.01	0.01	0.01
11.050	0.01	0.01	0.01	0.01	0.01
11.300	0.01	0.02	0.02	0.02	0.02
11.550	0.02	0.02	0.02	0.02	0.02
11.800	0.02	0.04	0.14	0.24	0.31
12.050	0.35	0.37	0.37	0.38	0.38
12.300	0.39	0.39	0.39	0.39	0.39
12.550	0.39	0.39	0.39	0.39	0.38
12.800	0.38	0.38	0.38	0.38	0.38
13.050	0.37	0.37	0.37	0.37	0.36
13.300	0.36	0.36	0.36	0.36	0.35
13.550	0.35	0.35	0.35	0.34	0.34
13.800	0.34	0.34	0.33	0.33	0.33
14.050	0.32	0.32	0.32	0.32	0.31
14.300	0.31	0.31	0.31	0.30	0.30
14.550	0.30	0.30	0.29	0.29	0.29
14.800	0.29	0.28	0.28	0.28	0.28
15.050	0.27	0.27	0.27	0.27	0.26
15.300	0.26	0.25	0.25	0.25	0.24
15.550	0.24	0.23	0.23	0.23	0.22
15.800	0.22	0.22	0.21	0.21	0.21
16.050	0.20	0.20	0.20	0.20	0.19
16.300	0.19	0.19	0.18	0.18	0.18
16.550	0.18	0.17	0.17	0.17	0.17
16.800	0.17	0.16	0.16	0.16	0.16
17.050	0.15	0.15	0.15	0.15	0.15
17.300	0.14	0.14	0.14	0.14	0.14
17.550	0.14	0.13	0.13	0.13	0.13

Subsection: Pond Routed Hydrograph (total out)
 Label: PO-1 (OUT)

Return Event: 2 years
 Storm Event: 2-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
17.800	0.13	0.13	0.13	0.12	0.12
18.050	0.12	0.12	0.12	0.12	0.12
18.300	0.11	0.11	0.11	0.11	0.11
18.550	0.11	0.11	0.11	0.10	0.10
18.800	0.10	0.10	0.10	0.10	0.10
19.050	0.10	0.10	0.10	0.09	0.09
19.300	0.09	0.09	0.09	0.09	0.09
19.550	0.09	0.09	0.09	0.09	0.08
19.800	0.08	0.08	0.08	0.08	0.08
20.050	0.08	0.08	0.08	0.08	0.08
20.300	0.08	0.08	0.07	0.07	0.07
20.550	0.07	0.07	0.07	0.07	0.07
20.800	0.07	0.07	0.07	0.07	0.07
21.050	0.07	0.07	0.07	0.07	0.06
21.300	0.06	0.06	0.06	0.06	0.06
21.550	0.06	0.06	0.06	0.06	0.06
21.800	0.06	0.06	0.06	0.06	0.06
22.050	0.06	0.06	0.06	0.06	0.06
22.300	0.06	0.06	0.06	0.06	0.06
22.550	0.06	0.06	0.05	0.05	0.05
22.800	0.05	0.05	0.05	0.05	0.05
23.050	0.05	0.05	0.05	0.05	0.05
23.300	0.05	0.05	0.05	0.05	0.05
23.550	0.05	0.05	0.05	0.05	0.05
23.800	0.05	0.05	0.05	0.05	0.05

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 10 years
Storm Event: 10-yr

Peak Discharge	1.17 ft ³ /s
Time to Peak	12.150 hours
Hydrograph Volume	0.322 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
5.250	0.00	0.00	0.00	0.00	0.00
5.500	0.00	0.00	0.00	0.00	0.00
5.750	0.00	0.00	0.00	0.00	0.00
6.000	0.00	0.00	0.00	0.00	0.00
6.250	0.00	0.00	0.00	0.00	0.00
6.500	0.00	0.00	0.00	0.00	0.00
6.750	0.00	0.00	0.00	0.00	0.00
7.000	0.00	0.00	0.00	0.00	0.00
7.250	0.00	0.00	0.00	0.00	0.00
7.500	0.00	0.01	0.01	0.01	0.01
7.750	0.01	0.01	0.01	0.01	0.01
8.000	0.01	0.01	0.01	0.01	0.01
8.250	0.01	0.01	0.01	0.01	0.01
8.500	0.01	0.01	0.01	0.01	0.01
8.750	0.01	0.01	0.01	0.01	0.01
9.000	0.01	0.01	0.01	0.01	0.01
9.250	0.01	0.01	0.01	0.01	0.01
9.500	0.01	0.01	0.01	0.01	0.01
9.750	0.01	0.01	0.01	0.01	0.02
10.000	0.02	0.02	0.02	0.02	0.02
10.250	0.02	0.02	0.02	0.02	0.02
10.500	0.02	0.02	0.02	0.02	0.02
10.750	0.02	0.02	0.02	0.02	0.02
11.000	0.02	0.02	0.02	0.02	0.02
11.250	0.02	0.02	0.02	0.02	0.02
11.500	0.02	0.02	0.04	0.07	0.12
11.750	0.18	0.26	0.33	0.41	0.70
12.000	0.97	1.10	1.16	1.17	1.17
12.250	1.16	1.15	1.14	1.12	1.11
12.500	1.09	1.07	1.05	1.03	1.02
12.750	1.00	0.97	0.94	0.91	0.89
13.000	0.86	0.84	0.81	0.79	0.77
13.250	0.74	0.72	0.70	0.68	0.66
13.500	0.64	0.62	0.61	0.59	0.57
13.750	0.56	0.54	0.53	0.51	0.50
14.000	0.48	0.47	0.46	0.45	0.43
14.250	0.42	0.42	0.41	0.41	0.41
14.500	0.40	0.40	0.40	0.39	0.39
14.750	0.39	0.39	0.38	0.38	0.38
15.000	0.37	0.37	0.37	0.37	0.36
15.250	0.36	0.36	0.35	0.35	0.35
15.500	0.35	0.34	0.34	0.34	0.34
15.750	0.33	0.33	0.33	0.32	0.32

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 10 years
Storm Event: 10-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
16.000	0.32	0.32	0.31	0.31	0.31
16.250	0.31	0.30	0.30	0.30	0.30
16.500	0.29	0.29	0.29	0.29	0.28
16.750	0.28	0.28	0.28	0.27	0.27
17.000	0.27	0.27	0.26	0.26	0.26
17.250	0.25	0.25	0.24	0.24	0.24
17.500	0.23	0.23	0.23	0.23	0.22
17.750	0.22	0.22	0.21	0.21	0.21
18.000	0.21	0.20	0.20	0.20	0.20
18.250	0.19	0.19	0.19	0.19	0.18
18.500	0.18	0.18	0.18	0.17	0.17
18.750	0.17	0.17	0.17	0.16	0.16
19.000	0.16	0.16	0.16	0.16	0.15
19.250	0.15	0.15	0.15	0.15	0.15
19.500	0.14	0.14	0.14	0.14	0.14
19.750	0.14	0.13	0.13	0.13	0.13
20.000	0.13	0.13	0.13	0.12	0.12
20.250	0.12	0.12	0.12	0.12	0.12
20.500	0.12	0.12	0.11	0.11	0.11
20.750	0.11	0.11	0.11	0.11	0.11
21.000	0.11	0.11	0.10	0.10	0.10
21.250	0.10	0.10	0.10	0.10	0.10
21.500	0.10	0.10	0.10	0.10	0.10
21.750	0.09	0.09	0.09	0.09	0.09
22.000	0.09	0.09	0.09	0.09	0.09
22.250	0.09	0.09	0.09	0.09	0.09
22.500	0.09	0.09	0.09	0.08	0.08
22.750	0.08	0.08	0.08	0.08	0.08
23.000	0.08	0.08	0.08	0.08	0.08
23.250	0.08	0.08	0.08	0.08	0.08
23.500	0.08	0.08	0.08	0.08	0.08
23.750	0.08	0.08	0.08	0.08	0.08
24.000	0.08	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Pond Routed Hydrograph (total out)
Label: PO-1 (OUT)

Return Event: 100 years
Storm Event: 100-yr

Peak Discharge	1.88 ft ³ /s
Time to Peak	12.150 hours
Hydrograph Volume	0.562 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
3.750	0.00	0.00	0.00	0.00	0.00
4.000	0.00	0.00	0.00	0.00	0.00
4.250	0.00	0.00	0.00	0.00	0.00
4.500	0.00	0.00	0.00	0.00	0.00
4.750	0.00	0.00	0.00	0.00	0.00
5.000	0.00	0.00	0.00	0.00	0.00
5.250	0.00	0.00	0.00	0.00	0.00
5.500	0.00	0.00	0.01	0.01	0.01
5.750	0.01	0.01	0.01	0.01	0.01
6.000	0.01	0.01	0.01	0.01	0.01
6.250	0.01	0.01	0.01	0.01	0.01
6.500	0.01	0.01	0.01	0.01	0.01
6.750	0.01	0.01	0.01	0.01	0.01
7.000	0.01	0.01	0.01	0.01	0.01
7.250	0.01	0.01	0.01	0.01	0.01
7.500	0.01	0.01	0.01	0.01	0.01
7.750	0.01	0.01	0.01	0.02	0.02
8.000	0.02	0.02	0.02	0.02	0.02
8.250	0.02	0.02	0.02	0.02	0.02
8.500	0.02	0.02	0.02	0.02	0.02
8.750	0.02	0.02	0.02	0.02	0.02
9.000	0.02	0.02	0.02	0.02	0.02
9.250	0.02	0.02	0.02	0.02	0.02
9.500	0.02	0.02	0.02	0.02	0.02
9.750	0.02	0.02	0.02	0.02	0.02
10.000	0.02	0.02	0.02	0.02	0.02
10.250	0.02	0.03	0.03	0.04	0.05
10.500	0.06	0.07	0.07	0.08	0.09
10.750	0.10	0.11	0.12	0.13	0.14
11.000	0.15	0.16	0.17	0.18	0.19
11.250	0.21	0.22	0.23	0.25	0.26
11.500	0.28	0.29	0.30	0.33	0.37
11.750	0.45	0.69	1.01	1.30	1.55
12.000	1.73	1.83	1.87	1.88	1.87
12.250	1.87	1.86	1.85	1.84	1.82
12.500	1.81	1.79	1.77	1.76	1.74
12.750	1.71	1.69	1.67	1.64	1.62
13.000	1.60	1.57	1.55	1.53	1.50
13.250	1.48	1.46	1.44	1.41	1.38
13.500	1.35	1.31	1.28	1.25	1.22
13.750	1.20	1.17	1.14	1.11	1.09
14.000	1.06	1.04	1.01	0.99	0.96
14.250	0.92	0.89	0.87	0.84	0.81

Subsection: Pond Routed Hydrograph (total out)
 Label: PO-1 (OUT)

Return Event: 100 years
 Storm Event: 100-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
14.500	0.79	0.76	0.74	0.72	0.69
14.750	0.67	0.65	0.64	0.62	0.60
15.000	0.58	0.57	0.55	0.54	0.52
15.250	0.51	0.50	0.49	0.47	0.46
15.500	0.45	0.44	0.43	0.42	0.42
15.750	0.41	0.41	0.41	0.40	0.40
16.000	0.40	0.40	0.39	0.39	0.39
16.250	0.39	0.38	0.38	0.38	0.37
16.500	0.37	0.37	0.37	0.36	0.36
16.750	0.36	0.36	0.35	0.35	0.35
17.000	0.35	0.35	0.34	0.34	0.34
17.250	0.34	0.33	0.33	0.33	0.33
17.500	0.32	0.32	0.32	0.32	0.32
17.750	0.31	0.31	0.31	0.31	0.31
18.000	0.30	0.30	0.30	0.30	0.30
18.250	0.29	0.29	0.29	0.29	0.29
18.500	0.28	0.28	0.28	0.28	0.28
18.750	0.27	0.27	0.27	0.27	0.26
19.000	0.26	0.26	0.25	0.25	0.25
19.250	0.24	0.24	0.24	0.24	0.23
19.500	0.23	0.23	0.23	0.22	0.22
19.750	0.22	0.22	0.21	0.21	0.21
20.000	0.21	0.20	0.20	0.20	0.20
20.250	0.19	0.19	0.19	0.19	0.19
20.500	0.18	0.18	0.18	0.18	0.18
20.750	0.18	0.17	0.17	0.17	0.17
21.000	0.17	0.17	0.16	0.16	0.16
21.250	0.16	0.16	0.16	0.16	0.16
21.500	0.15	0.15	0.15	0.15	0.15
21.750	0.15	0.15	0.15	0.15	0.14
22.000	0.14	0.14	0.14	0.14	0.14
22.250	0.14	0.14	0.14	0.14	0.14
22.500	0.13	0.13	0.13	0.13	0.13
22.750	0.13	0.13	0.13	0.13	0.13
23.000	0.13	0.13	0.13	0.13	0.12
23.250	0.12	0.12	0.12	0.12	0.12
23.500	0.12	0.12	0.12	0.12	0.12
23.750	0.12	0.12	0.12	0.12	0.12
24.000	0.12	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Elevation-Volume-Flow Table (Pond)
Label: PO-2

Return Event: 1 years
Storm Event: WQ

Infiltration	
Infiltration Method (Computed)	No Infiltration
Initial Conditions	
Elevation (Water Surface, Initial)	984.00 ft
Volume (Initial)	0.000 ac-ft
Flow (Initial Outlet)	0.00 ft ³ /s
Flow (Initial Infiltration)	0.00 ft ³ /s
Flow (Initial, Total)	0.00 ft ³ /s
Time Increment	0.050 hours

Elevation (ft)	Outflow (ft ³ /s)	Storage (ac-ft)	Area (acres)	Infiltration (ft ³ /s)	Flow (Total) (ft ³ /s)	2S/t + O (ft ³ /s)
984.00	0.00	0.000	0.098	0.00	0.00	0.00
984.50	0.04	0.053	0.115	0.00	0.04	25.76
985.00	0.05	0.115	0.133	0.00	0.05	55.74
985.50	0.31	0.186	0.150	0.00	0.31	90.16
986.00	0.47	0.265	0.167	0.00	0.47	128.60
986.25	0.52	0.308	0.176	0.00	0.52	149.40
986.50	0.78	0.353	0.186	0.00	0.78	171.54
987.00	2.24	0.450	0.205	0.00	2.24	220.24
987.50	3.95	0.558	0.224	0.00	3.95	273.85
987.75	4.45	0.615	0.234	0.00	4.45	302.06
988.00	8.64	0.675	0.244	0.00	8.64	335.16

Subsection: Level Pool Pond Routing Summary
Label: PO-2 (IN)

Return Event: 1 years
Storm Event: WQ

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		984.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		2.10 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		0.04 ft³/s	Time to Peak (Flow, Outlet)
			11.950 hours
			18.000 hours
Elevation (Water Surface, Peak)			
		984.70 ft	
Volume (Peak)		0.077 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		0.116 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		0.043 ac-ft	
Volume (Retained)		0.072 ac-ft	
Volume (Unrouted)		-0.001 ac-ft	
Error (Mass Balance)		1.0 %	

Subsection: Level Pool Pond Routing Summary
Label: PO-2 (IN)

Return Event: 2 years
Storm Event: 2-yr

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)	984.00 ft		
Volume (Initial)	0.000 ac-ft		
Flow (Initial Outlet)	0.00 ft³/s		
Flow (Initial Infiltration)	0.00 ft³/s		
Flow (Initial, Total)	0.00 ft³/s		
Time Increment	0.050 hours		
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)	8.86 ft³/s	Time to Peak (Flow, In)	11.900 hours
Flow (Peak Outlet)	0.50 ft³/s	Time to Peak (Flow, Outlet)	13.000 hours
Elevation (Water Surface, Peak)	986.17 ft		
Volume (Peak)	0.293 ac-ft		
Mass Balance (ac-ft)			
Volume (Initial)	0.000 ac-ft		
Volume (Total Inflow)	0.493 ac-ft		
Volume (Total Infiltration)	0.000 ac-ft		
Volume (Total Outlet Outflow)	0.351 ac-ft		
Volume (Retained)	0.140 ac-ft		
Volume (Unrouted)	-0.002 ac-ft		
Error (Mass Balance)	0.3 %		

Subsection: Level Pool Pond Routing Summary
Label: PO-2 (IN)

Return Event: 10 years
Storm Event: 10-yr

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		984.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		14.31 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		2.17 ft³/s	Time to Peak (Flow, Outlet)
			11.900 hours
			12.200 hours
Elevation (Water Surface, Peak)		986.98 ft	
Volume (Peak)		0.446 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		0.812 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		0.643 ac-ft	
Volume (Retained)		0.167 ac-ft	
Volume (Unrouted)		-0.002 ac-ft	
Error (Mass Balance)		0.2 %	

Subsection: Level Pool Pond Routing Summary
Label: PO-2 (IN)

Return Event: 100 years
Storm Event: 100-yr

Infiltration			
Infiltration Method (Computed)		No Infiltration	
Initial Conditions			
Elevation (Water Surface, Initial)		984.00 ft	
Volume (Initial)		0.000 ac-ft	
Flow (Initial Outlet)		0.00 ft³/s	
Flow (Initial Infiltration)		0.00 ft³/s	
Flow (Initial, Total)		0.00 ft³/s	
Time Increment		0.050 hours	
Inflow/Outflow Hydrograph Summary			
Flow (Peak In)		22.82 ft³/s	Time to Peak (Flow, In)
Flow (Peak Outlet)		8.03 ft³/s	Time to Peak (Flow, Outlet)
Elevation (Water Surface, Peak)		987.96 ft	
Volume (Peak)		0.666 ac-ft	
Mass Balance (ac-ft)			
Volume (Initial)		0.000 ac-ft	
Volume (Total Inflow)		1.329 ac-ft	
Volume (Total Infiltration)		0.000 ac-ft	
Volume (Total Outlet Outflow)		1.121 ac-ft	
Volume (Retained)		0.206 ac-ft	
Volume (Unrouted)		-0.002 ac-ft	
Error (Mass Balance)		0.2 %	

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 1 years
Storm Event: WQ

Peak Discharge	0.04 ft ³ /s
Time to Peak	18.000 hours
Hydrograph Volume	0.043 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
11.000	0.00	0.00	0.00	0.00	0.00
11.250	0.00	0.00	0.00	0.00	0.00
11.500	0.00	0.00	0.00	0.00	0.01
11.750	0.01	0.01	0.01	0.02	0.02
12.000	0.03	0.03	0.04	0.04	0.04
12.250	0.04	0.04	0.04	0.04	0.04
12.500	0.04	0.04	0.04	0.04	0.04
12.750	0.04	0.04	0.04	0.04	0.04
13.000	0.04	0.04	0.04	0.04	0.04
13.250	0.04	0.04	0.04	0.04	0.04
13.500	0.04	0.04	0.04	0.04	0.04
13.750	0.04	0.04	0.04	0.04	0.04
14.000	0.04	0.04	0.04	0.04	0.04
14.250	0.04	0.04	0.04	0.04	0.04
14.500	0.04	0.04	0.04	0.04	0.04
14.750	0.04	0.04	0.04	0.04	0.04
15.000	0.04	0.04	0.04	0.04	0.04
15.250	0.04	0.04	0.04	0.04	0.04
15.500	0.04	0.04	0.04	0.04	0.04
15.750	0.04	0.04	0.04	0.04	0.04
16.000	0.04	0.04	0.04	0.04	0.04
16.250	0.04	0.04	0.04	0.04	0.04
16.500	0.04	0.04	0.04	0.04	0.04
16.750	0.04	0.04	0.04	0.04	0.04
17.000	0.04	0.04	0.04	0.04	0.04
17.250	0.04	0.04	0.04	0.04	0.04
17.500	0.04	0.04	0.04	0.04	0.04
17.750	0.04	0.04	0.04	0.04	0.04
18.000	0.04	0.04	0.04	0.04	0.04
18.250	0.04	0.04	0.04	0.04	0.04
18.500	0.04	0.04	0.04	0.04	0.04
18.750	0.04	0.04	0.04	0.04	0.04
19.000	0.04	0.04	0.04	0.04	0.04
19.250	0.04	0.04	0.04	0.04	0.04
19.500	0.04	0.04	0.04	0.04	0.04
19.750	0.04	0.04	0.04	0.04	0.04
20.000	0.04	0.04	0.04	0.04	0.04
20.250	0.04	0.04	0.04	0.04	0.04
20.500	0.04	0.04	0.04	0.04	0.04
20.750	0.04	0.04	0.04	0.04	0.04
21.000	0.04	0.04	0.04	0.04	0.04
21.250	0.04	0.04	0.04	0.04	0.04
21.500	0.04	0.04	0.04	0.04	0.04

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 1 years
Storm Event: WQ

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
21.750	0.04	0.04	0.04	0.04	0.04
22.000	0.04	0.04	0.04	0.04	0.04
22.250	0.04	0.04	0.04	0.04	0.04
22.500	0.04	0.04	0.04	0.04	0.04
22.750	0.04	0.04	0.04	0.04	0.04
23.000	0.04	0.04	0.04	0.04	0.04
23.250	0.04	0.04	0.04	0.04	0.04
23.500	0.04	0.04	0.04	0.04	0.04
23.750	0.04	0.04	0.04	0.04	0.04
24.000	0.04	(N/A)	(N/A)	(N/A)	(N/A)

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 2 years
Storm Event: 2-yr

Peak Discharge	0.50 ft ³ /s
Time to Peak	13.000 hours
Hydrograph Volume	0.351 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
6.550	0.00	0.00	0.00	0.00	0.00
6.800	0.00	0.00	0.00	0.00	0.00
7.050	0.00	0.00	0.00	0.00	0.00
7.300	0.00	0.00	0.00	0.00	0.00
7.550	0.00	0.00	0.00	0.00	0.00
7.800	0.00	0.00	0.00	0.00	0.00
8.050	0.00	0.00	0.00	0.00	0.00
8.300	0.00	0.01	0.01	0.01	0.01
8.550	0.01	0.01	0.01	0.01	0.01
8.800	0.01	0.01	0.01	0.01	0.01
9.050	0.01	0.01	0.01	0.01	0.01
9.300	0.01	0.01	0.01	0.01	0.01
9.550	0.01	0.01	0.01	0.01	0.01
9.800	0.01	0.01	0.01	0.01	0.01
10.050	0.01	0.01	0.02	0.02	0.02
10.300	0.02	0.02	0.02	0.02	0.02
10.550	0.02	0.02	0.02	0.02	0.02
10.800	0.02	0.02	0.02	0.03	0.03
11.050	0.03	0.03	0.03	0.03	0.03
11.300	0.03	0.03	0.04	0.04	0.04
11.550	0.04	0.04	0.04	0.04	0.05
11.800	0.05	0.11	0.23	0.33	0.40
12.050	0.44	0.47	0.48	0.48	0.48
12.300	0.49	0.49	0.49	0.49	0.50
12.550	0.50	0.50	0.50	0.50	0.50
12.800	0.50	0.50	0.50	0.50	0.50
13.050	0.50	0.50	0.50	0.50	0.50
13.300	0.50	0.50	0.50	0.50	0.50
13.550	0.50	0.50	0.50	0.50	0.49
13.800	0.49	0.49	0.49	0.49	0.49
14.050	0.49	0.49	0.49	0.49	0.49
14.300	0.48	0.48	0.48	0.48	0.48
14.550	0.48	0.48	0.48	0.48	0.48
14.800	0.47	0.47	0.47	0.47	0.47
15.050	0.47	0.47	0.47	0.46	0.46
15.300	0.46	0.46	0.46	0.45	0.45
15.550	0.45	0.45	0.45	0.44	0.44
15.800	0.44	0.44	0.44	0.43	0.43
16.050	0.43	0.43	0.42	0.42	0.42
16.300	0.42	0.42	0.41	0.41	0.41
16.550	0.41	0.41	0.40	0.40	0.40
16.800	0.40	0.40	0.39	0.39	0.39
17.050	0.39	0.39	0.39	0.38	0.38

Subsection: Pond Routed Hydrograph (total out)
 Label: PO-2 (OUT)

Return Event: 2 years
 Storm Event: 2-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
17.300	0.38	0.38	0.38	0.37	0.37
17.550	0.37	0.37	0.37	0.36	0.36
17.800	0.36	0.36	0.36	0.36	0.35
18.050	0.35	0.35	0.35	0.35	0.35
18.300	0.34	0.34	0.34	0.34	0.34
18.550	0.33	0.33	0.33	0.33	0.33
18.800	0.33	0.32	0.32	0.32	0.32
19.050	0.32	0.32	0.31	0.31	0.31
19.300	0.31	0.31	0.31	0.30	0.30
19.550	0.30	0.29	0.29	0.29	0.29
19.800	0.28	0.28	0.28	0.28	0.27
20.050	0.27	0.27	0.27	0.26	0.26
20.300	0.26	0.26	0.25	0.25	0.25
20.550	0.25	0.25	0.24	0.24	0.24
20.800	0.24	0.24	0.23	0.23	0.23
21.050	0.23	0.23	0.22	0.22	0.22
21.300	0.22	0.22	0.21	0.21	0.21
21.550	0.21	0.21	0.21	0.20	0.20
21.800	0.20	0.20	0.20	0.20	0.20
22.050	0.19	0.19	0.19	0.19	0.19
22.300	0.19	0.19	0.18	0.18	0.18
22.550	0.18	0.18	0.18	0.18	0.18
22.800	0.17	0.17	0.17	0.17	0.17
23.050	0.17	0.17	0.17	0.16	0.16
23.300	0.16	0.16	0.16	0.16	0.16
23.550	0.16	0.16	0.16	0.15	0.15
23.800	0.15	0.15	0.15	0.15	0.15

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 10 years
Storm Event: 10-yr

Peak Discharge	2.17 ft ³ /s
Time to Peak	12.200 hours
Hydrograph Volume	0.643 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
4.850	0.00	0.00	0.00	0.00	0.00
5.100	0.00	0.00	0.00	0.00	0.00
5.350	0.00	0.00	0.00	0.00	0.00
5.600	0.00	0.00	0.00	0.00	0.00
5.850	0.00	0.00	0.00	0.00	0.00
6.100	0.00	0.00	0.00	0.00	0.00
6.350	0.01	0.01	0.01	0.01	0.01
6.600	0.01	0.01	0.01	0.01	0.01
6.850	0.01	0.01	0.01	0.01	0.01
7.100	0.01	0.01	0.01	0.01	0.01
7.350	0.01	0.01	0.01	0.01	0.01
7.600	0.01	0.01	0.01	0.01	0.01
7.850	0.01	0.01	0.01	0.01	0.01
8.100	0.01	0.01	0.01	0.02	0.02
8.350	0.02	0.02	0.02	0.02	0.02
8.600	0.02	0.02	0.02	0.02	0.02
8.850	0.02	0.02	0.02	0.02	0.02
9.100	0.02	0.02	0.02	0.02	0.03
9.350	0.03	0.03	0.03	0.03	0.03
9.600	0.03	0.03	0.03	0.03	0.03
9.850	0.03	0.03	0.03	0.03	0.04
10.100	0.04	0.04	0.04	0.04	0.04
10.350	0.04	0.04	0.04	0.04	0.04
10.600	0.04	0.04	0.04	0.04	0.04
10.850	0.04	0.04	0.04	0.05	0.05
11.100	0.05	0.05	0.05	0.05	0.05
11.350	0.05	0.05	0.05	0.06	0.08
11.600	0.11	0.15	0.20	0.27	0.34
11.850	0.42	0.50	0.73	1.38	1.88
12.100	2.12	2.17	2.17	2.16	2.14
12.350	2.11	2.08	2.04	1.99	1.94
12.600	1.89	1.84	1.78	1.73	1.68
12.850	1.63	1.59	1.54	1.49	1.45
13.100	1.41	1.36	1.32	1.28	1.25
13.350	1.21	1.18	1.14	1.11	1.08
13.600	1.04	1.01	0.99	0.96	0.93
13.850	0.91	0.88	0.86	0.83	0.81
14.100	0.79	0.77	0.77	0.76	0.75
14.350	0.74	0.73	0.73	0.72	0.71
14.600	0.70	0.70	0.69	0.68	0.68
14.850	0.67	0.66	0.65	0.65	0.64
15.100	0.63	0.63	0.62	0.61	0.61
15.350	0.60	0.60	0.59	0.58	0.58

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 10 years
Storm Event: 10-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
15.600	0.57	0.56	0.56	0.55	0.55
15.850	0.54	0.54	0.53	0.52	0.52
16.100	0.52	0.51	0.51	0.51	0.51
16.350	0.51	0.51	0.51	0.51	0.51
16.600	0.50	0.50	0.50	0.50	0.50
16.850	0.50	0.50	0.50	0.50	0.49
17.100	0.49	0.49	0.49	0.49	0.49
17.350	0.49	0.49	0.49	0.48	0.48
17.600	0.48	0.48	0.48	0.48	0.48
17.850	0.48	0.47	0.47	0.47	0.47
18.100	0.47	0.47	0.47	0.46	0.46
18.350	0.46	0.46	0.46	0.45	0.45
18.600	0.45	0.45	0.45	0.44	0.44
18.850	0.44	0.44	0.44	0.43	0.43
19.100	0.43	0.43	0.42	0.42	0.42
19.350	0.42	0.42	0.41	0.41	0.41
19.600	0.41	0.41	0.40	0.40	0.40
19.850	0.40	0.40	0.39	0.39	0.39
20.100	0.39	0.39	0.39	0.38	0.38
20.350	0.38	0.38	0.38	0.37	0.37
20.600	0.37	0.37	0.37	0.36	0.36
20.850	0.36	0.36	0.36	0.36	0.35
21.100	0.35	0.35	0.35	0.35	0.35
21.350	0.34	0.34	0.34	0.34	0.34
21.600	0.34	0.33	0.33	0.33	0.33
21.850	0.33	0.33	0.33	0.32	0.32
22.100	0.32	0.32	0.32	0.32	0.32
22.350	0.31	0.31	0.31	0.31	0.31
22.600	0.31	0.30	0.30	0.30	0.30
22.850	0.29	0.29	0.29	0.29	0.29
23.100	0.28	0.28	0.28	0.28	0.27
23.350	0.27	0.27	0.27	0.27	0.26
23.600	0.26	0.26	0.26	0.26	0.26
23.850	0.25	0.25	0.25	0.25	(N/A)

Subsection: Pond Routed Hydrograph (total out)
Label: PO-2 (OUT)

Return Event: 100 years
Storm Event: 100-yr

Peak Discharge	8.03 ft ³ /s
Time to Peak	12.100 hours
Hydrograph Volume	1.121 ac-ft

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
3.450	0.00	0.00	0.00	0.00	0.00
3.700	0.00	0.00	0.00	0.00	0.00
3.950	0.00	0.00	0.00	0.00	0.00
4.200	0.00	0.00	0.00	0.00	0.00
4.450	0.00	0.00	0.00	0.00	0.01
4.700	0.01	0.01	0.01	0.01	0.01
4.950	0.01	0.01	0.01	0.01	0.01
5.200	0.01	0.01	0.01	0.01	0.01
5.450	0.01	0.01	0.01	0.01	0.01
5.700	0.01	0.01	0.01	0.01	0.01
5.950	0.01	0.01	0.01	0.01	0.02
6.200	0.02	0.02	0.02	0.02	0.02
6.450	0.02	0.02	0.02	0.02	0.02
6.700	0.02	0.02	0.02	0.02	0.02
6.950	0.02	0.02	0.02	0.02	0.02
7.200	0.03	0.03	0.03	0.03	0.03
7.450	0.03	0.03	0.03	0.03	0.03
7.700	0.03	0.03	0.03	0.03	0.03
7.950	0.03	0.04	0.04	0.04	0.04
8.200	0.04	0.04	0.04	0.04	0.04
8.450	0.04	0.04	0.04	0.04	0.04
8.700	0.04	0.04	0.04	0.04	0.04
8.950	0.04	0.04	0.04	0.04	0.04
9.200	0.04	0.05	0.05	0.05	0.05
9.450	0.05	0.05	0.05	0.05	0.05
9.700	0.05	0.05	0.05	0.05	0.05
9.950	0.05	0.05	0.05	0.05	0.06
10.200	0.07	0.08	0.09	0.10	0.11
10.450	0.12	0.13	0.13	0.14	0.15
10.700	0.17	0.18	0.19	0.20	0.21
10.950	0.22	0.24	0.25	0.26	0.28
11.200	0.29	0.31	0.32	0.33	0.34
11.450	0.35	0.36	0.38	0.40	0.44
11.700	0.48	0.52	0.77	1.61	2.75
11.950	3.97	5.08	7.69	8.03	7.19
12.200	6.25	5.45	4.78	4.42	4.35
12.450	4.27	4.19	4.11	4.02	3.92
12.700	3.76	3.62	3.47	3.34	3.21
12.950	3.08	2.96	2.85	2.74	2.64
13.200	2.54	2.44	2.35	2.26	2.18
13.450	2.11	2.04	1.97	1.90	1.84
13.700	1.78	1.72	1.66	1.61	1.56
13.950	1.51	1.46	1.42	1.37	1.33

Subsection: Pond Routed Hydrograph (total out)
 Label: PO-2 (OUT)

Return Event: 100 years
 Storm Event: 100-yr

HYDROGRAPH ORDINATES (ft³/s)
Output Time Increment = 0.050 hours
Time on left represents time for first value in each row.

Time (hours)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)	Flow (ft ³ /s)
14.200	1.29	1.25	1.22	1.18	1.15
14.450	1.12	1.09	1.06	1.04	1.01
14.700	0.99	0.96	0.94	0.92	0.90
14.950	0.88	0.86	0.84	0.83	0.81
15.200	0.79	0.78	0.77	0.77	0.76
15.450	0.75	0.75	0.74	0.74	0.73
15.700	0.72	0.72	0.71	0.71	0.70
15.950	0.69	0.69	0.68	0.68	0.67
16.200	0.66	0.66	0.65	0.65	0.64
16.450	0.64	0.63	0.63	0.62	0.61
16.700	0.61	0.60	0.60	0.59	0.59
16.950	0.59	0.58	0.58	0.57	0.57
17.200	0.56	0.56	0.55	0.55	0.54
17.450	0.54	0.54	0.53	0.53	0.52
17.700	0.52	0.52	0.52	0.51	0.51
17.950	0.51	0.51	0.51	0.51	0.51
18.200	0.51	0.51	0.51	0.51	0.51
18.450	0.50	0.50	0.50	0.50	0.50
18.700	0.50	0.50	0.50	0.50	0.50
18.950	0.50	0.49	0.49	0.49	0.49
19.200	0.49	0.49	0.49	0.49	0.49
19.450	0.49	0.49	0.48	0.48	0.48
19.700	0.48	0.48	0.48	0.48	0.48
19.950	0.48	0.47	0.47	0.47	0.47
20.200	0.47	0.47	0.47	0.47	0.46
20.450	0.46	0.46	0.46	0.46	0.45
20.700	0.45	0.45	0.45	0.45	0.45
20.950	0.44	0.44	0.44	0.44	0.44
21.200	0.44	0.43	0.43	0.43	0.43
21.450	0.43	0.43	0.42	0.42	0.42
21.700	0.42	0.42	0.42	0.41	0.41
21.950	0.41	0.41	0.41	0.41	0.40
22.200	0.40	0.40	0.40	0.40	0.40
22.450	0.40	0.39	0.39	0.39	0.39
22.700	0.39	0.39	0.39	0.38	0.38
22.950	0.38	0.38	0.38	0.38	0.38
23.200	0.37	0.37	0.37	0.37	0.37
23.450	0.37	0.37	0.37	0.36	0.36
23.700	0.36	0.36	0.36	0.36	0.36
23.950	0.35	0.35	(N/A)	(N/A)	(N/A)

Index

C

CM-1 (Runoff CN-Area, 1 years)...13, 14
CM-1 (Time of Concentration Calculations, 1 years)...11, 12
CM-1 (Unit Hydrograph Summary, 1 years)...15, 16
CM-1 (Unit Hydrograph Summary, 10 years)...19, 20
CM-1 (Unit Hydrograph Summary, 100 years)...21, 22
CM-1 (Unit Hydrograph Summary, 2 years)...17, 18
CM-2 (Unit Hydrograph Summary, 1 years)...23
CM-2 (Unit Hydrograph Summary, 10 years)...25
CM-2 (Unit Hydrograph Summary, 100 years)...26
CM-2 (Unit Hydrograph Summary, 2 years)...24
CM-3 (Unit Hydrograph Summary, 1 years)...27
CM-3 (Unit Hydrograph Summary, 10 years)...29
CM-3 (Unit Hydrograph Summary, 100 years)...30
CM-3 (Unit Hydrograph Summary, 2 years)...28
Composite Outlet Structure - 1 (Composite Rating Curve, 1 years)...40
Composite Outlet Structure - 1 (Individual Outlet Curves, 1 years)...36, 37, 38, 39
Composite Outlet Structure - 1 (Outlet Input Data, 1 years)...33, 34, 35
Composite Outlet Structure - 2 (Composite Rating Curve, 1 years)...50
Composite Outlet Structure - 2 (Individual Outlet Curves, 1 years)...44, 45, 46, 47, 48, 49
Composite Outlet Structure - 2 (Outlet Input Data, 1 years)...41, 42, 43

M

Master Network Summary...1, 2

P

PO-1 (Elevation-Area Volume Curve, 1 years)...31
PO-1 (Elevation-Volume-Flow Table (Pond), 1 years)...51
PO-1 (IN) (Level Pool Pond Routing Summary, 1 years)...52
PO-1 (IN) (Level Pool Pond Routing Summary, 10 years)...54
PO-1 (IN) (Level Pool Pond Routing Summary, 100 years)...55
PO-1 (IN) (Level Pool Pond Routing Summary, 2 years)...53
PO-1 (OUT) (Pond Routed Hydrograph (total out), 1 years)...56, 57
PO-1 (OUT) (Pond Routed Hydrograph (total out), 10 years)...60, 61
PO-1 (OUT) (Pond Routed Hydrograph (total out), 100 years)...62, 63
PO-1 (OUT) (Pond Routed Hydrograph (total out), 2 years)...58, 59

PO-2 (Elevation-Area Volume Curve, 1 years)...32

PO-2 (Elevation-Volume-Flow Table (Pond), 1 years)...64

PO-2 (IN) (Level Pool Pond Routing Summary, 1 years)...65

PO-2 (IN) (Level Pool Pond Routing Summary, 10 years)...67

PO-2 (IN) (Level Pool Pond Routing Summary, 100 years)...68

PO-2 (IN) (Level Pool Pond Routing Summary, 2 years)...66

PO-2 (OUT) (Pond Routed Hydrograph (total out), 1 years)...69, 70

PO-2 (OUT) (Pond Routed Hydrograph (total out), 10 years)...73, 74

PO-2 (OUT) (Pond Routed Hydrograph (total out), 100 years)...75, 76

PO-2 (OUT) (Pond Routed Hydrograph (total out), 2 years)...71, 72

T

Time-Depth - 1 (Time-Depth Curve, 1 years)...9, 10

Time-Depth - 1 (Time-Depth Curve, 10 years)...5, 6

Time-Depth - 1 (Time-Depth Curve, 100 years)...3, 4

Time-Depth - 1 (Time-Depth Curve, 2 years)...7, 8