



November 1, 2022

Lee's Summit Development Services
City Hall
220 SE Green Street
Lee's Summit, MO 64063

To Whom it May Concern:

The City approved Street & Storm Sewer Plans for Osage 1st Plat and City stamped on 07/08/2020 have been revised to remove a low point at an intersection. The following changes to the City approved plans are as follows:


Street & Storm Sewer Plans

Sheet C120

- After construction of the intersection, it was found that there was a low point in the SW quadrant of the intersection that pooled water.
- To remove the low point, the area hatched in gray will be removed and replaced to drain water away from the curb to the north, or towards the storm inlet to the west.
- The pavement section, sidewalk section, and curb type will remain the same as the approved plans.

Please review these changes to approved plans.

Sincerely,



Julie Sellers, P.E.
Olsson