

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Friday, December 02, 2022

To:

Property Owner: REORGANIZED SCHOOL DIST NO 7
Email:

Applicant: MULTISTUDIO
Email:

Engineer: KAW VALLEY ENGINEERING INC
Email: LX@KVENG.COM

From: Mike Weisenborn, Project Manager

Re:

Application Number: PL2022374

Application Type: Commercial Final Development Plan

Application Name: Lee's Summit North High School - Robotics Facility

Location: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	No Comments
------------------------	-----------------------------------	---	-------------

Engineering Review	Gene Williams, P.E. (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------------	---	--------------------------

1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)). These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$4,252.13

2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.

3. Review of the waiver is currently under review by the City Engineer. It is anticipated the waiver shall be approved. If not, it may be possible that detention shall be required or other measures for the new improvements. If this occurs, a revision to the Final Development Plan shall be required.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. IFC 506.1 - Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type listed in accordance with UL 1037, and shall contain keys to gain necessary access as required by the fire code official. 506.1.1 Locks. An approved lock shall be installed on gates or similar barriers when required by the fire code official.

A Knox padlock shall be provided on the gate if not already there.

Traffic Review	Brad Cooley, P.E., RSPI Brad.Cooley@cityofls.net	No Comments
-----------------------	---	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------

