

DEVELOPMENT SERVICES

**Minor Plat
Applicant's Letter**

Date: Thursday, December 29, 2022

To:

Property Owner: CITY OF LEES SUMMIT Email:

Property Owner: WAIS INC Email:

Applicant: CITY OF LEE'S SUMMIT Email:
MISSOURI

Engineer: J&J Survey LLC Email: cee@jandjsurvey.com

Architect: GLMV ARCHITECTURE Email: JHERNANDEZ@GLMV.COM

From: Mike Weisenborn, Project Manager

Re:

Application Number: PL2022360

Application Type: Minor Plat

Application Name: Executive Lakes Center Lots 6B and 7A

Location: 5051 NE LAKEWOOD WAY, LEES SUMMIT, MO 640645031 NE
LAKEWOOD WAY, LEES SUMMIT, MO 64064

Electronic Plans for Resubmittal

All Planning applicaiton and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in mulit-page Portable Document Format (PDF).

DEVELOPMENT SERVICES

- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Review Status:

Okay to submit the plat for City signatures. Please submit a minimum of three (3) mylars, five (5) paper copies, and one (1) digital copy following the electronic plan submittal guides as stated above. After recording the documents, return one (1) recorded mylar and one (1) recorded paper to the Development Services Department.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
------------------------	-----------------------------------	---	-------------

Engineering Review	Gene Williams, P.E. (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------------	---	-----------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final plat and approved prior to the approval of the final plat. All public infrastructure must be substantially complete, prior to the issuance of any building permits.

2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).

3. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.

DEVELOPMENT SERVICES

4. A Land Disturbance Permit shall be obtained from the City if groundbreaking will take place prior to the issuance of a site development permit, building permit, or prior to the approval of the Final Development Plan / Engineering Plans.

5. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	No Comments
-------------------	---------------------------------	--	-------------
