

DEVELOPMENT SERVICES

**Final Plat
Applicant's Letter**

Date: Thursday, January 19, 2023

To:

Property Owner: KELLEY PAUL L TRUSTEE

Email:

Applicant: Daniel Villanueva

Email: daniel.villanueva@entresdevelopment.com

Engineer: Doug Ubben

Email: dougubben@phelpsenengineering.com

City Staff: Scott Ready

Email: Scott.Ready@cityofls.net

From: Scott Ready, Project Manager

Re:

Application Number: PL2022321

Application Type: Final Plat

Application Name: Orchard Woods

Location: 1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

Tentative Schedule

Submit revised plans by N/A

Planning Commission Meeting: January 26, 2023 at 05:00 PM

City Council date will be set after all subdivision related public improvements have been completed and a Certificate of Final Acceptance has been issued. In lieu of completion of public improvements, an escrow secured with cash or an irrevocable letter of credit shall be deposited with the City to secure the completion of all public improvements prior to scheduling a City Council date.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Re-submittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns you may have.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at 816-969-1200.

Voluntary Residential Development Surcharge

In a combined effort with both the R-4 and the R-7 School Districts the City of Lee's Summit is working together to educate the development community on a new program, the "Lee's Summit Voluntary Residential Development Surcharge." This is a program which will help raise capital to build new schools for our community. Brochures are available at the front counter of both the Development Services Department. You can also find more information on the City of Lee's Summit web site at www.cityofls.net. (For more information please contact the Board of Education at 986-2400).

Planning Review	Hector Soto Jr. (816) 969-1238	Planning Division Manager Hector.Soto@cityofls.net	Approved with Conditions
------------------------	-----------------------------------	---	--------------------------

1. COMMON AREA TRACT. Provide a copy of the Declaration of Covenants, Conditions and Restrictions for review to ensure that the required language from UDO Section 4.290 governing common area ownership and maintenance responsibilities is included. Staff has a template of the required language that may be used for inclusion in the CC&Rs upon request from staff.

The uploaded response letter states that a copy of the CC&Rs has been uploaded for staff review. However, no such document has been uploaded. Please provide a copy of the CC&Rs per the previous comment.

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

1. A Master Drainage Plan (MDP) shall be submitted and approved in accordance with the City's Design and Construction Manual for all areas of the development, including all surrounding impacted areas, along with the engineering plans for the development. The MDP shall address drainage level of service issues on an individual lot basis.

2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).

3. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.
4. The As-graded Master Drainage Plan shall be submitted to and accepted by the City prior to the issuance of a Certificate of Substantial Completion and prior to the issuance of any building permits for the development.
5. A Land Disturbance Permit shall be obtained from the City if groundbreaking will take place prior to the issuance of a site development permit, building permit, or prior to the approval of the Final Development Plan / Engineering Plans.
6. All permanent off-site easements, in a form acceptable to the City, shall be executed and recorded with the Jackson County Recorder of Deeds prior to the issuance of a Certificate of Substantial Completion or approval of the final plat. A certified copy shall be submitted to the City for verification.
7. All ADA sidewalk ramps shall be constructed by the developer at the time the street is constructed.
8. All sidewalks adjacent to a common area tract, unplatted land or any land where no structure is intended to be built, and is required, shall be constructed by the developer at the time the street is constructed.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
Traffic Review	Brad Cooley, P.E., RSPI	Brad.Cooley@cityofls.net	No Comments
GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	No Comments