

Date: January 25, 2023

Re: Responses to City Comments – Offsite Waterline
Orchard Woods
PEI #211142

We have received your comments and have addressed each with the enclosed plans and comment responses in *red italics* below. Please let us know if you have any questions during your review.

Thank you,
Doug

Engineering Review - Corrections

1. General:
 - Please submit a set of plans signed/sealed by the engineer.
Response: Set signed and sealed.
 - Submit an Engineer's Estimate of Probable Construction Costs.
2. *Response: Estimate included*
3. Sheet 3: Please revise the proposed pipe size to 8" in Plan view.

Response: Revised

Traffic Review - No Comments