

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Friday, February 17, 2023

To:

Property Owner: CCRC OF LEES SUMMIT LLC Email:

Applicant: Jordan Anderson Email: jordan.anderson@scenic-dev.com

Engineer: Julie Sellers Email: jsellers@olsson.com

Architect: Tim Fisher Email: tjf@fisher-arch.com

City Staff: Scott Ready Email: Scott.Ready@cityofls.net

From: Scott Ready, Project Manager

Re:

Application Number: PL2022290

Application Type: Commercial Final Development Plan

Application Name: Raintree Village Senior Living-Phase 1

Location: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	Corrections
------------------------	-----------------------------------	---	-------------

1. Can the eastern sidewalk be connected to the public sidewalk adjacent to MO-150? This will provide a more direct pedestrian route to/from the front entrance and better promote a sense of walkability.
2. Please update the site plat to reflect the new two lot configuration.

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

1. A Land Disturbance Permit shall be obtained from the City if groundbreaking will take place prior to the issuance of a site development permit, building permit, or prior to the approval of the Final Development Plan / Engineering Plans.
2. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
3. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
4. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$xxx.xx
5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Brad Cooley, P.E., RSPi Brad.Cooley@cityofls.net	No Comments
-----------------------	---	-------------

Building Codes Review Joe Frogge
(816) 969-1241

Plans Examiner
Joe.Frogge@cityofls.net

No Comments
