

2023.03.07

Mike Weisenborn  
Project Manager, Development Center  
City of Lee's Summit, Missouri  
220 SE Green Street, Lee's Summit, MO 64063

Mike:

We are in receipt of the comments dated 2023.02.28. We have addressed the comments as follows:

**Engineering Review** – Contact Sue Pyles, 816.969.1245, Sue.Pyles@cityofls.net

1. The pavement design is a part of these FDP plans, so the waiver will be required prior to plan approval. An alternative to getting the waiver now would be to revise the plans to meet the City's pavement design requirements and then request a design waiver prior to placement of pavement.  
**Asphalt Pavement sections revised to include stabilized subgrade or geogrid**
2. Compacted fill is not shown where required. I'll provide a sketch where it seems that it would be required. Please hatch all areas requiring compacted fill for clarity.  
**Storm profiles revised to include compacted fill per provided sketch**
3. Please submit a copy of the issued MDNR Land Disturbance Permit.  
**MDNR Land Disturbance Permit included with submittal**
4. Provide a stamped and signed plan set  
**Plan stamped and signed for resubmittal**