

DEVELOPMENT SERVICES

Commercial Final Development Plan Applicant's Letter

Date:	Thursday, March 16, 2023					
То:	City Staff: Scott F	Ready	Email: Scott.Ready@cityofls.net			
	Engineer: Dan Finn		Email: dfinn@phelpsengineering.com			
	Architect: POWELL MINNIS		Email:			
	Applicant: Lee's	Summit Retail Partners, LLC	Email: dcarr@usfpco.com			
	Scott Ready, Project Manager					
Re: Application Number:		PL2022391				
Application Type:		Commercial Final Development Plan				
Application Name:		Market Street Center Lot 2 - Westlake Ace Hardware				
Location:		3511 SW MARKET ST, LEES SUMMIT, MO 64082				

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats All plats shall be provided in mulit-page Portable Document Format (PDF).
- Engineered Civil Plans All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost,

as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Corrections

1. Sheet C3:

• Specify fire line material.

• Locate the water meter as required by Design and Construction Manual Section 6901.L.1, which in this case is in the R/W within 1' of the R/W line.

• Design and Construction Manual Section 6901.1.3 requires buildings located more than 50' from the public water main to include a BFPD located in a buried vault located within 5' of the R/W on the private side. Please revise the plans accordingly, and include the sump drainage as previously requested. Please update the estimate as needed.

Fire Review	Jim Eden	Assistant Chief	Approved with Conditions
	(816) 969-1303	Jim.Eden@cityofls.net	

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. IFC 105.6.20 - A Hazardous materials permit is required for the using, dispensing, transporting, handling, and/or storing of extremely hazardous substances. "Extremely Hazardous Substances (EHS) Facilities" are defined as facilities subject to the provisions of Superfund Amendments and Reauthorization Act of 1986 (SARA TITLE III), Section 302, for storing, dispensing, using, or handling of listed chemicals in excess of their threshold planning quantities (TPQ). See amended Section 5001.4 of the 2018 International Fire Code.

A Haz Mat permit is also required for propane (LPG) filling and exchange. Complete a Hazardous Materials Permit application. Include quantites and specifications for the filling operation and employee training.

Traffic Review	Brad Cooley, P.E., RSPI		No Comments
		Brad.Cooley@cityofls.net	
Building Codes Review	Joe Frogge	Plans Examiner	No Comments
	(816) 969-1241	Joe.Frogge@cityofls.net	
	00	Joe.Frogge@cityofls.net	