

---

**DEVELOPMENT SERVICES**

---

**Date:** Tuesday, April 17, 2023

**To:** SCHLAGEL & ASSOCIATES  
14920 W 107TH ST  
LENEXA, KS 66215

**From:** Gene Williams, P.E.  
Senior Staff Engineer

**Application Number:** PL2022415

**Application Type:** Engineering Plan Review

**Application Name:** Residences at Blackwell - Public Water

---

The Development Services Department has completed its review of the above-referenced plans dated Mar. 29, 2023 and offer the following comments listed below.

- See comments below to determine the required revisions and resubmit to the Development Services Department public portal located at [devservices.cityofls.net](https://devservices.cityofls.net). Digital documents shall follow the electronic plan submittal guides as stated below.
- Revised plans will be reviewed within ten (10) business days of the date received.

**Engineering Review - Corrections**

1. There are discrepancies in the location and sizing of the existing main along Blue Pkwy. I have attached a separate sheet showing the location of where we are showing the as-built location of the existing 16 inch main (i.e., not a 12 inch main as shown on the plans). Please revise the plans as appropriate.
2. I have attached a separate markup showing how the connection to the new 12 inch water main should be made in relation to the existing 16 inch main. Please see the separate attachment and adjust and revise as appropriate.

**Traffic Review - Not Required**

In order to calculate the Engineering Plan Review and Inspection Fee, a sealed Engineer's Opinion of Probable Construction Costs shall accompany your final submittal copies. The itemized estimate (material and installation) shall be sufficiently broken down and shall include the following items, as applicable.

- Public infrastructure, both onsite and offsite.
- Private street construction, including parking lots and driveways.
- Sidewalks located within the right-of-way.
- ADA accessible ramps.
- Sanitary sewer manholes and piping between manholes, including private mains.
- Connection of the building sanitary sewer stub to the public main.
- Waterlines larger than 2 inches in diameter, valves, hydrants, and backflow preventer with vault, if outside the building.

- Stormwater piping greater than 6 inches in diameter, structures, and detention / retention facilities - public or private.
- Water quality features installed to meet the 40-hour extended duration detention requirements.
- Grading for detention / retention ponds.
- Grading to establish proper site drainage.
- Utility infrastructure adjustments to finished grade (i.e. manhole lids, water valves, etc.).
- Erosion and sediment control devices required for construction.
- Re-vegetation and other post-construction erosion and sediment control activities.

### **Electronic Plans for Resubmittal**

---

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact me if you have any questions or comments.

Sincerely,

/s/ electronically signed Apr. 17, 2023

Gene Williams, P.E.  
Senior Staff Engineer  
(816) 969-1223  
Gene.Williams@cityofls.net

cc: Development Engineering Project File