

**DEVELOPMENT SERVICES**

**Commercial Final Development Plan  
Applicant's Letter**

**Date:** Wednesday, April 26, 2023

**To:**

**Property Owner:** HFI 463 WARD LLC

**Email:**

**Engineer:** MS CONSULTANTS INC

**Email:** KAKERS@MSCONSULTANTS.COM

**Applicant:** WHATABURGER

**Email:** GABNER@WBHQ.COM

**From:** Dawn Bell, Project Manager

**Re:**

**Application Number:** PL2022258

**Application Type:** Commercial Final Development Plan

**Application Name:** WHATABURGER M150

**Location:** 204 SW M 150 HWY, LEES SUMMIT, MO 64082

---

**Electronic Plans for Resubmittal**

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

**Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

**Review Status:****Required Corrections:**

<b>Planning Review</b>	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	Corrections
------------------------	-----------------------------------	---	-------------

---

1. Please break up the flat roof line on the south façade by increasing the height of the brick parapet wall to above the corrugated metal parapet wall.

<b>Engineering Review</b>	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

---

1. The applicant shall submit and the City shall accept an "As-built / As-graded" detention basin plan prior to issuance of any occupancy permit for the proposed development.
2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
3. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), water tap and meter setup fee, and sanitary sewer development fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$71,427.02.
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

<b>Fire Review</b>	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

---

<b>Traffic Review</b>	Brad Cooley, P.E., RSPi Brad.Cooley@cityofls.net	No Comments
-----------------------	---	-------------

---

<b>Building Codes Review</b>	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions
------------------------------	------------------------------	---	--------------------------

---

1. Light pole base detail required prior to inspections.

Action required: Comment is informational. Seed comments to building permit submission.