



June 29, 2023

City of Lee's Summit, Missouri

Attn: Susan Nelson
220 SE Green Street
Lee's Summit, MO 64063

Re: PL2023109 – Midwest Carwash – Public Water Main Extension

To whom it may concern:

The following are responses to your comments made on June 28, 2023, on the project referenced above.

Engineering Review

1. WM3.00

It appears that there is 3.5 to 4 feet of cover over the proposed water main. Water Utilities direction indicates providing 3 feet of cover over the water main with about a foot of separation to the storm sewer crossing. With less than 18 inches of separation, all water main joints within 10 feet of the outside of the storm pipe need to be restrained.

RESPONSE: Acknowledged. Profile has been adjusted. Notes can be found on sheet WM3.00 in regards to the restrained joint requirement.

2. Please include the public sanitary sewer main extension plans within the public water main plan set.

RESPONSE: Acknowledged. Items/sheets for the sanitary sewer main have been added to the planset.

Thank you,

Luke Moore/ Seth Reece
Olsson