

**DEVELOPMENT SERVICES**

**Commercial Final Development Plan  
Applicant's Letter**

**Date:** Friday, July 14, 2023

**To:**

**Property Owner:** HD DEVELOPMENT OF  
MARYLAND INC

**Email:**

**Applicant:** ENGINEERING SOLUTIONS

**Email:** MSCHLICHT@ES-KC.COM

**Engineer/Surveyor:** ENGINEERING SOLUTIONS

**Email:** MSCHLICHT@ES-KC.COM

**From:** Mike Weisenborn, Project Manager

**Re:**

**Application Number:** PL2022386

**Application Type:** Commercial Final Development Plan

**Application Name:** LP Mart

**Location:** 601 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

**Electronic Plans for Resubmittal**

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

**Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

---

**Review Status:**

Revisions Required: One or more departments have unresolved issues regarding this development application. See

comments below to determine the required revisions and resubmit to the Development Services Department. Resubmit one (1) digital copy following the electronic plan submittal guides as stated above. Revised plans will be reviewed within five (5) business days of the date received.

### **Required Corrections:**

<b>Planning Review</b>	Hector Soto Jr. (816) 969-1238	Senior Planner Hector.Soto@cityofls.net	Corrections
------------------------	-----------------------------------	--	-------------

---

1. LIGHTING. Submit a revised photometric plan that replaces the description of fixture WP3 in the luminaire schedule from the originally proposed "TMWP-LED-04L-40-11 MTG" with the updated fixture "XWS SIL".

<b>Engineering Review</b>	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	---	--------------------------

---

1. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
2. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), the water tap and meter setup fee, and the sanitary sewer development fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$30,176.95
3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

<b>Fire Review</b>	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

---

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.
2. IFC 105.6.20 - A Hazardous materials permit is required for the using, dispensing, transporting, handling, and/or storing of extremely hazardous substances. "Extremely Hazardous Substances (EHS) Facilities" are defined as facilities subject to the provisions of Superfund Amendments and Reauthorization Act of 1986 (SARA TITLE III), Section 302, for storing, dispensing, using, or handling of listed chemicals in excess of their threshold planning quantities (TPQ). See amended Section 5001.4 of the 2018 International Fire Code.

A Hazardous Materials Permit is required for 75,000-gallons or greater of gasoline and 100,000-gallons of diesel. Will you have all gasoline, or a mix of gasoline and diesel?

<b>Traffic Review</b>	Erin Ralovo Erin.Ravolo@cityofls.net	No Comments
-----------------------	---	-------------

---

**Building Codes Review** Joe Frogge  
(816) 969-1241

Plans Examiner  
Joe.Frogge@cityofls.net

No Comments

---