# City of Lee's Summit

### Department of Planning & Development

Phone (816) 969-1600 Fax (816) 969-1619

## Commercial Final Development Plan Review

Date: Thursday, June 30, 2011

To:

SAINT LUKES EAST Email: acrise@saint-lukes.org Fax #: (816) 932-5731

HOSPITAL

ACLBOLAND Email: Fax #: <NO FAX NUMBER>

mhunter@aci-boland.com

SHAFER KLINE & WARREN Email: eblen@skw-inc.com Fax #: <NO FAX NUMBER>

From: Hector Soto, Planner

Re:

**Application Number:** PL2011074

**Application Summary:** Commercial Final Development Plan

"SAINT LUKE'S EAST ER ADDITION #2"

**Location:** 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

#### **Excise Tax**

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Permitting and Plan Review Division of the Codes Administration Department at 816-969-1200.

Revisions Required: One or more departments have unresolved issues. See comments below to determine the corrections needed. Submit seven (7) copies of revised drawings, folded individually (or in sets) to 8-1/2" x 11" to Planning & Development. Revised plans will be reviewed within 5 business days of resubmittal.

#### **Required Corrections:**

Planning Review Hector Soto Planner (816	3) 969-1604 Corrections
--	-------------------------

1. UTILITY EASEMENTS. The proposed expansion is shown to be built over two overlapping 10' wide utility easements. No structures are allowed to encroach into any utility easements.

<b>Engineering Review</b>	Gene Williams	Senior Staff	(816) 969-1812	Corrections
		Engineer		

<sup>1.</sup> Building footprint appears to be encroaching upon a utility easement as evident from the plat. Buildings and permanent structures cannot encroach upon utility easements.

- 2. Sheet C5.0 shows a detail of the sanitary sewer connection using vitrified clay pipe which is no longer allowed in the City of Lee's Summit.
- 4. A sealed Engineer's Opinion of Probable Construction Costs should accompany your final submittal copies. Public Works' review and inspection fee is based on that cost. The following items, both materials and installation, should be included in the itemized estimate
- Any water line larger than 2" in diameter, valves, hydrants, and backflow preventer with vault, if outside the building
- All storm water piping 6" or larger, structures, and detention/retention facilities
- All grading for detention/retention ponds
- All sanitary sewer manholes and piping between manholes, including private mains
- The connection of the building sewer stub to the public main
- All public infrastructure, both onsite and offsite
- All private street construction, excluding parking lots, drive approaches and sidewalks
- All erosion control devices

Fire Review	Jim Eden	Assistant Chief (816) 969-1303	Complete
			_

1. Fire Department-All building and life safety issues shall comply with the 2006 International Fire Code and local amendments as adopted by the City of Lee's Summit.

Traffic Review	Michael Park	City Traffic	(816) 969-1820	No Comments
		Engineer		