



Woodland Oaks
August 18, 2023
Woodland Oaks – Street and Storm
Lee's Summit, MO

Project: Woodland Oaks 1st Plat
Application Number: PL2021073
Application Type: Engineering Plan Review

Engineering Review

1. Revised ADA ramp per city markup.
2. Cross slope of street is a different angle to so when it runs through ramp the slope is the same.

Please forward all comments or concerns to Matthew Schlicht.