



LEE'S SUMMIT MISSOURI

DESIGN & CONSTRUCTION MANUAL DESIGN CRITERIA MODIFICATION REQUEST

PROJECT NAME: **The Village at Discovery Park Zone 1 – Public Sanitary Sewer Plans**

ADDRESS: **NW Colbern Rd & NE Douglas St, Lee's Summit, MO**

PERMIT NUMBER: **PL2023145 (Project #)**

OWNER'S NAME: **Jon Odle, Intrinsic Development**

TO: Deputy Director of Public Works / City Engineer

In accordance with the City of Lee's Summit's Design and Construction Manual (DCM), I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the DCM is observed and the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: Cite specific code sections, justification and all appropriate supporting documents.)

A modification to Section 6501.E.3.a is requested to allow an increase of maximum depth of sanitary sewers and manholes from 20 ft to 25 ft. Modification will apply to EX. SANITARY LINE Z (existing 12" sewer main that's partially relocated) shown on sheets C653-C655 of referenced plans.

The sewer main in question will be running along the top of embankment of proposed wet permanent detention basin. The basin geometry and grading are dictated by storm water detention and water quality requirements. Also, since the sewer main is existing, it's flow invert elevations are fixed at upstream and downstream points. Although all the efforts were made to keep the relocated and existing sewer main as shallow as possible, the basin grading and fixed flow invert elevations of the sewer lead to a need in design modification request.

SUBMITTED BY:

NAME: **David Eickman**

ADDRESS: **1301 Burlington Street**

CITY, STATE, ZIP: **North Kansas City, MO 64116**

Email: deickman@olsson.com

() OWNER (X) OWNER'S AGENT

PHONE #: **816.361.1177**

SIGNATURE: _____

SUE PYLES, P.E.

DEVELOPMENT ENGINEERING MANAGER

SIGNATURE: _____

() APPROVAL

() DENIAL

DATE: _____

JEFF THORN, P.E.

DEPUTY DIRECTOR OF WATER UTILITIES

SIGNATURE: _____

() APPROVED

() DENIAL

DATE: _____

GEORGE M. BINGER III, P.E.

DEPUTY DIRECTOR OF PUBLIC WORKS / CITY ENGINEER

SIGNATURE: _____

() APPROVED

() DENIAL

DATE: _____

COMMENTS: _____

