

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Thursday, November 02, 2023

To:

Property Owner: 150 HIGHWAY LEES SUMMIT LLC Email:

Applicant: Casey's Marketing Company Email: shannon.gerard@caseys.com

Engineer/Surveyor: SBB Engineering, LLC Email: jeff.laubach@sbbeng.com

From: Scott Ready, Project Manager

Re:

Application Number: PL2023181

Application Type: Commercial Final Development Plan

Application Name: Casey's General Store

Location: 1620 SW M 150 HWY, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:**Required Corrections:**

| | | | |
|------------------------|-----------------------------------|--|-------------|
| Planning Review | Shannon McGuire (816) 969-1237 | Senior Planner Shannon.McGuire@cityofls.net | No Comments |
|------------------------|-----------------------------------|--|-------------|

| | | | |
|---------------------------|-----------------------------------|---|--------------------------|
| Engineering Review | Sue Pyles, P.E. (816) 969-1245 | Development Engineering Manager Sue.Pyles@cityofls.net | Approved with Conditions |
|---------------------------|-----------------------------------|---|--------------------------|

1. A Land Disturbance Permit shall be obtained from the City if groundbreaking will take place prior to the issuance of a site development permit, building permit, or prior to the approval of the Final Development Plan / Engineering Plans.
2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
3. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$56,333.32
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

| | | | |
|--------------------|----------------------------|--|--------------------------|
| Fire Review | Jim Eden (816) 969-1303 | Assistant Chief Jim.Eden@cityofls.net | Approved with Conditions |
|--------------------|----------------------------|--|--------------------------|

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.
2. IFC 105.6.20 - A Hazardous materials permit is required for the using, dispensing, transporting, handling, and/or storing of extremely hazardous substances. "Extremely Hazardous Substances (EHS) Facilities" are defined as facilities subject to the provisions of Superfund Amendments and Reauthorization Act of 1986 (SARA TITLE III), Section 302, for storing, dispensing, using, or handling of listed chemicals in excess of their threshold planning quantities (TPQ). See amended Section 5001.4 of the 2018 International Fire Code.

A Hazardous Materials Permit may be required depending on total quantity of fuel to be stored.

| | | | |
|-----------------------|-------------|--------------------------|-------------|
| Traffic Review | Erin Ralovo | Erin.Ravolo@cityofls.net | No Comments |
|-----------------------|-------------|--------------------------|-------------|

| | | | |
|------------------------------|------------------------------|---|--------------------------|
| Building Codes Review | Joe Frogge (816) 969-1241 | Plans Examiner Joe.Frogge@cityofls.net | Approved with Conditions |
|------------------------------|------------------------------|---|--------------------------|

2. Architectural plans not part of this review.

Action required: comment is informational.