

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Friday, November 10, 2023

To:

Engineer/Surveyor: Kevin Sterrett

Email: ksterrett@hgcons.com

Architect: GUY GRONBERG ARCHITECTS

Email:

Applicant: Matt Hendrickson

Email: matthewf.hendrickson@gmail.com

From: Scott Ready, Project Manager

Re:

Application Number: PL2023210

Application Type: Commercial Final Development Plan

Application Name: Douglas Corner, Lot 1C - Retail Building

Location: 150 NE TUDOR RD, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:**Required Corrections:**

Planning Review	Shannon McGuire (816) 969-1237	Senior Planner Shannon.McGuire@cityofls.net	No Comments
------------------------	-----------------------------------	--	-------------

Engineering Review	Susan Nelson, P.E. (816) 969-1229	Senior Staff Engineer Susan.Nelson@cityofls.net	Corrections
---------------------------	--------------------------------------	--	-------------

1. Domestic services shall be connected with corporation stops for 2-inch and smaller service lines and with a cut-in tee and appropriate valving for larger sizes. Use of a tapping sleeve is not permitted.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Erin Ralovo	Erin.Ravolo@cityofls.net	No Comments
-----------------------	-------------	--------------------------	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
