4	ID	Base Demand (gpm)	Base Pressure (psi)	Fire Demand (gpm)	Combined Demand (gpm)	Residual Pressure (psi)
1	J1032	0.00	116.10	0.00	0.00	93.72
2	6112	0.00	91.45	0.00	0.00	68.37
3	6113	156.23	103.10	1,326.00	1,482.23	79.14
4	6128	315.17	91.43	2,674.00	2,989.17	66.80
5	6109	0.00	91.43	0.00	0.00	67.12



		ID	Base Demand (gpm)	Base Pressure (psi)	Fire Demand (gpm)	Combined Demand (gpm)	Residual Pressure (psi)
		J1032	0.00	92.12	0.00	0.00	92.12
2	2 [	6112	0.00	67.66	0.00	0.00	67.66
;	3	6113	380.48	79.11	0.00	380.48	79.11
4	1	6128	562.33	67.59	0.00	562.33	67.59
	5	6109	0.00	67.61	0.00	0.00	67.61

Water Dema	nd supplied by	the proposed 12-inch	water main			
Water Berrie		Proposed 12 mon	- Water man			
368.7	gpm Max Day Demand for 724 apartments					
		Demand for 40,000 so		taurant space		
	· .					
	gpm Max Day Demand for 13,500 square feet of fitness space gpm Max Day Demand for 28,000 square feet of office / retail space				<u> </u>	
	gpm Max Day Demand for 219 hotel rooms					
	Total Max Day Demand					
	2.8 Total Peak Hour Demand					
Fire Flow Re	auirements					
	4,000.0 gpm Maximum fire flow required for a building with a sprinkler system					
,		fire flow require	ments			
		.,,,				
Divide Max [	Day Demand and	d Fire Flow between	the following tv	vo nodes:		
Node 1268						
Node 6113	1,482.0	,326 gpm)				
	,	,	<u> </u>			
Divide Peak	Divide Peak Hour Demand between the following two nodes:					
Node 1268	562.33					
Node 6113	380.48					

