



February 29, 2024

Gene Williams, PE
City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

**RE: PL2021433 – MANOR AT BAILEY FARM 1ST PLAT
Street, Stormwater, and Master Drainage Plan –
Revisions to Previously approved Plans**

Dear Gene:

The previously approved plans have been revised for:

1. Sheet 31 – Storm Line 100 - Change the material type between Inlets 102 and 109 from RCP to HDPE. Pipe sizes will remain the same.
2. Sheet 31 – Storm Line 1000 – Change Inlets 1009 and 1014 from 6'x4' Curb Inlets to 6'x4' Junction Boxes.
3. Sheet 27 – Updated drainage table due to Inlets 1009 and 1014 to junction boxes.
4. Sheet 28 – Updated Gutter Spread and Inlet Capacity table due to Inlets 1009 and 1014 becoming junction boxes.

If you need any additional information, please let me know.

Sincerely,

SCHLAGEL & ASSOCIATES, PA

A handwritten signature in blue ink, appearing to read 'Jim Long', with a stylized flourish at the end.

Jim Long, PE
Sr. Project Engineer
Direct 913-322-7146
JL@schlagelassociates.com

/mr
Enclosures