SITE DEVELOPMENT PLANS FOR SUMMIT FAIR, LOT 10C ADDRESS: 700 N.W. WARD ROAD IN THE CITY OF LEE'S SUMMIT, JACKSON COUNTY, MISSOURI

FLOOD NOTE:

THIS PROPERTY LIES WITHIN ZONE X, DEFINED AS AREAS DETERMINED TO BE OUTSIDE THE 0.2% ANNUAL CHANCE FLOODPLAIN, AS SHOWN ON THE FLOOD INSURANCE RATE MAP PREPARED BY THE FEDERAL EMERGENCY MANAGEMENT AGENCY FOR THE CITY OF LEE'S SUMMIT, COMMUNITY NO. 290174, JACKSON COUNTY, MISSOURI, MAP NO. 29095C0417G, AND DATEL JANUARY 20, 2017.

FIRE ACCESS ROAD NOTE: ALL FIRE ACCESS LANES SHALL BE HEAVY DUTY ASPHALT CAPABLE OF SUPPORTING 75,000-POUNDS.

OIL-GAS WELLS:

ACCORDING TO THE MISSOURI DEPARTMENT OF NATURAL RESOURCES STATE OIL & GAS COUNCIL WELLS, LOCATED AT www.dnr.mo.gov/geology/geosrv/oilandgas.htm, THERE ARE NO OIL OR GAS WELLS ON THE PROPERTY SHOWN HFRFON.

PRE-CONSTRUCTION MEETING NOTE:

THE CONTRACTOR SHALL CONTACT THE CITY'S DEVELOPMENT SERVICES ENGINEERING INSPECTION TO SCHEDULE A PRE-CONSTRUCTION MEETING WITH A FIELD ENGINEERING INSPECTOR PRIOR TO ANY LAND DISTURBANCE WORK AT (816) 969-1200.

UTILITY COMPANIES:

MISSOURI GAS ENERGY LUCAS WALLS (LUCAS.WALLS@SUG.COM) 3025 SOUTHEAST CLOVER DRIVE LEE'S SUMMIT, MO 64082	(816) 969–2218
EVERGY PHILLIP INGRAM (PHILLIP.INGRAM@KCPL.COM)	(816) 347–4339
RON DEJARNETTE (RON.DEJARNETTE@KCPL.COM) 1300 HAMBLEN ROAD LEE'S SUMMIT, MO 64081	(816) 347-4316
STORM SEWER (PUBLIC WORKS DEPARTMENT) 220 SE GREEN STREET LEE'S SUMMIT, MO 64063	(816) 969–1800
SANITARY SEWER & WATER (WATER UTILITIES DEPT.) 1200 SE HAMBLEM ROAD, LEE'S SUMMIT, MO 64081	(816)-969-1900
AT&T (913) 383–4929 MR. CLAYTON ANSPAUGH (CA4089@ATT.COM) 9444 NALL AVENUE OVERLAND PARK, KANSAS 66207	(913) 383-4849-FAX





Call before you dig.

UTILITY NOTES: VISUAL INDICATIONS OF UTILITIES ARE AS SHOWN. UNDERGROUND LOCATIONS SHOWN, AS FURNISHED BY THEIR LESSORS, ARE APPROXIMATE AND SHOULD BE VERIFIED IN THE FIELD AT THE TIME OF CONSTRUCTION. FOR ACTUAL FIELD LOCATIONS OF UNDERGROUND UTILITIES CALL 811.

C0 C0.1 C1 C1.1 C2 C2.1 C3 C4 C5 C6-C6.1 C7-C7.1	INDEX COVER SHEET DEMOLITION PLAN OVERALL SITE PLAN ENLARGED SITE PLAN OVERALL GRADING PLAN ENLARGED GRADING PLAN UTILITY PLAN DRAINAGE MAP STORM SEWER PLAN & PROFILE EROSION CONTROL PLAN & DETAILS STANDARD DETAILS	PHELPS ENGINEERING, INC. PLANNING PLANCARGA PLANNING PLANCARGA PLAN
JACKSON COUNTY,	CRIPTION: AIR, LOTS 10A – 10C, A SUBDIVISION IN THE CITY OF LEE'S SUMMIT, MISSOURI, ACCORDING TO THE RECORDED PLAT THEREOF. 11 ACRES / ±121,582 SQ.FT.	
PREPARED PHELPS ENGINEE 1270 N. WINCHE OLATHE, KS 660 913-393-1155 913-393-1166	STER)61 OFFICE FAX	10-C OAD

<u>LEGAL</u>


PREPA

PHELPS 1270 N. OLATHE, 913-393-913-393-CONTACT: JUDD CLAUSSEN, P.E.

DEVELOPER:

WSO PARTNERS, LLC C/O FORESIGHT REAL ESTATE SERVICES, LLC PÓ BOX 299 LIBERTY, MO 64069 816-918-1612 CONTACT: JOHN R. DAVIS, JR.

NW1/4	NE1/4	
SW1/4	SE1/4 DYDA DYDA DYDA DYDA DYDA DYDA DYDA DYD	
NW CHIPMAN ROAD		
VICINITY MAP SEC. 36-48-32		






SHEE OVER Ŭ $\overline{\mathcal{O}}$

SHEET





NW1/4 SW1/4

> NW CHIPMAN ROAD VICINITY MAP SEC. 36-48-32

DEMOLITION NOTES:

1. THE CONTRACTOR IS RESPONSIBLE FOR THE APPROVED BY ALL GOVERNING AUTHORITIES) AL UTILITIES, ETC., SUCH THAT THE IMPROVEMENT CONSTRUCTED. ALL FACILITIES TO BE REMOVED TO GRADE WITH SUITABLE COMPACTED FILL MAT

FOR DEMOLITION AND DISPOSAL.

3. DAMAGE TO ALL EXISTING CONDITIONS TO REMAIN WILL BE REPLACED AT CONTRACTOR'S EXPENSE. 4. CONTRACTOR MUST COORDINATE WITH OWNER PRIOR TO ANY CONSTRUCTION TO ESTABLISH CUSTOMER ACCESS AND TRAFFIC FLOW DURING ALL PHASES.

NE1/4

SE1/4

DEMOLITION KEY NOTES:

- ALL UTILITIES SERVING STRUCTURES IMMEDIATELY SURROUNDING THE DEMOLITION BOUNDARY SHALL REMAIN IN SERVICE THROUGHOUT THE PROJECT. THE CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO PREVENT ANY DAMAGE TO SUCH UTILITIES. TYPICAL LOCATION.
- B EXISTING CONCRETE MANHOLE W/ 4" STEEL PIPES EXITING TO SOUTH AND EAST. OWNER UNKNOWN. EXISTING GARDEN HOSE LOCATED WITHIN STRUCTURE AND ROUTED THROUGH 4" STEEL PIPE TO SOUTH. CONTRACTOR TO REMOVE EXISTING MANHOLE AND STEEL PIPES TO PROPERTY LINE. CONTRACTOR TO CAP EXISTING STEEP PIPES AT PROPERTY LINE.

HE DEMOLITION, REMOVAL, AND DISPOSAL (IN A LOCATION
LL CURBS, PARKING, DRIVES, DRAINAGE STRUCTURES,
TS SHOWN ON THE REMAINING PLANS CAN BE
) SHALL BE UNDERCUT TO SUITABLE MATERIAL AND BROUGHT
ITERIAL.


N

SCALE:

1"=2000'

2. THE CONTRACTOR IS RESPONSIBLE FOR REMOVING ALL DEBRIS FROM THE SITE AND DISPOSING THE DEBRIS IN A LAWFUL MANNER. THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING ALL PERMITS REQUIRED

- - R/W - - RIGHT - OF - WAYREMOVE EXISTING CURB & GUTTER EXISTING BUILDING TO BE REMOVED EXISTING ASPHALT PAVEMENT TO BE REMOVED EXISTING CONCRETE PAVEMENT/SIDEWALK TO BE REMOVED EXISTING GRAVEL TO BE REMOVED EXISTING TREE TO REMAIN REMOVE TREE EXISTING BURIED TELEPHONE ------ EXISTING FIBER OPTIC LINE _____w____ EXISTING WATER LINE EXISTING GAS LINE _____ G _____ EXISTING BURIED ELECTRIC ------BE------------ EXISTING OVERHEAD POWER LINE ------ ss ------ EXISTING SANITARY SEWER _____ EXISTING STORM SEWER EXISTING FIRE HYDRANT EXISTING LIGHT POLE



60'



 $\overline{\mathbf{A}}$

— — LL — — LOT LINE

<u>LEGEND</u>

Mr

Q

LP ------



NW1/4	NE1/4	
SW1/4	DYDA DYDA DYN DYDA DYN MN	
NW CHIPMAN ROAD		
VICINITY MAP SEC. 36-48-32		

LEGAL DESCRIPTION:

LOT 10C, SUMMIT FAIR, LOTS 10A - 10C, A SUBDIVISION IN THE CITY OF LEE'S SUMMIT, JACKSON COUNTY, MISSOURI, ACCORDING TO THE RECORDED PLAT THEREOF.

 $AREA = \pm 2.7911 ACRES / \pm 121,580 SQ.FT.$

SITE PLAN NOTES:

1. All construction materials and procedures on this project shall conform to the latest revision of the following governing requirements, incorporated herein by reference: A) City ordinances & O.S.H.A. Regulations.

B) The City of Lee's Summit Technical Specifications and Municipal Code.

2. The contractor shall have one (1) signed copy of the plans (approved by the City) and one (1) copy of the appropriate Design and Construction Standards and Specifications at the job site at all times.

3. The contractor will be responsible for securing all permits, bonds and insurance required by the contract documents, City of Lee's Summit, Missouri, and all other governing agencies (including local, county, state and federal authorities) having jurisdiction over the work proposed by these construction documents. The cost for all permits, bonds and insurance shall be the contractors responsibility and shall be included in the bid for the work.

4. The contractor is responsible for coordination of his and his sub-contractor's work. The contractor shall assume all responsibility for protecting and maintaining his work during the construction period and between the various trades/sub-contractors constructing the work.

5. The demolition and removal(or relocation) of existing pavement, curbs, structures, utilities, and all other features necessary to construct the proposed improvements, shall be performed by the contractor. All waste material removed during construction shall be disposed off the project site. The contractor shall be responsible for all permits for hauling and disposing of waste material. The disposal of waste material shall be in accordance with all local, state and federal regulations.

6. Contractor shall be responsible for all relocations, including but not limited to, all utilities, storm drainage, sanitary sewer services, signs, traffic signals & poles, etc. as required. All work shall be in accordance with governing authorities specifications and shall be approved by such. All cost shall be included in base bid.

7. All existing utilities indicated on the drawings are according to the best information available to the Engineer; however, all utilities actually existing may not be shown. The contractor shall be responsible for contacting all utility companies for an exact field location of each utility prior to any construction. All underground utilities shall be protected at the contractor's expense. All utilities, shown and unshown, damaged through the negligence of the contractor shall be repaired or replaced by the contractor at his expense.

8. The contractor will be responsible for all damage to existing utilities, pavement, fences, structures and other features not designated for removal. The contractor shall repair all damages at his expense.

9. The contractor shall verify the flow lines of all existing storm or sanitary sewer connections and utility crossings prior to the start of construction. Notify the engineer of any discrepancies.

10. <u>SAFETY NOTICE TO CONTRACTOR</u>: In accordance with generally accepted construction practices, the contractor shall be solely and completely responsible for conditions of the job site, including safety of all persons and property during performance of the work. This requirement will apply continuously and not be limited to normal working hours. Any construction observation by the engineer of the contractor's performance is not intended to include review of the adequacy of the contractor's safety measures, in, on or near the construction site.

11. Refer to the building plans for site lighting electrical requirements, including conduits, pole bases, pull boxes, etc.

SITE DIMENSION NOTES:

1. BUILDING TIES SHOWN ARE TO THE OUTSIDE FACE OF PROPOSED WALLS. THE SUBCONTRACTOR SHALL REFER TO THE ARCHITECTURAL PLANS FOR SPECIFIC DIMENSIONS AND LAYOUT INFORMATION FOR THE BUILDINGS. 2. ALL DIMENSIONS SHOWN FOR THE PARKING LOT AND CURBS ARE MEASURED FORM BACK OF CURB TO BACK OF CURB.

PAVEMENT MARKING AND SIGNAGE NOTES:

1. PARKING STALL MARKING STRIPES SHALL BE FOUR INCH (4") WIDE WHITE STRIPES. DIRECTIONAL ARROW AND HANDICAP STALL MARKINGS SHALL BE FURNISHED AT LOCATIONS SHOWN ON PLANS.

2. HANDICAP PAVEMENT MARKINGS AND SIGNS SHALL CONFORM TO ALL FEDERAL (AMERICANS WITH DISABILITIES ACT) AND STATE LAWS AND REGULATIONS.

3. TRAFFIC CONTROL DEVICES AND PAVEMENT MARKINGS SHALL CONFORM TO THE REQUIREMENTS OF THE "MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES".

4. STOP SIGNS SHALL BE PROVIDED AT ALL LOCATIONS AS SHOWN ON PLANS AND SHALL CONFORM TO THE "MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES". SIGNS SHALL BE 18" X 12", 18 GAUGE STEEL AND SHALL BE ENGINEER GRADE REFLECTIVE.

5. TRAFFIC CONTROL AND PAVEMENT MARKINGS SHALL BE PAINTED WITH A WHITE SHERWIN WILLIAMS S-W TRAFFIC MARKING SERIES B-29Y2 OR APPROVED EQUAL. THE PAVEMENT MARKING SHALL BE APPLIED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS. APPLY ON A CLEAN, DRY SURFACE AND AT A SURFACE TEMPERATURE OF NOT LESS THAN 70°F AND THE AMBIENT AIR TEMPERATURE SHALL NOT BE LESS THAN 60°F AND RISING. TWO COATS SHALL BE APPLIED.

ZONING:

THIS PROPERTY IS ZONED PMIX, DEFINED AS PLANNED MIXED USE.

OIL-GAS WELLS:

ACCORDING TO THE MISSOURI DEPARTMENT OF NATURAL RESOURCES STATE OIL & GAS COUNCIL WELLS, LOCATED AT www.dnr.mo.gov/geology/geosrv/oilandgas.htm, THERE ARE NO OIL OR GAS WELLS ON THE PROPERTY SHOWN HEREON.

PRE-CONSTRUCTION MEETING NOTE:

THE CONTRACTOR SHALL CONTACT THE CITY'S DEVELOPMENT SERVICES ENGINEERING INSPECTION TO SCHEDULE A PRE-CONSTRUCTION MEETING WITH A FIELD ENGINEERING INSPECTOR PRIOR TO ANY LAND DISTURBANCE WORK AT (816) 969-1200.

FIRE ACCESS ROAD NOTE:

ALL FIRE ACCESS LANES SHALL BE HEAVY DUTY ASPHALT CAPABLE OF SUPPORTING 75,000-POUNDS.

FLOOD NOTE:

THIS PROPERTY LIES WITHIN ZONE X, DEFINED AS AREAS DETERMINED TO BE OUTSIDE THE 0.2% ANNUAL CHANCE FLOODPLAIN, AS SHOWN ON THE FLOOD INSURANCE RATE MAP PREPARED BY THE FEDERAL EMERGENCY MANAGEMENT AGENCY FOR THE CITY OF LEE'S SUMMIT, COMMUNITY NO. 290174, JACKSON COUNTY, MISSOURI, MAP NO. 29095C0417G, AND DATED JANUARY 20, 2017.

BUILDING & LOT DATA

Zoning	PMIX
Lot 10D	
Site Area	1.28 Ac.
Impervious Area	0.13 Ac. (10%)
Open Space	1.15 Ac. (90%)
Lot 10E	
Site Area	0.77 Ac.
Impervious Area	0.07 Ac. (9%)
Open Space	0.70 Ac. (91%)
Lot 10F	
Site Area	0.74 Ac.
Impervious Area	0.05 Ac. (7%)
Open Space	0.69 Ac. (93%)

<u>LEGEND</u>

_		_
_	-LL-	—
_	-R/W-	_

-	LOT LINE
	RIGHT-OF-WAY
	2' CUPP & CUTTER

PROPERTY LINE

2' CURB & GUTTER

HEAVY DUTY ASPHALT PAVEMENT


CONCRETE PAVEMENT




60' 30'




PLAN 10-C AD RO/ RD M Щ. О ភ ALL ั่ว ว ΜΞ 700 EE'S








ELPS-SERVER\Projects\P\240017\Dwg\Permit Plans\SITE.dwg Layout:1 Apr 04, 2024 - 5:35pm Daniel Fi





Know what's **below**.

Call before you dig.

- CONTOURS AND ELEVATIONS: Existing and proposed contours are shown on plans at one foot (1') contour intervals, unless otherwise noted, proposed contours and elevations shown represent approximate finish grade. Contractor shall hold down
- 2. If the contractor does not accept existing topography as shown on the plans, without exception, he shall have made at his
- CLEARING AND GRUBBING: Prior to beginning preparation of subgrade, all areas under pavements or building shall be stripped of all topsoil, vegetation, large rock fragments (greater than 6 inches in any dimension) and any other deleterious material. The actual stripping depth should be based on visual examination during construction and the results of proof-rolling operations. The root systems of all trees (not designated to remain) shall be removed in their entirety. Stripping materials shall not be
- 4. TOPSOIL STRIPPING: Prior to the start of site grading, the contractor shall strip all topsoil from areas to be graded, and stockpiled at a location on or adjacent to the site as directed by the owner. At completion of grading operations and related construction, the contractor will be responsible for redistribution of topsoil over all areas disturbed by the construction activities. Topsoil shall be placed to a minimum depth of six inches (6") and in accordance with specifications for landscaping. At that time, and prior to the installation of landscaping or irrigation, all topsoil graded areas shall be visually inspected and accepted
- 5. Contractor shall adjust and/or cut existing pavement as necessary to assure a smooth fit and continuous grade. Contractor shall assure positive drainage away from buildings for all natural and paved areas.
- SUBGRADE PREPARATION: Prior to placement of new fill material, the existing subgrade shall be proofrolled and approved under
- PROOFROLLING: Subsequent to completion of stripping and over-excavation, all building and pavement areas to receive engineered fill should be systematically proof-rolled using a tandem axle dump truck loaded to approximately 20,000 pounds per axle. Also, any finished subgrade areas to receive paving shall be proof-rolled within 48 hours of paving. Unsuitable soils that are detected and that can not be recompacted should be over-excavated and replaced with controlled structural fill.

A) GEOTECHNICAL: All earthwork shall conform to the recommendations of the Geotechnical report. Said report and its recommendations are herein incorporated into the project requirements by reference. Prior to beginning construction, the contractor shall obtain a copy of and become familiar with the geotechnical report. Unless specifically noted on the plans, the recommendations in the geotechnical report are hereby incorporated into the project requirements and specifications.

B) SURFACE WATER: Surface water shall be intercepted and diverted during the placement of fill.

C) FILLS: All fills shall be considered controlled or structural fill and shall be free of vegetation, organic matter, topsoil and debris. In areas where the thickness of the engineered fill is greater than five, feet building and pavement construction should not commence until so authorized by the on-site geotechnical engineer to allow for consolidation.


D) BUILDING SUBGRADE: As specified in the Geotechnical Engineering Report, the upper section of building subgrade shall consist of Low Volume Change (LVC) material defined as approved, compacted granular fill or low to moderate plasticity cohesive soil materials stabilized with Class C Flyash. Granular fill shall consist of compacted granular materials with a maximum particle size of two (2) inches or less, such as limestone screenings. Refer to geotechnical report for complete


E) EXISTING SLOPES: Where fill material is to be placed on existing slopes greater than 5:1 (horizontal to vertical), existing slope shall be benched providing a minimum vertical face of twelve inches (12"). The benches should be cut wide enough to accommodate the compaction equipment. Fill material shall be placed and compacted in horizontal lifts not exceeding nine inches (9") (loose lift measurement), unless otherwise approved by the Geotechnical Engineer.


F) COMPACTION REQUIREMENTS: The upper 9 inches of pavement subgrade areas shall be compacted to a minimum density of ninety five percent (95%) of the material's maximum dry density as determined by ASTM D698 (standard proctor compaction). The moisture content at the time of placement and compaction shall within a range of 0% below to 4% above optimum moisture content as defined by the standard proctor compaction procedure. The moisture contents shall be maintained within this range until completion of the work. Where compaction of earth fill by a large roller is impractical or


- 9. All cut or fill slopes shall be 3:1 or flatter. All asphalt parking areas shall be a minimum of 1% slope but not more than 5% slope unless otherwise noted. All pavements within ADA parking areas shall not exceed 2% total slope. All grades around building shall be held down 6" from finish floor and slope away another 6" in 10 feet. Contractor shall notify engineer prior to final subgrade construction of any areas not within this slope requirement.
- TESTING AND INSPECTION: Owner's Independent Testing Laboratory (ITL) shall make tests of earthwork during construction and observe the placement of fills and other work performed on this project to verify that work has been completed in accordance with Geotechnical Engineering Report, Project Specifications and within industry standards. The ITL will be selected by the owner
- 11. CLASSIFICATION: All excavation shall be considered unclassified. No separate or additional payments shall be made for rock
- 12. PERMANENT RESTORATION: All areas disturbed by earthwork operations shall be seeded.
- 13. UTILITIES: The contractor is specifically cautioned that the location and/or elevation of existing utilities as shown on these plans is based on records of the various utility companies, and where possible, measurements taken in the field. The information is not to be relied on as being exact or complete. The contractor must call the appropriate utility companies at least 48 hours before any excavation to request exact field location of utilities. It shall be the responsibility of the contractor to relocate all existing utilities which conflict with the proposed improvements shown on the plans.
- LAND DISTURBANCE: The contractor shall adhere to all terms & conditions as outlined in the EPA or applicable state N.P.D.E.S. permit for storm water discharge associated with construction activities. Refer to project S.W.P.P.P. requirements.


vation	1,100 Cu. Yds.	
Compaction (+15%)	-2,445 Cu. Yds.	
nt Adjustment	458 Cu. Yds.	(assume 12.5" of additional excavation)
Adjustment	0 Cu. Yds.	(assume 24" of additional excavation)
let	-887 Cu. Yds.	_











LEGEND PROPERTY LINE

PL — PL — — — — — — — — — — — — — — — —
920 918 920 918
TW TW

LOT LINE RIGHT-OF-WAY 2' CURB & GUTTER EXISTING CONTOURS PROPOSED CONTOURS PROPOSED SPOT ELEVATION LG LIP OF GUTTER TC TOP OF CURB SW SIDEWALK MATCH EXISTING ME HIGH POINT HP LOW POINT TOP OF PAVEMENT TOP OF STRUCTURE GROUND ELEVATION BOTTOM OF STEPS BOTTOM OF WALL TOP OF WALL BW ΤW

EXISTING STORM SEWER PROPOSED STORM PIPE


PROPOSED WET CURB & GUTTER


PROPOSED DRY CURB & GUTTER

SUMMIT 4C-1 4C-1, 4C-2 AND 4

NW1/4	NE1/4	
SW1/4	SE1/4	
NW CHIPMAN ROAD		
VICINITY MAP SEC. 36-48-32		







UTILITY NOTES:


- 1. The contractor is specifically cautioned that the location and/or elevation of existing utilities as shown on these plans is based on records of the various utility companies, and where possible, measurements taken in the field. The information is not to be relied on as being exact or complete. The contractor must call the appropriate utility companies at least 48 hours before any excavation to request exact field location of utilities. It shall be the responsibility of the contractor to coordinate with and relocate &/or remove all existing utilities which conflict with the proposed improvements shown on the plans.
- 2. The construction of storm sewers on this project shall conform to the requirements of the City's Technical Specifications and Design Criteria. The contractor shall field verify the exact location and elevation of the existing storm sewer lines and the existing elevation at locations where the proposed storm sewer collects or releases to existing ground. If discrepancies are encountered from the information shown on the plans, the contractor shall contact the design engineer. No pipes shall be laid until direction is received from the design engineer. 3.
- 4. It will be the contractors responsibility to field adjust the top of all manholes and boxes as necessary to match the grade of the adjacent area. Tops of existing manholes shall be raised as necessary to be flush with proposed pavement elevations, and to be 6-inches above finished ground elevations in non-paved areas. No separate or additional compensation will be made to the contractor for making final adjustments to the manholes and boxes.
- 5. Inlet locations, horizontal pipe information and vertical pipe information is shown to the center of the structure. Deflection angles shown for storm sewer pipes are measured from the center of curb inlets and manholes. The contractor shall adjust the horizontal location of the pipes to go to the face of the boxes. All roof drains shall be connected to storm sewer structures. Provide cleanouts on roof drain lines at 100' max. Spacing and at all bend points. Do not connect roof drains directly to storm sewer pipe.
- 6. The contractor shall be responsible for furnishing and installing all fire and domestic water lines, meters, backflow devices, pits, valves and all other incidentals required for a complete operable fire protection and domestic water system. All costs associated with the complete water system for the buildings shall be the responsibility of the contractor. All work shall conform to the requirements of City.
- 7. The contractor shall be responsible for furnishing and installing all sanitary sewer service lines from the buildings to the public line. All work shal conform to the requirements of the City. 8. The contractor will be responsible for securing all permits, bonds and insurance required by the contract documents, City, and all other governing
- agencies (including local, county, state and federal authorities) having jurisdiction over the work proposed by these construction documents. The cost for all permits bonds and insurance shall be the contractors responsibility and shall be included in the bid for the work. 9. By the use of these construction documents the contractor hereby agrees that he/she shall be solely responsible for the safety of the construction
- workers and the public. The contractor agrees to hold the engineer and owner harmless for any and all injuries, claims, losses or damages related to the project. 10. The Contractor shall be responsible for furnishing all materials, tools and equipment and installation of electrical power, telephone and gas service
- from a point of connection from the public utility lines to the building structures. This will include all conduits, service lines, meters, concrete pad and all other incidentals required for a complete and operational system as required by the owner and the public utilities. Refer to building plans for exact tie-in locations of all utilities. Contractor shall verify connection points prior to installation of utility line.
- 11. All fill material is to be in place, compacted, and consolidated before installation of proposed utilities. On-site geotechnical engineer shall provide written confirmation that this requirement has been met and that utilities may proceed in the fill areas. All utilities are to be placed in trench conditions
- 12. Contractor shall notify the utility authorities inspectors 48 hours before connecting to any existing line.
- 13. Water lines shall be as follows (unless otherwise shown on plans): - Pipe sizes less than 3-inches that are installed below grade and outside building shall comply with the following: 1. Seamless Copper Tubing: Type "K" soft copper, ASTM B88.
- 2. Fittings: Wrought copper (95_5 Tin Antimony solder joint), ASME B 16.22.
- 14. Minimum trench width shall be 2 feet.
- 15. Contractor shall maintain a minimum of 42" cover on all waterlines. All water line joints are to be mechanical joints with thrust blocking as called out in specifications and construction plans. Water mains and service lines shall be constructed in accordance to City's specifications for commercial services.
- 16. All waterlines shall be kept min. ten (10') apart (parallel) from sanitary sewer lines or manholes. Or when crossing, a 24" vertical clearance (outside edge of pipe to outside edge of pipe) of the water line above the sewer line is required.
- 17. Sanitary conflicts will be resolved prior to permit issuance.
- 18. All underground storm, sanitary, water and other utility lines shall be installed, inspected and approved before backfilling. Failure to have inspection approval prior to backfill will constitute rejection of work.
- 19. All necessary inspections and/or certifications required by codes and/or utility service companies shall be performed prior to announced building possession and the final connection of service. Contractor shall coordinate with all utility companies for installation requirements and specifications
- 20. Refer to building plans for site lighting electrical plan, irrigation, parking lot security system and associated conduit requirements. Coordinate with Owner that all required conduits are in place & tested prior to paving.
- 21. When a building utility connection from site utilities leading up to the building cannot be made immediately, temporarily mark all such site utility terminations
- 22. Refer to the building plans for site lighting electrical requirements, including conduits, pole bases, pull boxes, etc.

UTILITY COMPANIES: MICCOURL CAS ENERCY


MISSOURI GAS ENERGY LUCAS WALLS (LUCAS.WALLS@SUG.COM) 3025 SOUTHEAST CLOVER DRIVE LEE'S SUMMIT, MO 64082	(816) 969–2218
EVERGY PHILLIP INGRAM (PHILLIP.INGRAM@KCPL.COM)	(816) 347-4339
RON DEJARNETTE (RON.DEJARNETTE@KCPL.COM) 1300 HAMBLEN ROAD LEE'S SUMMIT, MO 64081	(816) 347-4316
STORM SEWER (PUBLIC WORKS DEPARTMENT) 220 SE GREEN STREET LEE'S SUMMIT, MO 64063	(816) 969–1800
SANITARY SEWER & WATER (WATER UTILITIES DEPT.) 1200 SE HAMBLEM ROAD, LEE'S SUMMIT, MO 64081	(816)-969-1900
AT&T (913) 383–4929 MR. CLAYTON ANSPAUGH (CA4089@ATT.COM) 9444 NALL AVENUE OVERLAND PARK, KANSAS 66207	(913) 383-4849-FAX


ANTICIPATED FUTURE STORM SEWER (BY OTHERS, SEE SHEET C5 FOR STORM SEWER


NW1/4	NE1/4							
SW1/4	DADA DAAW WN							
NW CHIPMAN ROAD								
VICINITY MAP SEC. 36-48-32								



UMBER 03/08/24 ONAL Š ROAD SSOURI \mathbf{O} **A** Ο








I. RUNOFF								III. PIPE DESIGN										REMARKS							
	S T	S INCREMENTAL CUMULATIVE						STRUCTURE PIPE																	
N L U I M E E R	R U C T U R E	RUNOFF COEFFICIENT "C"	AREA "A" (ACRES)	C x A	AREA "A" (ACRES)	СхА	SYSTEM TIME OF CONCENTRATION "T _c " AT STRUCTURE (MIN)	RAINFALL	SITY PRECIPITATION I100" FACTOR	RUNOFF "Q ₂₅ / Q ₁₀₀ " (CFS)	Upstream Structure Number	Downstream Structure Number	Upstream Structure Rim Elevation	Height of Structure (FT)	Diameter "D" (IN)	Length "L" (FT)	Upstream Invert Elevation	Downstream Invert Elevation	Slope "S" (FT/FT)	Travel Time in Pipe "TT" (min)	Velocity Full V _p (FPS)	Runoff Q ₂₅ (CFS)	Runoff Q ₁₀₀ (CFS)	Full Flow Q _p (CFS)	
	10	0.76	0.96	0.73	0.96	0.73	5.00	8.53	1.10	6.8	10	11	998.80	3.50	18	115.79	995.30	994.72	0.0050	0.46	4.2	6.8	9.4	7.4	FUTURE (BY OTHER
	11	0.70	0.72	0.55	1.69	1.00	5.00	10.32	1.25	9.4	11	10	008.20	4.42	24	116.00	993.78	993.20	0.0050	0.29	5 1	12.0	16.5	16.0	
	11	0.76	0.72	0.55	1.68	1.28	5.00	8.53 10.32	1.10 1.25	12.0 16.5	11	12	998.20	4.42	24	116.80	995.78	993.20	0.0050	0.38	5.1	12.0	16.5	16.0	
1	12	0.76	0.91	0.69	2.59	1.97	5.00	8.53	1.25	18.5	12	13	998.50	5.80	24	236.69	992.70	991.02	0.0070	0.65	6.1	18.5	25.4	18.9	
								10.32	1.25	25.4							hum	hund							
	13	0.76	0.00	0.00	2.59	1.97	5.00	8.53	1.10	18.5	13	EX	1002.77	11.95	24	94.13	990.82	989.79	0.0109	0.21	7.6	18.5	25.4	23.6	EXISTIN
								10.32	1.25	25.4															

STORM DRAINAGE CALCULATIONS






LEGEND

----XXX---- EXISTING CONTOURS ——XXX—— XXX PROPOSED CONTOURS


> DENOTES DRAINAGE AREA DENOTES FLOW DIRECTION


> > DENOTES STRUCTURE NUMBER




DENOTES DRAINAGE AREA TO STRUCTURE


THIS PROPERTY LIES WITHIN ZONE X, DEFINED AS AREAS DETERMINED TO BE OUTSIDE THE 0.2% ANNUAL CHANCE FLOODPLAIN, AS SHOWN ON THE FLOOD INSURANCE RATE MAP PREPARED BY THE FEDERAL EMERGENCY MANAGEMENT AGENCY FOR THE CITY OF LEE'S SUMMIT, COMMUNITY NO. 290174, JACKSON COUNTY, MISSOURI, MAP NO. 29095C0417G, AND DATED JANUARY 20, 2017.







*28' SAN_SEWER_FSMI_ 55 55 55 *DOC. 2008E0085123 55 55 55	PHELDS ENCINCERING, INC. PARIDS EN
STRUCTURE BACKFILL NOTES: 1. CLSM SHALL BE USED TO BACKFILL AROUN AS MANHOLES, INLETS, JUNCTION BOXES, VAU BE PLACE THE FULL DEPTH OF THE TRENCH SHALL BE AT LEAST 6 INCHES BELOW THE B SUBGRADE UNDER PAVEMENTS OR 12 INCHES SURFACE IN LANDSCAPED AREAS. THE EXTER OF WEEP HOLES SHALL BE COVERED WITH HA SURROUNDED WITH A MINIMUM OF THREE CUE CONSOLIDATED GRANULAR BEDDING MATERIAL	ULTS, ETC. CLSM SHALL BACKFILL ZONE, BUT BOTTOM OF PREPARED S BELOW THE GROUND RNAL OPENING SURFACES ARDWARE CLOTH AND BIC FEET OF
EX. 24" HDPE	b 1"=20' 40' b c 1 c 1 c 20' HORIZ. c 5' VERT. b c c c c c c c c
1 (PRIVATE) CRADE RINGS	1020 1020 1020 1015 1020 1015 1020 1015
STA. 0+00.00, LINE 1 CONNECT TO EX. 4' DI RAISE EX. M.H. TO NET FINISHED GRADE VIA G EX. TE=1000.77 PROP. TE=1002.77	1015 Revisions: Revisions: Revisions: Revisions: Revisions: Revisions: Revisions: 1010 1010 1010 Revisions: Revisions: 1010 Revisions: Revisions: 1010 Revisi
25-YEAR HGL	0001 No. Date 001 No. 001 No. 001 No. 0001 No. 0
EX. 24" HDPE	CERTIFICATE OF AUTHORIZATION CERTIFICATE OF AUTHORIZATION CERTIFICATE OF AUTHORIZATION CERTIFICATE OF AUTHORIZATION CERTIFICATE OF AUTHORIZATION CERTIFICATE OF AUTHORIZATION MISSOURI MISSOURI MISSOURI CERTIFICATE OF AUTHORIZATION MISSOURI MISSOU
Image: Sector	2 2 2 2 3 2 3 3 5 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 3 2 5 5 3 2 5 5 3 2 5 5 5 5
0+50 0+00	980



Call before you dig.

EROSION AND SEDIMENT CONTROL GENERAL NOTES:

- 1. Prior to Land Disturbance activities, the contractor shall: -Construct a stabilized entrance/parking/delivery area and install all perimeter sediment controls on the site. Land disturbance work shall not proceed until t here is a satisfactory inspection. barriers or other means acceptable to the contractor and the City inspector.
- of $\frac{1}{2}$ " or more within any 24-hour period
- on—site drainage channel. Failure to do so is a violation of the provisions of City Ordinances and State permit requirements.
- adequate erosion and sediment control at any time during the project, the contractor shall install additional or alternate measures that provide effective control.
- Spills will be reported as required by law and immediate actions taken to contain them.

- NEEDED.
- ONE-THIRD THE HEIGHT OF THE SILT FENCE.
- DRESSING OF THE TEMPORARY PARKING AS CONDITIONS DEMAND.

				STAC	GING CHART	
		Project Stage	Order	BMP Description	Remove after Stage:	Notes:
_	A.	Prior to Land Disturbance	$\langle 1 \rangle$	Sediment Fence	D	Place downstream project site perimeter. (APWA ESC-10)
Phase		and During Construction.	2	Constr Entrance & Staging Area	D	Maintain during all construction. Include concrete washout. (APWA ESC-01)
□			3	Inlet Protection at Existing Inlets	D	Install inlet protection. (APWA Details ESC-06 & ESC-07)
Phase II	В.	Mass Grading & Utility Installation	4	Inlet Protection at Proposed Inlets	D	Install inlet protection. (APWA Details ESC-06 & ESC-07)
Phase III	C.	Final Stabilization Prior to closure of Land Disturbance Permit		Final Stabilization	N/A	Seed all disturbed areas to establish final stabilization.

DISTURBED AREA = $2.8\pm$ ACRES

-Delineate the outer limits of any tree or stream preservation designated to remain with construction fencing.

-Install and request the inspection of the preconstruction erosion and sediment control measures designated on the approved erosion and sediment control plan. -Identify the limits of construction on the ground with easily recognizable indications such as construction staking, construction fencing, placement of physical

2. Erosion and sediment control devices protecting the public right-of-way shall be installed as soon as the right-of-way has been backfilled and graded.

3. The contractor shall comply with all requirements of City Ordinances or State permit requirements, such as: -The contractor shall seed, mulch, or otherwise stabilize any disturbed area where the land disturbance activity has ceased for more than 14 days. -The contractor shall perform inspections of erosion and sediment control measures at least once a every 14 days and within 24 hours following each rainfall event

-The contractor shall maintain an inspection log including the inspector's name, date of inspection, observations as to the effectiveness of the erosion and sediment control measures, actions necessary to correct deficiencies, when the deficiencies were corrected, and the signature of the person performing the inspection. The log

shall be available for review by the City, the State of Missouri, or other authorities having jurisdiction. 4. The contractor shall maintain installed erosion and sediment control devices on a manner that preserves their effectiveness for preventing sediment from leaving the site or entering a sensitive area such as a natural stream corridor, tree preservation areas of the site intended to be left undisturbed, a storm sewer, or an

5. The contractor is responsible for providing erosion and sediment control for the duration of a project. If the City determines that the BMP's in place do not provide

6. Concrete wash or rinsewater from concrete mixing equipment, tools and/or ready-mix trucks, tools, etc., may not be discharged into or be allowed to run directly into any existing water body or storm inlet. One or more locations for concrete wash out will be designated on site, such that discharges during concrete washout will be contained in a small area where waste concrete can solidify in place and excess water evaporated or infiltrated into the ground.

Chemicals or materials capable of causing pollution may only be stored onsite in their original container. Materials store outside must be in closed and sealed water—proof containers and located outside of drainageways or areas subject to flooding. Locks and other means to prevent or reduce vandalism shall be used.

MAINTENANCE: ALL MEASURES STATED ON THIS EROSION AND SEDIMENT CONTROL PLAN, AND IN THE STORM WATER POLLUTION PREVENTION PLANATION, SHALL BE MAINTAINED IN FULLY FUNCTIONAL CONDITION UNTIL NO LONGER REQUIRED FOR A COMPLETED PHASE OF WORK OR FINAL STABILIZATION OF THE SITE. ALL EROSION AND SEDIMENTATION CONTROL MEASURES SHALL BE CHECKED BY A QUALIFIED PERSON IN ACCORDANCE WITH THE CONTRACT DOCUMENTS OR THE APPLICABLE PERMIT, WHICHEVER IS MORE STRINGENT, AND REPAIRED IN ACCORDANCE WITH THE FOLLOWING:

1. INLET PROTECTION DEVICES AND BARRIERS SHALL BE REPAIRED OR REPLACED IF THEY SHOW SIGNS OF UNDERMINING, OR DETERIORATION.

2. ALL SEEDED AREAS SHALL BE CHECKED REGULARLY TO SEE THAT A GOOD STAND IS MAINTAINED. AREAS SHOULD BE FERTILIZED, WATERED, AND RESEEDED AS

3. SILT FENCES SHALL BE REPAIRED TO THEIR ORIGINAL CONDITIONS IF DAMAGED. SEDIMENT SHALL BE REMOVED FROM THE SILT FENCES WHEN IT REACHES

4. THE CONSTRUCTION ENTRANCES SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT TRACKING OR FLOW OF MUD ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING OF THE CONSTRUCTION ENTRANCES AS CONDITIONS DEMAND.

5. THE TEMPORARY PARKING AND STORAGE AREA SHALL BE KEPT IN GOOD CONDITION (SUITABLE FOR PARKING AND STORAGE). THIS MAY REQUIRE PERIODIC TOP




LEGEND

STABILIZED ROCK ENTRANCE

PROPOSED SILT FENCE


INLET PROTECTION -PRIOR TO PAVING USE SILT FENCE INLET PROTECTION WITH WIRE SUPPORT -AFTER TO PAVING USE GRAVEL FILTER BAGS









SCALE: 1"=30' 60' 30'








NON-SETBACK CURB INLET

(6" Throat) SCALE: N.T.S.


- 3" (TYP) - TEMPORARY ASPHALT CURB - PAVEMENT


- PROOF ROLL AND RE-COMPACT THE EXPOSED SURFACES UP TO A MINIMUM LATERAL DISTANCE OF TWO (2) FEET OUTSIDE THE PAVEMENT. ANY LOCALIZED SOFT, WET, OR LOOSE AREAS IDENTIFIED DURING THE PROOF ROLLING SHOULD BE REPAIRED PRIOR TO PAVING. FILL MATERIAL SHOULD BE PLACED IN LOOSE LIFTS UP TO A MAXIMUM OF EIGHT (8) INCHES IN THICKNESS AND COMPACTED TO AT LEAST 95% OF THE MAXIMUM DRY DENSITY IN ACCORDANCE WITH ASTM D698 AT MOISTURE CONTENTS WITHIN 0% AND +4% OF THE OPTIMUM FOR SOILS WITH A LIQUID LIMIT OF GREATER THAN 40, AND - +/- 3% OF THE OPTIMUM FOR SOILS WITH A LIQUID LIMIT OF LESS THAN 40. MAXIMUM DRY DENSITY AND OPTIMUM MOISTURE CONTENT SHOULD BE DETERMINED
- PROOFROLL WITH A 25 TON RUBBER TIRE VEHICLE AND REPAIR SUBGRADE DEFICIENCIES. IF ANY SIGNIFICANT EVENT, SUCH AS PRECIPITATION, OCCURS AFTER PROOFROLLING, THE SUBGRADE SHOULD BE REVIEWED BY
- PAVING SHALL BE COMPACTED AB-3 OR EQUIVALENT.
- LIFTS OF ASPHALT.




 All welds shall be performed in accordance with appropriate AWS Specifications and Procedures. Any specifications and procedures.
 All welds on exposed surfaces shall be dressed so as to provide a pleasing finished appearance.
 The entire frame shall be hot dip zinc coated in accordance with ASTM A-123.

Aocations, shown construction plans are center of structure. ____ No. 4 Bars placed at 45 degree angle (Typical) Inside Wall Outside Edge of Concrete Footing _ _ _ __ -Deeter #2512_Grate and Frame or Approved Equal A -PLAN Scale: 1/2"=1'-0"







-

ັ N N