



KAW VALLEY ENGINEERING, INC.

Office: 913.894.5150

Fax: 913.894.5977

Web: www.kveng.com

Address: 14700 West 114th Terrace
Lenexa, KS 66215

July 16, 2024

C23D1880

City of Lee's Summit
Development Services
220 SE Green Street
Lee's Summit, Missouri 64063

**RE: PROPOSED HYDRANT ASSEMBLY (PL2024066)
LSHS EAST PARKING LOT
LEE'S SUMMIT, MISSOURI**

To Whom it May Concern:

To expedite construction and reduce loss of service to the campus fire suppression system, the Lee's Summit School District contractor has requested to install a tapping sleeve and valve and wet tap the LSSD owned 8 PVC Fire Line for the new hydrant assembly in lieu of installing the cut in tee and sleeve as noted on the approved project Site Plan (Sheet C100).

Kaw Valley Engineering, Inc. (KVE) has reviewed the request and recommends approval with concurrence from the City. Due to the connection being on the district owned fire main and downstream of the LSSD owned backflow device, the risk to City owned water infrastructure is mitigated.

This letter is submitted to the project file for your records. If you have any questions or need additional information regarding the proposed project, don't hesitate to contact me at (913) 894-5150 or at wood@kveng.com.

Respectfully submitted,
Kaw Valley Engineering, Inc.

David D. Wood, P.E.
Project Manager



Attachments: Plan Sheet C100.

cc: Kent Andersen, Lee's Summit School District
Dan Ward, Wil-Pav

\\VMLX-FILE\Projects\C23_1880\DSN\FDP and Permit\City Review\Response 20240625\20240716 LSHS East Parking Lot FDP Connection for Fire Hydrant.docx

