

Commercial Preliminary Development Plan Applicant's Letter

Date: Friday, August 23, 2024

To:

Property Owner: OLDHAM INVESTORS LLC

Email:

Property Owner: OLDHAM INVESTORS X LLC

Email:

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Other: DRAKE DEVELOPMENT, LLC

Email: Ian@DrakeKC.com

From: Grant White,

Re:

Application Number: PL2023188

Application Type: Commercial Preliminary Development Plan

Application Name: Oldham Village Phase 1

Location: 1025 SW JEFFERSON ST, LEES SUMMIT, MO 64081
1031 SW JEFFERSON ST, LEES SUMMIT, MO 64081
101 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

Schedule

Planning Commission Meeting: September 12, 2024 at 05:00 PM

City Council Public Hearing: October 08, 2024 at 06:00 PM

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plat - All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided as multi-page Portable Document Format (PDF).

- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided as multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Planning Commission and City Council Presentations

Presentations before the Planning Commission and City Council shall be (1) in electronic format or (2) reduced drawings for use on the document camera to display on the screen. Electronic presentations shall be on a laptop, CD-ROM, DVD, or flash drive. The City's presentation system can support Word, Excel, PowerPoint, Adobe, Windows Media Player and Internet Explorer applications. Presentation boards will no longer be allowed. The presentation(s) shall be submitted to Development Services Department staff no later than the day of the Planning Commission meeting by 4:00 pm.

Notice Requirements

1. Notification of Surrounding Property Owners.

- **Mail Notices.** The applicant must mail letter notices to all property owners within 300 feet from the boundaries of the property for which the application is being considered at least 15 days prior to the hearing. Sample notices are available. The notice must include:
 - time and place of hearing,
 - general description of the proposal,
 - location map of the property,
 - street address, or general street location
 - statement explaining that the public will have an opportunity to be heard
- **File Affidavit.** An affidavit must be filed with the Development Services Department prior to the public hearing certifying the notices have been sent. Provide a list of the property owners notified and a copy of the sent notice .

2. Notice Signs.

- **Post Sign.** The applicant shall post a sign on the premises, at least 15 days prior to the date of the hearing, informing the general public of the time and place of the public hearing. When revised plans are submitted, staff will prepare the sign and provide it to the applicant for posting.
- **Maintain Sign.** The applicant shall make a good faith effort to maintain the sign for at least the 15 days immediately preceding the date of the hearing, through the hearing, and through any continuances of the hearing. The sign shall be placed within 5 feet of the street right-of-way line in a central position on the property that is the subject of the hearing. The sign shall be readily visible to the public. If the property contains more than one street frontage, one sign shall be placed on each street frontage so as to face each of the streets abutting the land. The sign may be removed at the conclusion of the public hearing(s) and must be removed at the end of all proceedings on the application or upon withdrawal of the application.

3. Neighborhood Meeting. One neighborhood meeting is required for each application, which must occur within the initial 10 day review period and prior to re-submission of the application. More than one neighborhood meeting may be held on an application, at the option of the applicant

- **Timing and location:** Within two miles of the project site, Monday through Thursday, excluding holidays, and start between 6:00P.M. and 8:00 P.M. If location for the meeting is not available within [2] miles of the subject property. The applicant shall select a location outside this area that is reasonably close to these boundaries.
- **Notification:** Shall be mail or delivered to property owners within 300 feet of the project site. Mailed notices shall be postmarked at least seven days prior to the meeting. Hand deliveries must occur at least five (5) days prior to the meeting.
- **Notes:** The Applicant shall take sufficient notes at the neighborhood meeting to recall issues raised by the participants, in order to report on and discuss them at public hearings before City governmental bodies on the application. The notes shall be turned in with the application re-submittal.

Analysis of Commercial Preliminary Development Plan:

Planning Review	Hector Soto Jr. (816) 969-1238	Senior Planner Hector.Soto@cityofls.net	Corrections
------------------------	-----------------------------------	--	-------------

1. BUILDING ELEVATIONS. Provide color elevations for the proposed buildings (only black and white elevations have been provided): Five Four Restaurant & Draffhouse building; and Popeye's.

2. ROOF-TOP MECHANICAL SCREENING. To comply with City ordinance, RTUs shall be fully screened from view on all sides via building parapet walls of a height at least equal to the height of the units being screened. The use of a separate screen system is not allowed on new construction buildings. 1) It isn't clear from the Panda Express building elevations if the composite bamboo material that will screen the units on three sides comprises parapet walls with the bamboo composite as the exterior finish material, or if said material is a separate screen system independent of the building architecture. 2) The Casey's building elevations show the RTUs being screened via a separate screen system rather than vertically extended parapet walls as required by the UDO.

3. Please submit an electronic copy of the legal description. Microsoft Word document or selectable text PDF are the preferred file formats. The legal description can be emailed to the planner's email address above.

Engineering Review	Gene Williams, P.E. (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------------	---	--------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final development plan. All public infrastructure must be substantially complete, prior to the issuance of any certificates of occupancy.

2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).

3. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.

4. A Land Disturbance Permit shall be obtained from the City if groundbreaking will take place prior to the issuance of a site development permit, building permit, or prior to the approval of the Final Development Plan / Engineering Plans.

5. All permanent off-site easements, in a form acceptable to the City, shall be executed and recorded with the Jackson County Recorder of Deeds prior to the issuance of a Certificate of Substantial Completion or approval of the final plat. A certified copy shall be submitted to the City for verification.

6. All ADA sidewalk ramps shall be constructed by the developer at the time the street is constructed.

7. A United States Army Corps of Engineers (USACE) permit may be required for work within the jurisdictional stream near the proposed in-line detention basin. A jurisdictional determination letter shall be submitted during the Final Development Plan phase of this project.

Fire Review

Jim Eden
(816) 969-1303

Assistant Chief
Jim.Eden@cityofls.net

Corrections

3. Provide a drawing showing turning movements on the fire lanes for a 44' straight fire truck. Show movements to shared parking lot accesses, private roads and particularly the aerial access lanes next to the apartment building

Not provided

4. IFC 507.5.1 - Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 300 feet from a hydrant on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains shall be provided where required by the fire code official.

Provide a complete hydrant plan showing public and private hydrants. Hydrant distances are measured around the buildings and not through them. Public hydrants shall be located and spaced per design standards Who will be responsible for the maintenance of private hydrants on the access roads?

Provide hydrants on four lane roads and roads separated separated by medians arrange hydrants on either side of the street wit an average spacing of 500 feet (IFC Table C102.1).

Show public hydrants along Oldham Parkway

6. Provide a phasing plan for road construction.

Traffic Review

Erin Ralovo

Erin.Ravolo@cityofls.net

Corrections

1. The description of access 6 in the TIA is not correct as it references itself and claims to provide access to 3 pad sites but the plan only shows 2.

2. Because the trail access across the Field House parking area is 10 FT wide, and the Mulit-use trail on the East side of Jefferson is 10 FT wide, please extend the sidewalk west of Jefferson to match the 10 FT width.

3. Final approval of the plans will not be given until MoDOT approves any improvements within their ROW.

4. The SB left Turn lane at Access 2 as well as the northbound turn lane at access 3 do not meet the minimum lengths specified in the TIS. Please move Access 3 further to the North in order to lengthen these turn lanes and provide the required 150 FT of storage.

5. The signal at access 2 is not shown.

6. TIS recommends 300 FT of storage for the SB right turn lane on MO 291, plans only provide 200 FT. The lane should be extended as far as possible and MoDOT will need to approve any deviation from the TIS.