

DEVELOPMENT SERVICES

**Residential Rezoning with Preliminary Development Plan
Applicant's Letter**

Date: Friday, September 06, 2024

To:

Property Owner: CHOYCE LLC

Email:

Engineer/Surveyor: MATT SCHLICHT

Email: MSCHLICHT@ES-KC.COM

From: Daniel Fernandez, Project Manager

Re:

Application Number: PL2024217

Application Type: Residential Rezoning with Preliminary Development Plan

Application Name: Townhomes at Chapel Ridge - Rezoning and PDP

Location: 4060 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

Tentative Schedule

Submit revised plans by 4pm on Tuesday, September 24, 2024 . Revised documents shall be uploaded to the application through the online portal.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plat - All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided as multi-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided as multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Planning Commission and City Council Presentations

Presentations before the Planning Commission and City Council shall be (1) in electronic format or (2) reduced drawings for use on the document camera to display on the screen. Electronic presentations shall be on a laptop, CD-ROM, DVD, or flash drive. The City's presentation system can support Word, Excel, PowerPoint, Adobe, Windows Media Player and Internet Explorer applications. Presentation boards will no longer be allowed. The presentation(s) shall be submitted to Development Services Department staff no later than the day of the Planning Commission meeting by 4:00 pm.

Notice Requirements

1. Notification of Surrounding Property Owners.

- **Mail Notices.** The applicant must mail letter notices to all property owners within 300 feet from the boundaries of the property for which the application is being considered at least 15 days prior to the hearing. Sample notices are available. The notice must include:
 - time and place of hearing,
 - general description of the proposal,
 - location map of the property,
 - street address, or general street location
 - statement explaining that the public will have an opportunity to be heard
- **File Affidavit.** An affidavit must be filed with the Development Services Department prior to the public hearing certifying the notices have been sent. Provide a list of the property owners notified and a copy of the sent notice .

2. Notice Signs.

- **Post Sign.** The applicant shall post a sign on the premises, at least 15 days prior to the date of the hearing, informing the general public of the time and place of the public hearing. When revised plans are submitted, staff will prepare the sign and provide it to the applicant for posting.
- **Maintain Sign.** The applicant shall make a good faith effort to maintain the sign for at least the 15 days immediately preceding the date of the hearing, through the hearing, and through any continuances of the hearing. The sign shall be placed within 5 feet of the street right-of-way line in a central position on the property that is the subject of the hearing. The sign shall be readily visible to the public. If the property contains more than one street frontage, one sign shall be placed on each street frontage so as to face each of the streets abutting the land. The sign may be removed at the conclusion of the public hearing(s) and must be removed at the end of all proceedings on the application or upon withdrawal of the application.

3. **Neighborhood Meeting.** One neighborhood meeting is required for each application, which must occur within the initial 10 day review period and prior to re-submission of the application. More than one neighborhood meeting may be held on an application, at the option of the applicant

- **Timing and location:** Within two miles of the project site, Monday through Thursday, excluding holidays, and start between 6:00 P.M. and 8:00 P.M. If location for the meeting is not available within [2] miles of the subject property. The applicant shall select a location outside this area that is reasonably close to these boundaries.
- **Notification:** Shall be mail or delivered to property owners within 300 feet of the project site. Mailed notices shall be postmarked at least seven days prior to the meeting. Hand deliveries must occur at least five (5) days prior to the meeting.

- **Notes:** The Applicant shall take sufficient notes at the neighborhood meeting to recall issues raised by the participants, in order to report on and discuss them at public hearings before City governmental bodies on the application. The notes shall be turned in with the application re-submittal.

Analysis of Residential Rezoning with Preliminary Development Plan:

Planning Review	Hector Soto Jr. (816) 969-1238	Senior Planner Hector.Soto@cityofls.net	Corrections
------------------------	-----------------------------------	--------------------------------------------	-------------

1. SITE PLAN. Provide a dimensioned site plan with the placement of the proposed building footprint(s) to demonstrate that the minimum setbacks of the RP-4 zoning district are met.
2. BUILDING ELEVATIONS. Provide color elevations of the proposed townhouse.
3. LANDSCAPING. What type of landscape/buffer is proposed to be installed in Tracts F and G between the proposed townhomes and the abutting single-family residences? A medium-impact buffer is typically required by the UDO between RP-3 and R-1 properties? Provide a landscape plan illustrating the proposed screening/buffer.

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	-----------------------------------------------------------	--------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final development plan. All public infrastructure must be substantially complete, prior to the issuance of any certificates of occupancy.
2. A Master Drainage Plan (MDP) shall be submitted and approved in accordance with the City's Design and Construction Manual for all areas of the development, including all surrounding impacted areas, along with the engineering plans for the development. The MDP shall address drainage level of service issues on an individual lot basis.
3. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).
4. All subdivision-related public improvements must have a Certificate of Final Acceptance prior to approval of the final plat, unless security is provided in the manner set forth in the City's Unified Development Ordinance (UDO) Section 7.340. If security is provided, building permits may be issued upon issuance of a Certificate of Substantial Completion of the public infrastructure as outlined in Article 3, Division V, Sections 3.540 and 3.550 and Article 3, Division IV, Section 3.475 of the UDO, respectively.
5. The As-graded Master Drainage Plan shall be submitted to and accepted by the City prior to the issuance of a Certificate of Substantial Completion and prior to the issuance of any building permits for the development.
6. All ADA sidewalk ramps shall be constructed by the developer at the time the street is constructed.

Traffic Review	Erin Ralovo Erin.Ravolo@cityofls.net	No Comments
-----------------------	-----------------------------------------	-------------

Fire Review	Jim Eden Assistant Chief	Approved with Conditions
--------------------	-----------------------------	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

2. Parking shall only be allowed on one side of the street. Post No Parking signs.