

DEVELOPMENT SERVICES

**Minor Plat
Applicant's Letter**

Date: Tuesday, September 24, 2024

To:

Property Owner: KEVIN HIGDON
CONSTRUCTION LLC

Email: kevin@higdonbuilders.com

Web Registered User: Adam Murry

Email: AMURRY@ES-KC.COM

Engineer/Surveyor: ENGINEERING
SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Property Owner: CHOYCE LLC

Email:

From: Daniel Fernandez, Project Manager

Re:

Application Number: PL2024229

Application Type: Minor Plat

Application Name: The Townhomes of Chapel Ridge, Lot 9-A and Tract AA

Location: 4001 NE CHAPEL RIDGE PL, LEES SUMMIT, MO 64064
18 NE LONE HILL DR, LEES SUMMIT, MO 64064

Electronic Plans for Resubmittal

All Planning applicaiton and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in mulit-page Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).

DEVELOPMENT SERVICES

- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Review Status:

Required Corrections:

Planning Review	Ian Trefren	Planner	Approved with Conditions
	(816) 969-1605	Ian.Trefren@cityofls.net	

1. Certification block references Lots 16-A/16-B/16-C. Please amend to reference Lot 9-A/Tract AA.
2. Please remove old lot lines to improve readability.

Engineering Review	Sue Pyles, P.E.	Development Engineering Manager	Corrections
	(816) 969-1245	Sue.Pyles@cityofls.net	

1. Please extend the 10' U/E along NE Lone Hill Dr. to the west and the 20' U/E along NE Chapel Ridge Pl. to the south to a point where they intersect.

Traffic Review	Erin Ralovo		No Comments
		Erin.Ravolo@cityofls.net	

Fire Review	Jim Eden	Assistant Chief	No Comments
	(816) 969-1303	Jim.Eden@cityofls.net	

GIS Plat Review	Kathy Kraemer	GIS Technician	Corrections
	(816) 969-1277	Kathy.Kraemer@cityofls.net	

1. Need ITB on curve coming out of coordinate 3, along the east lot line of 9A