

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Wednesday, October 09, 2024

To:

Property Owner: AURION LC

Email:

Email Contact: PHELPS ENGINEERING, INC

Email: DOUGUBBEN@PHELPSENGINEERING.COM

Applicant: AURION LC

Email:

From: Scott Ready, Project Manager

Re:

Application Number: PL2024168

Application Type: Commercial Final Development Plan

Application Name: Associated Plastic Surgeons

Location: 2701 NE MCBAINE DR, LEES SUMMIT, MO 64064

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Required Corrections:

Planning Review	Ian Trefren (816) 969-1605	Planner Ian.Trefren@cityofls.net	No Comments
------------------------	-------------------------------	-------------------------------------	-------------

Engineering Review	Susan Nelson, P.E. (816) 969-1229	Senior Staff Engineer Susan.Nelson@cityofls.net	Corrections
---------------------------	--------------------------------------	--	-------------

1. The BFPD vault sump must be daylighted or connected to the storm water system, as an aggregate pit is not allowed. Show in the plans how the BFPD vault sump will be drained.
2. Sheet flow across the top of the BFPD within a parking lot does not satisfy the requirement to grade the vault area to drain away. To achieve an appropriate design, grass areas are usually better locations for the BFPD vault. Please reevaluate the design.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Erin Ralovo	Erin.Ravolo@cityofls.net	No Comments
-----------------------	-------------	--------------------------	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions
------------------------------	------------------------------	---	--------------------------

1. Architectural plans not reviewed under this process.

Action required: Comment is informational.