

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Thursday, October 10, 2024

To:

Property Owner: ANACONDA LLC

Email:

Applicant: Kimley-Horn

Email: patrick.joyce@kimley-horn.com

Other: Matt Hendrickson

Email: matt@capitalbuilderskc.com

From: Scott Ready, Project Manager

Re:

Application Number: PL2023322

Application Type: Commercial Final Development Plan

Application Name: Lee's Summit Flex Space

Location: 60 SE THOMPSON DR, LEES SUMMIT, MO 64081

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Required Corrections:

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	No Comments
---------------------------	-----------------------------------	---	-------------

1. The applicant shall submit and the City shall accept an "As-built / As-graded" detention basin plan prior to issuance of any occupancy permit for the proposed development.
2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
3. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$36,211.12
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.