

Scott Ready

From: Susan Nelson
Sent: Tuesday, November 26, 2024 10:25 AM
To: mbengineeringinc@gmail.com
Cc: Scott Ready; Sue Pyles
Subject: PL2024020 Cowboy Carwash FDP

Follow Up Flag: Follow up
Flag Status: Flagged

Good morning, Mike.

We accept the provided stormwater report with your conclusion that the existing infrastructure is functioning as detention, therefore, a design waiver is not necessary. The design details will be reviewed when the Final Development Plans are resubmitted.

Susan Nelson, Senior Staff Engineer
220 SE Green Street | Lee's Summit, MO 64063
816.969.1229 | cityofLS.net | Susan.Nelson@cityofls.net

