

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Monday, December 30, 2024

To:

Property Owner: CHOYCE LLC

Email:

Engineer/Surveyor: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

From: Daniel Fernandez, Project Manager

Re:

Application Number: PL2024223

Application Type: Commercial Final Development Plan

Application Name: Newberry Lot 294

Location: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Required Corrections:

Planning Review

Claire Byers
(816) 969-1242

Senior Planner
Claire.Byers@cityofls.net

Corrections

1. Per UDO: Metal may not exceed 40% of any facade. A modification for the use of metal up to 75% of any facade may be approved by the Planning Commission. A modification for the use of metal to exceed 75% of any facade may be approved by the Governing Body (City Council). See full standards in attached Ordinance 10040, recently approved by City Council and less restrictive than previous UDO language on metal buildings.

Engineering Review	Susan Nelson, P.E. (816) 969-1229	Senior Staff Engineer Susan.Nelson@cityofls.net	Approved with Conditions
---------------------------	--------------------------------------	--	--------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final development plan. All public infrastructure must be substantially complete, prior to the issuance of any certificates of occupancy.
2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).
3. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.
4. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to coordinate a preconstruction meeting / conference with the assigned Field Engineering Inspector.
5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
6. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$xxx.xx

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

The use of the building shall comply with the 2018 Fire Code. Provide information for building permit review.

2. IFC 903.3.7 - Fire department connections. The location of fire department connections shall be approved by the fire code official. Connections shall be a 4 inch Storz type fitting and located within 100 feet of a fire hydrant, or as approved by the code official.

FDC not shown.

Traffic Review	Erin Ralovo	Senior Staff Engineer Erin.Ravolo@cityofls.net	Not Required
Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	Approved with Conditions

1. Architectural/MEP plans have not been reviewed during this process.

Action required: Comment is informational.

2. Unified Development Ordinance Article 8, Section 8.180.F

Ground mounted equipment – Ground mounted equipment shall be totally screened from view by landscaping or masonry wall up to a height of the units to be screened.

Action required: Make needed corrections to drawings that provide details as to how mechanical equipment will be screened from all 4 sides per referenced UDO section.

12/13/2024 - acknowledged in letter. To be field verified.

3. Specify size of water tap at main. Water pipe from main to meter must be 1" with a 1" meter. You can transition to the 1.5" 10' past meter.

12/13/2024 - acknowledged in letter. To be field verified.