

DEVELOPMENT SERVICES

**Vacation of Right-of-Way
Applicant's Letter**

Date: Friday, January 10, 2025

To:

Property Owner: OLDHAM INVESTORS LLC

Email:

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

From: Grant White, Project Manager

Re:

Application Number: PL2024218

Application Type: Vacation of Right-of-Way

Application Name: Oldham Village - Jefferson St

Location: 1204 SW JEFFERSON ST, LEES SUMMIT, MO 64081
1206 SW MARKET ST, LEES SUMMIT, MO 64081
1051 SW JEFFERSON ST, LEES SUMMIT, MO 64081
101 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

Tentative Schedule

Submit revised plans by 4pm on Tuesday, January 28, 2025. Revised documents shall be uploaded to the application through the online portal.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Planning Commission and City Council Presentations

Presentations before the Planning Commission and City Council shall be (1) in electronic format or (2) reduced drawings for use on the document camera to display on the screen. Electronic presentations shall be on a laptop, CD-ROM, DVD, or flash drive. The City's presentation system can support Word, Excel, PowerPoint, Adobe, Windows Media Player and Internet Explorer applications. Presentation boards will no longer be allowed. The presentation(s) shall be submitted to Development Services Department staff no later than 4:00 pm on the Tuesday prior to the Planning Commission meeting.

Notice Requirements

1. Notification of Surrounding Property Owners.

- **Mail Notices.** The applicant must mail letter notices to all property owners within 300 feet from the boundaries of the property for which the application is being considered at least 15 days prior to the hearing. Sample notices are available. The notice must include:
 - time and place of hearing,
 - general description of the proposal,
 - location map of the property,
 - street address, or general street location
 - statement explaining that the public will have an opportunity to be heard
- **File Affidavit.** An affidavit must be filed with the Development Services Department prior to the public hearing certifying the notices have been sent. Provide a list of the property owners notified and a copy of the sent notice .

2. Notice Signs.

- **Post Sign.** The applicant shall post a sign on the premises, at least 15 days prior to the date of the hearing, informing the general public of the time and place of the public hearing. When revised plans are submitted, staff will prepare the sign and provide it to the applicant for posting.
- **Maintain Sign.** The applicant shall make a good faith effort to maintain the sign for at least the 15 days immediately preceding the date of the hearing, through the hearing, and through any continuances of the hearing. The sign shall be placed within 5 feet of the street right-of-way line in a central position on the property that is the subject of the hearing. The sign shall be readily visible to the public. If the property contains more than one street frontage, one sign shall be placed on each street frontage so as to face each of the streets abutting the land. The sign may be removed at the conclusion of the public hearing(s) and must be removed at the end of all proceedings on the application or upon withdrawal of the application.

Analysis of Vacation of Right-of-Way:

Planning Review	Hector Soto Jr. (816) 969-1238	Senior Planner Hector.Soto@cityofls.net	No Comments
Engineering Review	Gene Williams, P.E. (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Corrections
Traffic Review	Erin Ralovo	Senior Staff Engineer Erin.Ravolo@cityofls.net	No Comments
GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	Corrections

1. It appears public sanitary sewer and public storm lines are contained within the right of way. There is also the possibility the public water main is within this area. We will either need to retain an easement, or ensure the easements are shown on the plat. Correction required.

1. Description (legal) is missing second-to-last call (64.15) from the drawing.