

DEVELOPMENT SERVICES

**Commercial Preliminary Development Plan
Applicant's Letter**

Date: Monday, March 31, 2025

To:

Property Owner: KRAFT THOMAS
ANTHONY-TRUSTEE

Email:

Applicant: Steve Kraft

Email: kraftt@lawnandleisure.com

From: Daniel Fernandez, Project Manager

Re:

Application Number: PL2025056
Application Type: Commercial Preliminary Development Plan
Application Name: Lawn & Leisure of Lee's Summit
Location: 706 SE BLUE PKWY, LEES SUMMIT, MO 64063

Tentative Schedule

Planning Commission Meeting: April 10, 2025 at 05:00 PM

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Planning Commission and City Council Presentations

Presentations before the Planning Commission and City Council shall be (1) in electronic format or (2) reduced drawings for use on the document camera to display on the screen. Electronic presentations shall be on a laptop, CD-ROM, DVD, or flash drive. The City's presentation system can support Word, Excel, PowerPoint, Adobe, Windows Media Player and Internet Explorer applications. Presentation boards will no longer be allowed. The presentation(s) shall be submitted to Development Services Department staff no later than 4:00 pm on the Tuesday prior to the Planning Commission meeting.

Analysis of Commercial Preliminary Development Plan:

Planning Review	Hector Soto Jr. (816) 969-1238	Senior Planner Hector.Soto@cityofls.net	No Comments
------------------------	-----------------------------------	--------------------------------------------	-------------

Engineering Review	Sue Pyles, P.E. (816) 969-1245	Development Engineering Manager Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------------	-----------------------------------------------------------	--------------------------

1. All required engineering plans and studies, including water lines, sanitary sewers, storm drainage, streets and erosion and sediment control shall be submitted along with the final development plan. All public infrastructure must be substantially complete, prior to the issuance of any certificates of occupancy.

2. All Engineering Plan Review and Inspection Fees shall be paid prior to approval of the associated engineering plans and prior to the issuance of any site development permits or the start of construction (excluding land disturbance permit).

3. Certain aspects of the development plan will be further reviewed during the Final Development Plan phase of the project. This includes detailed aspects of the design to help ensure that the plan meets the design criteria and specifications contained in the Design and Construction Manual.

4. Private parking lots shall follow Article 8 of the Unified Development Ordinance for pavement thickness and base requirements.

Traffic Review	Erin Ralovo (816) 969-1800	Senior Staff Engineer Erin.Ravolo@cityofls.net	No Comments
-----------------------	-------------------------------	---------------------------------------------------	-------------

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	------------------------------------------	--------------------------

1. IFC 506.1 - Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type listed in accordance with UL 1037, and shall contain keys to gain necessary access as required by the fire code official. 506.1.1 Locks. An approved lock shall be installed on gates or similar barriers when required by the fire code official.

Gates shall have Knox padlocks.