

From: Ryan McCormick
To: Steve LaCasse, PE
Subject: Hydrant Flow Data - 1231 NW WARD RD Lee's Summit MO
Date: Wednesday, April 9, 2025 8:13:00 AM
Attachments: image.png

Good morning Steve, here's the requested flow information:



Flow Test
8/27/24

Static PSI: 100
Residual PSI: 89

Static PSI: 98
Residual PSI: 70
Flow GPM: 2250

Ryan McCormick, Operations Technician
1200 SE Hamblen Road | Lee's Summit, MO 64081
816.969.1900 | lswater.net | Ryan.McCormick@cityofls.net



CONFIDENTIALITY NOTICE: "This electronic message transmission (including any accompanying attachments) from www.cityofls.net is intended solely for the person or entity for its intended recipient(s) and may contain information that is confidential, privileged, or otherwise protected from disclosure. The information contained is intended solely for the use of the individual(s), organization(s) or entity(ies) named above. If you have received this transmission but are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or use of the contents of this message is strictly prohibited. If you have received this e-mail in error, please contact sender immediately by Reply e-mail and delete/destroy the original message and all copies."

Although this e-mail and any attachments are believed to be free of any virus or other defect that might negatively affect any computer system into which it is received and opened, it is the responsibility of the recipient to ensure that it is virus free and no responsibility is accepted by the sender for any loss or damage arising in any way in the event that such a virus or defect exists.