

Project		Catalog #		Type	
Prepared by		Notes		Date	



McGraw-Edison GLEON Galleon

Area / Site Luminaire

Product Features



Product Certifications




Connected Systems

- WaveLinx PRO Wireless
- WaveLinx LITE Wireless
- Enlighted

Quick Facts

- Lumen packages range from 4,200 - 80,800 (34W - 640W)
- Efficacy up to 156 LPW
- Options to meet Buy American and other domestic preference requirements

Dimensional Details



Number of Light Squares	"A" Width	"B" Standard Arm Length	"B" Extended Arm Length	"B" OML Arm Length	"B" OML Length	"B" OMLA Length
1-4	15-1/2"	7"	10"	10-5/8"	--	16-9/16"
5-6	21-5/8"	7"	10"	10-5/8"	--	16-9/16"
7-8	27-5/8"	7"	13"	10-5/8"	10-5/16"	--
9-10	33-3/4"	7"	16"	--	10-5/16"	--

NOTES:
1. Visit www.designlighting.com/specs to confirm qualifications. Not all product variations are DLC qualified.
2. EA Certified for 3000K CCT and warmer only.




PS500020EN page 1
August 8, 2024 10:35 PM

EXTERIOR LIGHT FIXTURE SCHEDULE						
MARK	MANUF.	MODEL	MOUNTING	FINISH	SOURCE	
					TYPE	LUM
"SL1"	MCGRRAW-EDISON	GLEON-SA2C-740-U-T4W	POLE	BLACK	LED	14,559LUM/115W
"SL2"	MCGRRAW-EDISON	GLEON-SA2C-740-U-T4FT	POLE	BLACK	LED	14,371LUM/115W

NOTES:

- 1 MOUNT AT 15' AFF.
- 2 MOUNT ON SSS POLE

STATISTICS					
Description	Avg	Max	Min	Max/Min	Avg/Min
Parking Lot	1.5 fc	6.0 fc	0.1 fc	60.0:1	15.0:1
Property Line	0.0 fc	0.5 fc	0.0 fc	N/A	N/A



1 SITE PHOTOMETRIC
PHOTOMETRIC
1" = 30'-0"



ARCHITECT
B+A ARCHITECTURE
600 BROADWAY BLVD, SUITE 290
KANSAS CITY, MO 64105
PH: 816-753-6100

CIVIL ENGINEER
OWN, INC.
8455 COLLEGE BLVD
OVERLAND PARK, KS 66210
PH: 816-777-0400

COBEY CREEK CLUBHOUSE
COBEY CREEK 2ND PLAT - S29, T47N, R31W
LEE'S SUMMIT, MISSOURI

SEAL



9-20-2024

ISSUED: SEPTEMBER 19, 2024
NO. DESCRIPTION DATE

DESIGNED BY: TT/FCR
DRAWN BY: FCR
CHECKED BY: HD

THIS DRAWING IS THE PROPERTY OF B+A ARCHITECTURE AND IS NOT TO BE REPRODUCED OR COPIED IN WHOLE OR IN PART. IT IS ONLY TO BE USED FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN AND IS NOT TO BE USED ON ANY OTHER PROJECT.

SCALES AS STATED HEREON ARE VALID ON THE ORIGINAL DRAWING ONLY. CONTRACTOR SHALL CAREFULLY REVIEW ALL DIMENSIONS AND CONDITIONS SHOWN HEREON AND AT ONCE REPORT TO THE ARCHITECT ANY DISCREPANCIES OR OMISSIONS DISCOVERED.

SITE PHOTOMETRIC

E-001