



Response comments for ADA intersection - SOWP North, PL2024260
Commercial Final Development Plan

Engineering Review

1. Extend plan views to show all tie-in points. Add dimensions of the tie-ins to aid construction in the field. **Added dimensions.**
2. Add sidewalk geometric information for the southwest quadrant of the west intersection. Add turning space slope and cross slope, with call outs no greater than 1.5%, for the northwest and the northeast quadrant of the east intersection. **Revised.**
3. Add build information for the black areas between the curb ramps of the east intersection. **Added labels to C.102.**
4. Add a note to remove the existing sidewalk/curb ramp in the northwest quadrant of the west intersection. Show removal of the existing curb ramp in the northeast quadrant of the west intersection. **Added labels.**
5. Add the City Standard Detail GEN-3A for sidewalk/ramps. **Added.**
6. Typical "asphalt" pavement sections show "concrete" as the pavement material, please revise for clarity. **Revised.**