

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Tuesday, May 27, 2025

To:

Property Owner: PREMIER RE OF LEES SUMMIT LLC Email:

Architect: Falk Architects Email: bryan@falk-architects.com

Engineer/Surveyor: United Engineering Group Email: jladson@unitedeng.com

From: Grant White, Project Manager

Re:

Application Number: PL2025001

Application Type: Commercial Final Development Plan

Application Name: Hyundai Premier Auto Outlet

Location: 1231 NW WARD RD, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:**Required Corrections:**

Engineering Review	Gene Williams, P.E. (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------------	---	--------------------------

1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee, water tap and meter setup fee, and sanitary sewer impact fee) have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$89,052.98
2. Prior to the commencement of any construction activities, the Contractor shall contact Field Engineering Inspections at (816) 969-1200 to schedule a project coordination meeting with the assigned Field Engineering Inspector.
3. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2018 International Fire Code.

Traffic Review	Erin Ralovo (816) 969-1800	Senior Staff Engineer Erin.Ravolo@cityofls.net	Corrections
-----------------------	-------------------------------	---	-------------

1. The street light sign should be lighted. Please provide the correct equipment.
2. Add R3-4 NO U-TURN sign to NE Quadrant
3. Add Pedestrian signs R10-3 at push buttons.
4. Install ONLY pavement markings in Left and Right Turn Lanes.
5. City Details should be in plans as is and not marked out. All equipment should be installed per City details
6. Video detection will need to be provided for the new leg of the intersection. Please specify Iteris Next camera and related wiring.