

# City of Lee's Summit

PUBLIC WORKS DEPARTMENT/ENGINEERING DIVISION  
220 SE Green Street  
Lee's Summit, Missouri 64063  
(816) 969-1800 FAX (816) 969-1810

Tuesday, February 21, 2012

Applicant: Engineering Surveys & Services  
1113 Fay Street  
Columbia, MO 65201

Re: Engineering Plan Review  
Wilshire Hills Street, Sanitary and Storm Sewer Improvements  
PL2011067

Dear: Engineering Surveys & Services

The Public Works Department received drawings for this site dated January 18, 2012. These plans were received by our department on January 27, 2012. We have completed our review and offer the following comments:

1. Please label the station number where the lateral is connected to the sanitary sewer main.
3. Please remove the 5 foot stub out for future connection on the southernmost manhole. The City of Lee's Summit does not allow for future stub-offs (i.e., future connections must be core drilled).
4. Please provide the capacity of sedimentation basin #3. The capacity may be a stand-alone (i.e., email, etc.) document.
5. Sheet 24 contains Drawing ESC-19, Sediment Fence Drop Inlet Protection. Drawing ESC-19 may represent an ineffective use of silt fence. Deletion of Drawing ESC-19 from the plans is recommended. If this is acceptable to the Engineer, the City would be agreeable to marking an "X" through the drawing with the reviewers initials.

Feel free to contact Gene Williams at (816) 969-1812 or e-mail to [Gene.Williams@cityofls.net](mailto:Gene.Williams@cityofls.net) should you have any questions or comments.

Sincerely,

Gene Williams, P.E.  
Senior Staff Engineer